

**Questions from the Neighbourhood Liaison Committee Meeting
April 12, 2007**

During the Meeting:

- Percent of odour to be generated from T building? – approximately 10%
- Purpose of washroom near T-building? – to serve park users

Following the Formal Presentation:

1. What are the portions of odours from various sources
 - Aeration tanks and primary tanks is about 90%
2. What is the Total Cost (including P building)? Are they approved by City Council?
 - A budget of for the various projects are approved by City Council
 - P building budget alone is approximately \$150M
3. Construction – will it be odourous?
 - Yes – sludge facility construction will be odourous
 - The construction will be ongoing – all year – no limits on the time of year
4. Where will the new biofilter exhaust?
 - to a stack or stacks on the site in order to disperse it the air
 - an evaluation of the location of the stack(s) will be based on economics, odour, efficiency
5. When are Ministry of the Environment approvals expected?
 - To be negotiated with Ministry of the Environment
 - City's policy is to have full permit in hand prior to beginning construction
 - Submission to Ministry of the Environment for C of A in June
6. Odour concentration?
 - Top of stack – output
 - POI – dilution output
7. Permits prior to emission or air, water?
 - Yes – very little change to permit requirements
 - Levels of new standards apply

Comment cards may be forwarded to:

Ms. Shiri Pasternak, Public Consultation, City of Toronto

Spaster2@toronto.ca

55 John St., Toronto, ON M5V 3C6