Attachment 5: Jurisdictional Scan of Date Ranges and Temperature Thresholds

Municipality	Minimum Temperature Standard
Ajax	At least 20 degrees Celsius between Sept. 15 and May 31
Barrie	At least 20 degrees Celsius
Belleville	At least 21 degrees Celsius between Sept. 15 and May 31
Brampton	At least 20 degrees Celsius between Sept. 15 and June 1
Brantford	At least 21 degrees Celsius
Cornwall	At least 21 degrees Celsius during the day, 16 degrees at night
Guelph	At least 21 degrees Celsius
Hamilton	At least 20 degrees Celsius from Sept. 15 to May 15
Kingston	At least 21.1 degrees Celsius from Sept. 15 to June 1
Kitchener	At least 20 degrees Celsius
London	At least 20 degrees Celsius from Sept. 15 to June 15 between 6:00 am and 11:00 pm and a minimum temp of 18 degrees Celsius at all other times
Mississauga	At least 20 degrees from Sept. 15 to June 1 (Adequate Temp.)
Niagara Falls	At least 22 degrees from Sept. 15 to May 31
North Bay	At least 21 degrees
Oakville	At least 20 degrees from Sept. 1 to June 15
Oshawa	At least 22 degrees from Sept. 1 to June 15
Ottawa	At least 20 degrees
Peterborough	At least 70 degrees (21 C) Fahrenheit from Sept. 15 to May 31
Pickering	At least 18 degrees
Richmond Hill	At least 20 degrees
Sarnia	At least 20 degrees
Sault Ste. Marie	At least 21 degrees
St. Catharines	At least 20 degrees from Sept. 15 to June 1
Sudbury	At least 21 degrees
Thunder Bay	At least 21 degrees
Calgary	22 degrees (TBC)
Chicago	From September 15 to June 1, the temperature inside a rental
	residence is required to be at least 68°F (20°C) from 8:30 AM to
	10:30 PM, and at least 66°F (~19°C) from 10:30 PM to 8:30 AM.
Montreal	At least 21 degrees
New York City	Between October 1 and May 31, landlords must heat according to
	the following: -Between 6 AM and 10 PM, if the outside
	temperature falls below 55°F (~13°C), the inside temperature
	must be at least 68°F (20°C)Between 10 PM and 6 AM, the
	inside temperature must be at least 62°F (~17°C) at all times.
	There is no outside temperature requirement.
Vancouver	At least <u>22 degrees</u>

Attachments to Establishing a Framework to Address Excessive Indoor Temperatures in Leased Residential Premises

Attachment 5: Jurisdictional Scan of Bylaw Date Ranges and Temperature Thresholds