AECOM


Present Disinfection Practices and Solution for the Future Ashbridges Bay Treatment Plant

MTORONTO


Presentation Outline

- Project Background
- Overview of ABTP Existing Infrastructure and Flow Management
- Primary Effluent Disinfection
 - Chlorination / Dechlorination
- Secondary Effluent Disinfection
 - UV Disinfection
- Conclusions

DI TORONTO



AECOM



Project Background

-Berris Mermanis



Project Background

- New Federal Wastewater Systems Effluent Regulation requires 0.02 mg/L chlorine residual by end of 2015
- Current operation No dechlorination at ABTP
- 2009 Class EA Study recommended Chlor/Dechlor for disinfection at ABTP
- Council directed staff to provide UV disinfection (secondary effluent)
- New disinfection solution must work with existing plant layout and tie-in to future system





Current ABTP Disinfection System


- Liquid chlorine used for disinfection. Delivered by rail.
- No dechlorination
- No chlorine contact tank.
 Dose in secondary outlet conduits. Contact time in conduits and outfall
- Limited disinfection of primary bypass effluent





ABTP Proposed Future Disinfection Solution

 Secondary treated flows -Ultraviolet (UV) disinfection



- Primary effluent bypass -Chlorination/Dechlorination
 - Liquid sodium hypochlorite and sodium bisulphite






Overview of Existing Infrastructure and Flow Management

1.11



Key conduits and channels





AECOM

Current Operational Strategy 818 MLD

11

the prose lites

Full treatment provided



Current Operational Strategy 818 MLD

409 MILE

Full treatment provided

MIG

818





409 MLD

Outfall 818 MILD

Current Operational Strategy 2,000 MLD

Full treatment for maximum 2-hours After 2 hrs: full treatment of 818 MLD; remainder of primary effluent bypassed



Current Operational Strategy 2000 MLD

3.000 M

MILE

000

- Full treatment for maximum 2-hours
- After 2 hrs: full treatment of 818 MLD; remainder of primary effluent bypassed

DA TORONTO





-

700 MLD

ies

300

Outfall 1,100 MLD

Current Operational Strategy 3,300 MLD

Full treatment up to 2,000 MLD for max 2-hours After 2 hrs: full treatment of 818 MLD; remainder of primary effluent bypassed



Current Operational Strategy 3300 MLD

1,650

832 ML

Full treatment up to 2,000 MLD for max 2-hours

After 2 hrs: full treatment of 818 MLD; remainder of primary effluent bypassed

DA TORONTO

818





1,050 MILD

600 1010

Outfall 1.100 MLD

Primary and Secondary Disinfection Locations

Outlet from Plant

Combined Primary / **Secondary Disinfection** Facility





Primary Effluent West

combined Effluent East

Solution Two Disinfection Locations

Primary Effluent Disinfection

Secondary Effluent Disinfection Facility

DA TORONTO



13



Primary Effluent Disinfection

-Berth HELT



Primary Effluent Disinfection – Where???

a40

Retrofit Primary Tanks???

Demolish Digesters ???







Primary Effluent Disinfection

Retrofit Primary Tanks 1 & 2 into Chlorine Contact Tanks








Average Flow Conditions





AECOM

Secondary Bypass Flow Condition








Secondary Effluent Disinfection UV Disinfection

In the



Advancements in UV Lamp Technology








Various Lamp Technologies at ABTP

Lamp Technology	Number of Lamps Required	Power Draw
Low Pressure – High Output	4,720	1,180 kW
Medium Pressure – High Output	1,680	4,300 kW
New Low Pressure – Very High Output	1,408	1,280 kW





UV System Site Plan







AECOM

UV System Site Plan New UV Lamp Technology






UV System Site Plan Low-Pressure High-Output Lamps







UV System Site Plan Medium Pressure Lamps





UV Building – Conceptual Design








UV Building – Conceptual Design







Tie-In to Future Outfall







Conclusions

- UV for secondary effluent disinfection. Chlorination / Dechlorination for secondary bypass effluent disinfection
- Creative but simple solution for primary bypass disinfection very little automation
- Fully disinfected effluent discharged through seawall gates by 2019
 - Only ~5 years of this operation until all effluent discharged through new outfall
- Permanent disinfection solutions that work with existing infrastructure and new future outfall





Questions?

