

2016 Annual Report



March 31, 2017



2016 ANNUAL REPORT

EXECUTIVE SUMMARY

The North Toronto Treatment Plant is one of four wastewater treatment facilities operated by the City of Toronto. Located in the Don Valley, the plant currently serves a population of about 55,000. Treated effluent is discharged to the Don River. The facility normally operates at a controlled flow rate, with a maximum capacity of 45.5 ML/day¹. Because inflow to the plant is controlled, treatment plant bypasses are not required. The plant operates under Certificate of Approval (C of A) No. 7665-7NWMH2 issued on March 26, 2009.

The average daily influent flow rate was 17.6 ML/day. Average influent concentrations for 2016 were 286 mg/L of Total Suspended Solids (TSS), 197 mg/L of Biological Oxygen Demand (BOD₅), and 5.5 mg/L of Total Phosphorus (TP).

In 2016, the plant met all final effluent parameters regulated under the Certificate of Approval. North Toronto achieved the following effluent quality in 2016:

	Certificate of Approval ¹	2016 Treated Effluent
Total Suspended Solids (TSS)	25 mg/L	3 mg/L
Carbonaceous Biological Oxygen Demand (CBOD5)	25 mg/L	2 mg/L
Total Phosphorus (TP)	1.0 mg/L	0.7 mg/L
Escheria Coli (E. Coli) ²	200 CFU / 100 mL	10.8 CFU / 100 mL
pH	6.0-9.5	7.1
Total Chlorine Residual (TCR)	0.02	SBS Presence $(P)^3$
TSS Loading Rate	1,137.5 kg/day	52.3 kg/day
CBOD ₅ Loading Rate	1,137.5 kg/day	31.1 kg/day
TP Loading Rate	45.5 kg/day	12.1 kg/day

¹Referenced from C of A No. 7665-7NWMH2 issued on March 26, 2009.

²Geometric Mean

³Sodium Bisulphite (SBS) Presence (P) detected. The presence of Bisulphite Residual confirms a TCR of 0.0 mg/l.

Sludge (raw sludge and waste activated sludge) generated at the North Toronto Treatment Plant is transferred to the North Toronto Trunk Sewer and then conveyed by gravity to the Ashbridges Bay Treatment Plant via the Coxwell Sanitary Trunk Sewer (STS) for further treatment and disposal. An average of 0.48 ML/day (0.96% TS) of co-settled sludge was transferred in 2016.

The capital projects at the plant in 2016 included Combined Sewer Overflow (CSO) Tank improvements and electrical upgrades. In addition to routine maintenance, annual calibration of effluent monitoring equipment was completed.

Annual ferrous chloride consumption was 47,946 kg as Fe. The total sodium hypochlorite volume used to disinfect the final effluent in 2016 was 108.7 m³. The total sodium bisulphite volume used for dechlorination in 2016 was 33.1 m³. Total annual consumption for potable water and hydro in 2016 was 55,900 m³ and 2.75M kWh, respectively.

The plant operating costs for 2016 totalled \$1.94M. In 2016, the North Toronto Treatment Plant had 10 employees. As of March 31, 2017, there was one health and safety incident and 13 lost time days due to work related injuries.

¹ Rated capacity of treatment plant was incorrectly reported in previous annual reports and has been corrected as shown.



2016 ANNUAL REPORT

TABLE OF CONTENTS

E	XECUT	IVE SUMMARY	i
1.	INT	RODUCTION	1
2.	OPI	ERATIONS	2
	21	Influent Quality	2
	2.1	Preliminary Treatment	2
	2.3	Primary Treatment	2
	2.4	Secondary Treatment	
	2.5	Final Effluent Quality and Disinfection	3
	2.6	Bypasses, Spills and Abnormal Events	4
	2.6.	1 Bypasses	4
	2.6.2	2 Spills and Abnormal Events	4
	2.7	Solids Handling	5
	2.8	CSO Overflow	5
	2.9	Complaints	5
	2.10	Effluent Quality Assurance or Control Measures	5
_			
3.	CA	PITAL PROJECTS AND STUDIES	6
4	МА	INTERNANCIE	7
4.	MA		
	4.1	Effluent Monitoring Equipment Calibration and Maintenance Records	7
	4.2	North Toronto Work Area	7
_			
5.	CH	EMICALS AND UTILITIES	9
	5.1	Chemicals	9
	5.1.	1 Ferrous Chloride for Nutrient Removal	9
	5.1.2	2 Sodium Hypochlorite for Disinfection	9
	5.1.	3 Sodium Bisulphite for Dechlorination	9
	5.2	Utilities	9
	5.2.	1 Water	9
	5.2.2	2 Hydro	9
_			
6.	OPI	ERATIONS AND MAINTENANCE COSTS	10
7.	HU	MAN RESOURCES	
	71	Staffing	11
	7.1	Occupational Health & Safety	11
	73	Staff Training and Development	
	74	Utility Operator Certification	
	7.5	MOECC Correspondence	
	1.0		

2016 ANNUAL REPORT

APPENDICES

- **APPENDIX A Glossary of Abbreviations**
- **APPENDIX B Plant Schematic**

APPENDIX C – Plant Performance Charts:

- Influent Flows 2015 2016
- Influent TSS and BOD₅ Concentrations
- Influent TP and TKN Concentrations
- Effluent TSS and CBOD₅ Concentrations
- Effluent TP and Ammonia Concentrations
- Effluent pH
- Effluent E.Coli Concentration

APPENDIX D – Influent and Effluent Metal Concentrations

APPENDIX E – Analytical Testing Summary

APPENDIX F – Influent Flow Meter Calibration Records

LIST OF TABLES

Table 1: Influent Parameters	2
Table 2: Primary Treatment Effluent Parameters	3
Table 3: Secondary Treatment Process Parameters	3
Table 4: Annual Average Final Effluent Parameter Limits and Performance	4
Table 5: Monthly Average Final Effluent Parameter Limits and Performance	4
Table 6: Annual Average Final Effluent Parameter Objectives and Performance	4
Table 7: Utility Consumption	9
Table 8: Operations and Maintenance Cost Breakdown	.10
Table 9: Plant Staffing	.11
Table 10: Wastewater Treatment Certificates	.13
Table 11: Correspondence submitted to the MOECC for North Toronto Treatment Plant	.13



2016 ANNUAL REPORT

1. INTRODUCTION

The North Toronto Treatment Plant is one of four wastewater treatment facilities operated by the City of Toronto under the responsibility of the Wastewater Treatment section of Toronto Water. The plant is located in the Don Valley on a 27.2 ha site serving a sewershed of approximately 3,060 ha, and a connected population of approximately 55,000.

Commissioned in 1929, North Toronto was one of the first plants in North America to use the biological activated sludge process. The plant operates at a controlled uniform rate and is rated for 45.5 ML/day². Wastewater in excess of the controlled rate is diverted to the North Toronto Trunk Sewer and then conveyed by gravity to the Ashbridges Bay Treatment Plant via the Coxwell STS.

Major treatment processes include screening and grit removal, primary treatment, secondary treatment, phosphorus removal, effluent disinfection and dechlorination. Treated effluent is discharged to the Don River. Co-settled sludges (raw sludge and waste activated sludge) are transferred to the Ashbridges Bay Treatment Plant for disposal via the Coxwell STS. Numerous auxiliary systems are required for proper operation of many plant processes including: potable water, process water, heating, ventilation and air conditioning, electrical power distribution, gas, chemicals, instrument air, etc.

The Ministry of the Environment and Climate Control (MOECC) has classified the North Toronto Treatment Plant as a Class III wastewater treatment facility under Regulation 129/04. The facility operates under the C of ANo. 7665-7NWMH2 issued on March 26, 2009.

This report is a summary of plant operation and performance in 2016. In addition to a discussion of effluent quality and the plant's success in meeting treatment objectives, the report contains summaries of 2016 plant operations, maintenance, chemicals and utilities, costs and human resources.

² Rated capacity of treatment plant was incorrectly reported in previous annual reports and has been corrected as shown.



2016 ANNUAL REPORT

2. OPERATIONS

2.1 Influent Quality

The plant operates at a controlled uniform rate. Wastewater in excess of the controlled rate is diverted to the North Toronto Trunk Sewer and then conveyed by gravity to the Ashbridges Bay Treatment Plant via the Coxwell STS.

A summary of annual flow and influent parameter concentrations is shown in Table 1. The plant experienced a 12% decrease in influent flow from 2015 to 2016, as two primary clarifiers were taken out of service for four months. A comparison of monthly influent flow rates and characteristics for 2016 is illustrated in Appendix C.

Parameter	2016	2015	2014	2013
Influent Flow [ML/day]	17.6	20.0	23.2	24.4
Total Annual Flow [ML]	6,422	7,281	8,481	8,703
Influent TSS [mg/L]	286	268	229	212
Influent BOD ₅ [mg/L]	197	206	169	149
Influent TP [mg/L]	5.5	5.5	4.4	4.0

Table 1: Influent Parameters

Influent concentrations for eleven (11) select metals have been included in Appendix D and presented against the sewer Bylaw limits for comparison purposes only.

2.2 **Preliminary Treatment**

Wastewater enters the Head House, which provides a grit and screenings removal operation. There is one automatic climber type bar screen, with bars spaced at 1.27 centimetre openings. The bar screen removes rags and large pieces of debris from the wastewater. Grit channels located downstream of the screen remove sand, gravel and similar heavy inorganic material by gravity separation. The grit and screenings are collected and hauled to a sanitary landfill site.

The quantity of grit and screenings removed by the grit channels and mechanical bar screen averaged approximately 306.6 kg/day in 2016.

2.3 Primary Treatment

After the grit channels, the next step in the wastewater treatment process is Primary Clarification where the velocity of flow entering the clarifier tanks is reduced, allowing the heavier solids in the wastewater to settle to the bottom by gravity. Sludge collectors in the tanks sweep the settled sludge into a sludge hopper located on the bottom of the tank, from where the sludge is pumped to the Ashbridges Bay Treatment Plant via Coxwell STS. There are four square Primary Clarifiers, each with dimensions of $15.2 \text{ m x} \ 15.2 \text{ m x} \ 3.5 \text{ m}.$

Table 2 contains a summary of key primary treatment effluent parameter concentrations in 2016.

A portion of waste activated sludge from the Final Clarifiers is diverted to the primary clarifiers to cosettle with the raw sludge.

2016 ANNUAL REPORT

Parameter	2016	Primary Removal Efficiency	2015	Primary Removal Efficiency
TSS [mg/L]	100	64%	116	57%
CBOD ₅ [mg/L]	89	43% ¹	89	45% ^{1, 2}

Table 2: Primary Treatment Effluent Parameters

¹C of A No. 7665-7NWMH2 issued on March 26, 2009 condition 9 requires BOD₅ monitoring for influent flows and CBOD₅ monitoring for effluent flows. Therefore removal efficiency calculation assumes *influent CBOD₅* = *influent BOD₅* * 0.8. ²Quantity was incorrectly reported in 2015 and has been corrected as shown.

2.4 Secondary Treatment

In the activated sludge process, effluent from the Primary Clarifiers is mixed with Return Activated Sludge from the Final Clarifiers and aerated. The activated sludge is made up of naturally occurring bacteria and other micro-organisms. The micro-organisms use oxygen and dissolved organics in the wastewater for their metabolic functions and in doing so purify the wastewater. There are eight aeration Tanks, each with dimensions of 99.4 m x 3.96 m x 3.2 m. Aeration Tanks No. 1 to 4 are part of the original plant construction in 1929. Aeration Tanks No. 5 to 8 were added in 1932.

The mixed liquor from the Aeration Tanks flows to large quiescent Final Clarifiers where the activated sludge is allowed to settle. A controlled quantity of this sludge is "returned" to the Aeration Tanks to repeat the treatment process, and excess quantities are removed as Waste Activated Sludge to the Primary Clarifiers. There are five Final Clarifiers, two tanks with dimensions of 19.8 m x 3.2 m, and three tanks with dimensions of 19.8 m x 19.8 m x 4.87 m. Final Clarifiers #1 and #2 are part of the original plant construction in 1929. Final Clarifiers No. 3 to 5 were added in 1932.

A summary of key aeration basin parameters is shown in Table 3.

Parameter	2016	2015	2014
Aeration Loading [kg CBOD ₅ / m ³ ·day] ¹	0.15	0.17	0.17
Mixed Liquor Suspended Solids [mg/L]	2,439	2,317	2,434

¹Quantity was incorrectly reported in 2015 and has been corrected as shown.

2.5 Final Effluent Quality and Disinfection

Through operating and maintaining preliminary, primary and secondary treatment processes, final effluent is treated to meet Condition (6)(2)(c) of C of A. Treated effluent is disinfected with Sodium Hypochlorite and dechlorinated with Sodium Bisulphite (SBS) before it is discharged into the Don River. As required by Condition (9)(5) of C of A, SBS is being monitored as a surrogate to Total Chlorine Residual (TCR). Presence of Bisulphite residual confirms that chlorine has been removed to a level of 0.0 mg/L TCR.

In 2016, the North Toronto Treatment Plant encountered no abnormal operating problems, and continued to produce a high quality effluent which surpassed requirements of the plant's C of A. This was achieved through continuous improvement in operations and maintenance of the treatment process, and infrastructure delivery. The plant also met Federal Government effluent monitoring requirements, including un-ionized ammonia and acute toxicity.

A summary of key final effluent parameters, limits and objectives is shown in Table 4, Table 5 and Table 6. Details of the final effluent characteristics are presented in graphical form in Appendix C.

2016 ANNUAL REPORT

Table 4: Annual Average	e Final Effluent P	arameter Limits	and Performance
-------------------------	--------------------	-----------------	-----------------

Parameter	C of A Limit ¹	2016	Removal Efficiency	2015	Removal Efficiency
TSS [mg/L]	25	3	99%	4	99%
CBOD ₅ [mg/L]	25	2	99% ²	2	99% ²
pH	6.0 - 9.5	7.1	-	7.4	-
TSS Loading Rate [kg/day]	1,137.5	52.3	-	71.3	-
CBOD ₅ Loading Rate [kg/day]	1,137.5	31.1	-	42.9	-
TP Loading Rate [kg/day]	45.5	12.1	-	13.4	-

¹Referenced from condition 7 of C of A No. 7665-7NWMH2 issued on March 26, 2009.

 2 C of A No. 7665-7NWMH2 issued on March 26, 2009 condition 9 requires BOD₅ monitoring for influent flows and CBOD₅ monitoring for effluent flows. Therefore a correction factor of CBOD₅ = 0.8*BOD₅ has been applied for removal efficiency calculations and reporting.

Table 5: Monthly Average Final Effluent Parameter Limits and Performance

Parameter	C of A Limit ¹	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
TP [mg/L]	1.0	0.7	0.9	0.6	0.6	0.8	0.7	0.5	0.7	0.6	0.9	0.7	0.6
E-Coli ² [CFU/100mL]	200	2.1	38.5	10.9	34.1	1.0	1.0	1.3	16.1	5.3	15.3	3.0	1.0
TCR ³ [mg/L]	0.02	SBS (P)											

¹Referenced from condition 7 of C of A No. 7665-7NWMH2 issued on March 26, 2009.

²Monthly Geometric Mean

³SBS Presence (P) detected. The presence of Bisulphite Residual confirms a TCR of 0.0 mg/L.

Table 6: Annual Avera	ge Final Effluen	t Parameter Ob	jectives and	Performance
	2		9	

Parameter	C of A Objective ¹	2016
TSS [mg/L]	15	3
CBOD ₅ [mg/L]	15	2
TP [mg/L]	0.9	0.7
pH	6.0-8.5	7.1
TCR [mg/L]	0.0	SBS $(P)^2$
E.Coli ³ [CFU/100 mL]	150	10.8

¹Referenced from condition 6 of C of A No. 7665-7NWMH2 issued on March 26, 2009.

²SBS Presence (P) detected. The presence of Bisulphite Residual confirms a TCR of 0.0 mg/L. ³Arithmetic Mean of Monthly Geometric Means.

Secondary treatment effluent concentrations for eleven (11) select metals have been included in Appendix D.

2.6 Bypasses, Spills and Abnormal Events

2.6.1 Bypasses

Because inflow to the plant is controlled, treatment plant bypasses are not required.

2.6.2 Spills and Abnormal Events

There were no instances of spills and abnormal events in 2016.



2016 ANNUAL REPORT

2.7 Solids Handling

All sludge (raw sludge and waste activated sludge) generated at the North Toronto Treatment Plant is transferred to the Ashbridges Bay Treatment Plant for further treatment. The sludge generated during 2016 averaged 0.48 ML/day (0.96% TS). The flow projections for 2017 do not exceed the rated plant capacity of 45.5 ML/day and are expected to generate a sludge volume that will be +/-5% of the given volume for 2016.

2.8 CSO Overflow

The North Toronto Combined Sewer Detention System operates under Environmental Compliance Approval 2854-9H4JKF, issued May 2, 2014. The CSO Tanks provide holding capacity for combined sewer overflows resulting from wet weather flow conditions. After a wet weather event, the collected CSO is pumped to the Ashbridges Bay Treatment Plant for treatment. Under excessive flow conditions, the CSO Tanks will overflow into the outfall to the Don River. CSO Tank upgrades commenced in 2014 and the tanks have been out of service since then. The CSO tank construction is in its final stage with anticipated completion in 2017.

2.9 Complaints

There were no odour or noise complaints received in 2016.

2.10 Effluent Quality Assurance or Control Measures

Analytical tests to monitor required parameters are performed by the Toronto Water Laboratory which is accredited to ISO/IEC 17025 by Canadian Association for Laboratory Accreditation Inc. (CALA).



2016 ANNUAL REPORT

3. CAPITAL PROJECTS AND STUDIES

As part of the Toronto Water Capital Program, North Toronto Treatment Plant commenced or continued with the following capital works projects in 2016:

- CSO Tank Improvements
- Electrical Upgrades Project
- New Coxwell Bypass



2016 ANNUAL REPORT

4. MAINTENANCE

The North Toronto Treatment Plant performed a variety of scheduled, preventative, predictive and breakdown maintenance on a diverse spectrum of equipment. The main goal of maintenance activities is to ensure equipment availability to meet plant process operation requirements.

The following is a summary of significant maintenance accomplishments over the past year. These activities are considered to be Minor Modifications and were carried out as per Condition 11, as required by conditions 10(6)(c) and (j) of the C of A.

4.1 Effluent Monitoring Equipment Calibration and Maintenance Records

Flow to the plant is measured by effluent flow meters. The annual calibration of flow meters and on-line analysers for regulated parameters was completed in 2016, and found to be within acceptable limits. Calibration records are attached in Appendix F. The pH/temperature meter was calibrated in-house by the plant technician on November 4th, 2016.

4.2 North Toronto Work Area

The North Toronto work area includes all major and auxiliary processes. In addition to routine maintenance, the following maintenance was completed at the North Toronto Treatment Plant in 2016:

Process specific maintenance projects:

- Aeration System Improvements:
 - Replaced blown air stones and repaired damaged stone seats in Aeration Tanks
 - o Repaired various leaks and gaskets in the air piping system
 - Installed a new type of air distribution system unit in Aeration Tank No. 3 as a test unit trial
 - Installed dissolved oxygen (D.O.) sensors to improve monitoring and air demand balancing
 - Installed new D.O. sensors head unit for Aeration Tanks No. 7 and 8
 - D.O. sensors in all 8 Aeration Tanks were linked and connected to the plant's SCADA system
 - Operations Coordination Engineers involved in plant's process improvement studies
- Rebuilt two Drop Shaft Screens (the inlet screens to the plant)
- Bar Screen checks and repairs completed
- Rebuild of Primary Clarifier No. 3 Drive, and checks to scrapers and concrete structure.
- Overhauled Primary Pumps No. 1 and 2
- Overhauled Primary Macerator Grinder No. 2
- Replaced Sodium Bisulphite Pump No. 4
- Replaced pump discs on one Sodium Hypochlorite Pump
- External mechanical float system renewed for Sodium Hypochlorite Storage Tanks
- Replaced Ferrous Pump
- Overhauled Waste Activated Sludge Pump No. 4
- Boiler tubes inspected and repaired by outside contractor
- New automatic composite sampler installed for final effluent
- Chimney repairs completed by outside contractor



2016 ANNUAL REPORT

General area maintenance projects:

- Renovated washroom in the Administration building for use by female workers
- New large concrete pad fabricated behind the Old Filter Building to accommodate a future outdoor storage cage



2016 ANNUAL REPORT

5. CHEMICALS AND UTILITIES

5.1 Chemicals

Several chemicals are used for a variety of treatment processes at the plant. Major process chemicals are discussed below and include:

- Ferrous Chloride (Nutrient Removal)
- Sodium Hypochlorite (Disinfection)
- Sodium Bisulphite (Dechlorination)

5.1.1 Ferrous Chloride for Nutrient Removal

Ferrous chloride consumption for nutrient removal (i.e. phosphorus) during 2016 was approximately 47,946 kg as Fe. This is an 8.5% increase from 2015. Ferrous chloride is applied to the distribution conduits to the aeration tanks, at which primary effluent and return activated sludge are mixed. The average ferrous chloride dosage rate was 7.7 mg/L as Fe during the year.

Ferrous chloride for nutrient removal was purchased at a cost of \$800 per tonne Fe, plus applicable taxes.

5.1.2 Sodium Hypochlorite for Disinfection

Sodium hypochlorite is used for disinfection of the final effluent. In 2016, approximately 108.7 m³ was consumed for this purpose, representing a 17.1% decrease in consumption from 2015.

Sodium Hypochlorite was purchased at an average cost of \$129 per 1,000 L, plus applicable taxes.

5.1.3 Sodium Bisulphite for Dechlorination

Sodium Bisulphite was used as a dechlorination agent. The total sodium bisulphite usage in 2016 was 33.1 m³, representing a 33.7% decrease in consumption from 2015. This resulted from the decreased flows that were directed through the plant.

Sodium Bisulphite was purchased at an average cost of \$265 per tonne, plus applicable taxes.

5.2 Utilities

A summary of utility consumption for the previous two years at North Toronto Treatment Plant is provided in Table 7, below.

Table 7: Utility Consumption

Utility	2016	2015	2014
Water [m ³ / month]	4,658	3,758	3,674
Hydro [kWh / month]	229,183	231,830	207,484

5.2.1 Water

Total potable water consumption increased 23.9% from 2015 to an annual use of 55,900 m³. Total cost for potable water was \$203,007. The average unit cost of water was \$3.63 per cubic meter.

5.2.2 Hydro

Total energy consumption decreased 1.1% from 2015 to an annual use of 2.75M kWh. Total cost for hydro was \$398,591. The average unit cost power was \$0.14 per kWh.

2016 ANNUAL REPORT

6. OPERATIONS AND MAINTENANCE COSTS

Plant operations and maintenance costs are broken down into five (5) categories: Salaries and Benefits, Materials and Supplies, New Equipment, Services and Rents and Other Charges. Materials & Supplies is further segregated into Utilities (power and water), Machine and Equipment Parts, Chemicals and Other Materials and Supplies. The total cost of plant operation in 2016 was \$1.94M. A breakdown of 2016 annual operations and maintenance costs is shown in Table 8 and illustrated in Figure 1.

Operating Cost	2016	2015
Salaries and Benefits	\$1,024,845	\$820,569
Materials and Supplies		
Utilities	\$652,809	\$531,641
Machine and Equipment Parts	\$49,817	\$43,809
Chemicals	\$80,436	\$111,660
Other Materials and Supplies	\$59,357	\$76,840
New Equipment	\$9,871	\$27,025
Services and Rents	\$38,719	\$65,103
Other Charges	\$26,863	\$21,891
TOTAL PROGRAM COST:	1,942,716	1,698,538

 Table 8: Operations and Maintenance Cost Breakdown



Figure 1: North Toronto Treatment Plant Operations and Maintenance Cost Breakdown for 2016



2016 ANNUAL REPORT

7. HUMAN RESOURCES

7.1 Staffing

In 2016, the North Toronto Treatment Plant had 10 positions. Plant Staffing is shown in Table 9:

Table 9: Plant Staffing

Position Title	Number
Supervisor, Operational Support	1
EICT	1
Plant Technicians	1
Development Plant Technicians	2
Industrial Millwrights	4
Wastewater Plant Worker	1

7.2 Occupational Health & Safety

Continuous efforts are made in maintaining a safe working environment at the North Toronto Treatment Plant facility. The Joint Health and Safety Committee assists management in resolving issues through monthly meetings and Plant Audits.

Plant Health and Safety statistics for the North Toronto Treatment Plant in 2016 were as follows:

Incident	0	
First Aid	0	
Medical Aid	0	
Lost Time	1	
Recurrence	0	
Total	1	

As of March 31, 2017, there were 13 lost time days due to work related injuries in 2016.

7.3 Staff Training and Development

Toronto Water's Strategic Planning and Workforce Development team has developed a comprehensive Operator Training Program that expands the abilities of the operational staff, resulting in better service to the public. All North Toronto Treatment Plant operating staff and skilled trades staff attended the training. Plant Technicians are consistently taking training to meet their mandatory 40 hours of training for the year.

The training in 2016 included:

- a) Technical and Health and Safety Training:
 - 2015 Ontario Electrical Safety Code (26th Edition) New And Amended Requirements General Level 1
 - 2015 Ontario Electrical Safety Code (26th Edition) New And Amended Requirements General Level 2
 - Arc Flash Awareness For Non-Electrical Personnel
 - Backflow Prevention Awareness (2016-2018)
 - Conductors (2016-2018)

2016 ANNUAL REPORT

- Confined Space Awareness
- Confined Space Entry and Rescue Training Awareness
- Electrical Safety For Maintenance Staff (2016-2018)
- Emergency First Aid Level 'A' CPR (2016-2018)
- Emergency Response Information For Employees With Disabilities (May Tailgate)
- Equipment: Inspect It Before You Use It (August Tailgate)
- Fall Protection Awareness
- Fundamentals Of Ladder Safety Awareness
- Hot Work Permit System Awareness (2016-2018)
- Level "C" CPR Renewal (2016-2018)
- Lifting Safely Posture Matters (February Safety Tailgate)
- Lock Out, Tag Out and Test Awareness (2016-2018)
- Lockout, Tag Out And Test Awareness
- Mathematics For Operators: Module 1 (2016-2018)
- Rigging Safety Awareness (2016-2018)
- Safety In A High Voltage Environment (2016-2018)
- Scaffolding Awareness Course (2016-2018)
- Slip-Free, Trip-Free, Fall-Free (November Tailgate)
- Transportation Of Dangerous Goods (2016-2018)
- Wastewater Laboratory Procedures (2016-2018)
- Workplace Hazardous Materials Information System Training
- Worker Health And Safety Awareness In 4 Steps
- Working At Heights (2016-2018)
- b) Other Training:
 - Accessibility for Ontarians with Disabilities Act Ontario Human Rights Commission
 - Conflict Of Interest Part 2
 - Conflict Resolution And Negotiation Skills
 - Customer Service Essentials For Administrative Support And Frontline Staff
 - Fraud Prevention And Whistleblower Protection Part 2
 - Parks Annual Health and Safety Orientation
 - Positive Space Toronto Module 1
 - Protecting Privacy On The Job
 - The Toronto Public Service By-Law E-learning
 - West Nile
 - Workplace Innovation: Critical Thinking And Creative Problem Solving



2016 ANNUAL REPORT

7.4 Utility Operator Certification

Toronto Water has incorporated the requirement of a Class 1 operating licence into the job profiles of the skilled trades in the Water and Wastewater Treatment facilities.

Table 10 summarizes the status of operator certification at the North Toronto Treatment Plant for 2016.

Table 10: Wastewater Treatment Certificates

Class Level	Licensed
Class IV	2
Class III	1
Class II	1
Class I	5
O.I.T.	0
TOTAL	9

7.5 MOECC Correspondence

Table 11 summarizes the correspondence submitted to the MOECC for North Toronto Treatment Plant.

Date	Туре	Description					
June 24, 2016	Meeting minutes regarding a meeting between City and MOECC on North Toronto CSO Tank Expansion.	Communication with Loralyn Wild, MOECC Water Inspector, regarding updated meeting minutes.					
September 16, 2016	North Toronto CSO Tank Project - Update on Construction Status and Progression to Stage 2.	Report on Contractor's Progress - Progression to Stage 2.					
September 21, 2016	Updated Wet Weather Management Plan for CSO Tank.	Provided Melissa Hills, MOECC Water Inspector, with updated Wet Weather Management Plan as per Interim Approval Letter issued on July 14 th , 2015.					
December 15, 2016	North Toronto CSO Tank Project - Update on Construction Status and Completion of Stage 2.	Report on Contractor's Progress – Completion of Stage 2.					
	Consent Lett	ers					
N/A	N/A	N/A					
	Notice of Star	t-up					
N/A	N/A	N/A					
	MOE Inspection						
No Inspection.							

Table 11: Correspondence submitted to the MOECC for North Toronto Treatment Plant

Appendix A

Glossary of Abbreviations

Glossary of Abbreviations

ABTP	Ashbridges Bay Treatment Plant
BOD ₅	Five-Day Biological Oxygen Demand (in some instances this may be referred to as BOD)
CBOD ₅	Five-Day Carbonaceous Biological Oxygen Demand
CEU	Continuing Education Units
CFU	Colony Forming Units
C of A	Certificate of Approval
CPR	Cardiopulmonary Resuscitation
CSO	Combined Sewer Overflow (Tank)
DAF	Air Flotation
D.O.	Dissolved Oxygen
ECA	Environmental Compliance Approval
E. Coli	Escheria Coli
ha	Hectare
НСТР	Highland Creek Treatment Plant
HTP	Humber Treatment Plant
HP	Horsepower
HRT	Hydraulic Retention Time
kg	Kilogram
kg/dav	Kilogram per day
kWh	Kilowatt-hour
kWh/month	Kilowatt-hour per month
MWh	Megawatt-hour
m	Metre
m ³	Cubic metre
m ³ /month	Cubic metre per month
Μ	Million
MCC	Motor Control Centre
mA	milliamps
mg/L	Milligrams per litre
mĽ	Millilitre
ML	Megalitre
ML/day	Megalitre per day
MOECC	Ministry of Environment and Climate Change
No.	Number
Р	Presence
MTI	Mid-Toronto Interceptor Forcemain
NTTP	North Toronto Treatment Plant
SBS	Sodium Bisulphite
SCADA	Supervisory Control and Data Acquisition
STS	Sanitary Trunk Sewer
SS	Suspended Solids
TCR	Total Chlorine Residual
ТР	Total Phosphorus
TS	Total Solids
TSS	Total Suspended Solids
TVS	Total Volatile Solids
TWAS	Thickened Waste Activated Sludge
μg/L	micrograms per litre
WAS	Waste Activated Sludge

Appendix B

Plant Schematic



Process Flow Diagram for North Toronto Wastewater Treatment Plant

Appendix C

Plant Performance Charts

- Influent Flows 2015 2016
- Influent TSS and BOD₅ Concentrations
- Influent TP and TKN Concentrations
- Effluent TSS and CBOD₅ Concentrations
- Effluent TP and Ammonia Concentrations
- Effluent pH
- Effluent E.Coli Concentration















Appendix D

Influent and Effluent Metal Concentrations

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: January 2016

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0140	mg/L	0.0400	
	Iron	0.0857	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0389	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0368	mg/L	0.0400	
INFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.102	mg/L	2.0000	
	Iron	0.756	mg/L		
	Lead	< 0.005	mg/L	1.0000	
	Manganese	0.0415	mg/L	5.0000	
	Mercury	< 0.00006	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.0988	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 25-Feb-2016 /

Toronto Water

Central Laboratory (545 Commissioners Street, # Toronto,Ontario, M4M 1A5

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: February 2016

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0154	mg/L	0.0400	
	Iron	0.114	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	<u>0.0518</u>	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	<u>0.0418</u>	mg/L	0.0400	
INFLUENT	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	0.00446	mg/L	4.0000	
	Copper	0.128	mg/L	2.0000	
	Iron	1.18	mg/L		
	Lead	0.00677	mg/L	1.0000	
	Manganese	0.0579	mg/L	5.0000	
	Mercury	0.00009100	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.133	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 18-Mar-2016 /

TORONTO WATER LABORATORY Treatment Plant Monthly Metal Analysis for: March 2016

Tel: 416-392-2894 Fax: 416-397-0342

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
Monthly Metals at Dee - FINAL EFFLUENT La	ab BasenAentenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0137	mg/L	0.0400	
	Iron	0.131	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0427	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0356	mg/L	0.0400	
Monthly Metals at Dee INFLUENT	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.110	mg/L	2.0000	
	Iron	0.934	mg/L		
	Lead	< 0.005	mg/L	1.0000	
	Manganese	0.0491	mg/L	5.0000	
	Mercury	0.0001350	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.105	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 03-May-2016 /

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: April 2016						
DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES	
North Toronto Treatment Plant						
FINAL EFFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	0.0200		
	Cadmium	< 0.004	mg/L	0.0080		
	Chromium	< 0.004	mg/L	0.0800		
	Copper	0.0119	mg/L	0.0400		
	Iron	0.117	mg/L			
	Lead	< 0.005	mg/L	0.1200		
	Manganese	0.0412	mg/L	0.0500		
	Mercury	< 0.00006	mg/L	0.0004		
	Nickel	< 0.005	mg/L	0.0800		
	Zinc	0.0351	mg/L	0.0400		
INFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	1.0000		
	Cadmium	< 0.004	mg/L	0.7000		
	Chromium	< 0.004	mg/L	4.0000		
	Copper	0.0932	mg/L	2.0000		
	Iron	0.927	mg/L			
	Lead	< 0.005	mg/L	1.0000		
	Manganese	0.0472	mg/L	5.0000		
	Mercury	0.0001910	mg/L	0.0100		
	Nickel	< 0.005	mg/L	2.0000		
	Zinc	0.107	mg/L	2.0000		

Notes: All Results in mg/L. These samples are monthly composites. /

Underlined Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 16-May-2016 /

TORONTO WATER LABORATORY Treatment Plant Monthly Metal Analysis for: May 2016

Tel: 416-392-2894 Fax: 416-397-0342

DESCRIPTION	<u>NAME</u>	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0112	mg/L	0.0400	
	Iron	0.146	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0477	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0368	mg/L	0.0400	
INFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.111	mg/L	2.0000	
	Iron	0.975	mg/L		
	Lead	0.00792	mg/L	1.0000	
	Manganese	0.0490	mg/L	5.0000	
	Mercury	0.0001060	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.126	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 29-Jun-2016 /

TORONTO WATER LABORATORY Treatment Plant Monthly Metal Analysis for: June 2016

Tel: 416-392-2894 Fax: 416-397-0342

<u>DESCRIPTION</u>	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	<u>NOTES</u>
North Toronto Treatment Plant					
FINAL EFFLUENT- Monthly Metals at Dee	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0183	mg/L	0.0400	
	Iron	0.254	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0388	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	<u>0.0447</u>	mg/L	0.0400	
INFLUENT- Monthy Metals at Dee	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.117	mg/L	2.0000	
	Iron	0.790	mg/L		
	Lead	0.00653	mg/L	1.0000	
	Manganese	0.0454	mg/L	5.0000	
	Mercury	0.0001160	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.128	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 29-Jul-2016 /

TORONTO WATER LABORATORY Treatment Plant Monthly Metal Analysis for: July 2016

Tel: 416-392-2894 Fax: 416-397-0342

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly @ Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0173	mg/L	0.0400	
	Iron	0.148	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0500	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0369	mg/L	0.0400	
INFLUENT - Monthly @ Dee.	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	0.00511	mg/L	4.0000	
	Copper	0.110	mg/L	2.0000	
	Iron	1.74	mg/L		
	Lead	0.0107	mg/L	1.0000	
	Manganese	0.0726	mg/L	5.0000	
	Mercury	0.0001590	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.144	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 30-Aug-2016 /

TORONTO WATER LABORATORY Treatment Plant Monthly Metal Analysis for: August 2016

Tel: 416-392-2894 Fax: 416-397-0342

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly Meatls @ Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0114	mg/L	0.0400	
	Iron	0.105	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0190	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0342	mg/L	0.0400	
INFLUENT - Monthly Meatls @ Dee.	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	0.00476	mg/L	4.0000	
	Copper	0.155	mg/L	2.0000	
	Iron	1.64	mg/L		
	Lead	0.00924	mg/L	1.0000	
	Manganese	0.0627	mg/L	5.0000	
	Mercury	0.00008900	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.165	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 03-Oct-2016 /

TORONTO WATER LABORATORY

Tel: 416-392-2894 # Fax: 416-397-0342 #

Treatment Plant Monthly Metal Analysis for: September 2016 (

DESCRIPTION	NAME	RESULT	<u>UNITS</u>	LIMITS	<u>NOTES</u> /
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly Metals at Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0158	mg/L	0.0400	
	Iron	0.345	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0258	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	0.0393	mg/L	0.0400	
INFLUENT - Monthly Metals at Dee.	Arsenic	<0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.121	mg/L	2.0000	
	Iron	0.850	mg/L		
	Lead	0.00602	mg/L	1.0000	
	Manganese	0.0417	mg/L	5.0000	
	Mercury	0.0001490	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.120	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 31-Oct-2016 /

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: October 2016

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
EFFLUENT Monthly Metals	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0189	mg/L	0.0400	
	Iron	0.365	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0266	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	<u>0.0416</u>	mg/L	0.0400	
INFLUENT Monthly Metals	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.123	mg/L	2.0000	
	Iron	0.843	mg/L		
	Lead	0.00672	mg/L	1.0000	
	Manganese	0.0461	mg/L	5.0000	
	Mercury	0.00007500	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.129	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 01-Dec-2016 /

Toronto Water

Central Laboratory (545 Commissioners Street, # Toronto,Ontario, M4M 1A5

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: November 2016

DESCRIPTION	NAME	<u>RESULT</u>	<u>UNITS</u>	LIMITS	NOTES
North Toronto Treatment Plant					
FINAL EFFLUENT	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0198	mg/L	0.0400	
	Iron	0.422	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	0.0292	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	<u>0.0483</u>	mg/L	0.0400	
INFLUENT	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.142	mg/L	2.0000	
	Iron	0.878	mg/L		
	Lead	0.00675	mg/L	1.0000	
	Manganese	0.0502	mg/L	5.0000	
	Mercury	0.0001050	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.160	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 04-Jan-2017 /

TORONTO WATER LABORATORY

Tel: 416-392-2894 Fax: 416-397-0342

Treatment Plant Monthly Metal Analysis for: December 2016

DESCRIPTION	NAME	RESULT	<u>UNITS</u>	LIMITS	<u>NOTES</u>
North Toronto Treatment Plant					
FINAL EFFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	0.0200	
	Cadmium	< 0.004	mg/L	0.0080	
	Chromium	< 0.004	mg/L	0.0800	
	Copper	0.0209	mg/L	0.0400	
	Iron	0.502	mg/L		
	Lead	< 0.005	mg/L	0.1200	
	Manganese	<u>0.0604</u>	mg/L	0.0500	
	Mercury	< 0.00006	mg/L	0.0004	
	Nickel	< 0.005	mg/L	0.0800	
	Zinc	<u>0.0491</u>	mg/L	0.0400	
INFLUENT - Monthly Metals @ Dee.	Arsenic	< 0.01	mg/L	1.0000	
	Cadmium	< 0.004	mg/L	0.7000	
	Chromium	< 0.004	mg/L	4.0000	
	Copper	0.140	mg/L	2.0000	
	Iron	1.26	mg/L		
	Lead	0.00797	mg/L	1.0000	
	Manganese	0.126	mg/L	5.0000	
	Mercury	0.00008700	mg/L	0.0100	
	Nickel	< 0.005	mg/L	2.0000	
	Zinc	0.149	mg/L	2.0000	

Notes: All Results in mg/L. These samples are monthly composites. /

<u>Underlined</u> Results have exceeded respective Sanitary or Storm Sewer Bylaw limits of the Sewer Use Bylaw Chapter 681 of the Toronto Municipal Code. limits. /

Date Report Printed: 16-Jan-2017 /

Appendix E

Analytical Testing Summary

01/03/2016 From: To: Number of Samples: 1338

12/31/2016

North Toronto Treatment Plant

	ALK pH DS COND	BOD	CBOD	Chlorine	ECOLI	Ferric Chloride	IONS	Mercury	METALS	NH3 (as N)	Р	pH_15	SPGR	Sulphite	TKN (as N)	Toxicity	тs	TSS	Un-ionized NH3 (as N)	TOTAL
COMBINED SEWER OVERFLOW	0	1	8	0	9	0	0	0	0	9	10	0	0	0	9	0	0	11	0	57
CUSTOM SAMPLE POINT	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3
FINAL EFFLUENT	66	0	52	54	55	0	504	12	110	51	151	29	0	49	51	12	0	56	25	1,277
INFLUENT	0	52	0	0	0	0	0	12	108	51	151	0	0	0	51	0	0	56	0	481
MIXED LIQUOR COMPOSITE	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	293	0	293
NTTP FE SAMPLE	0	0	0	0	0	64	0	0	0	0	0	0	6	0	0	0	0	0	0	70
PRIMARY EFFLUENT	0	0	52	0	0	0	0	0	0	0	0	0	0	0	0	0	0	55	0	107
RAW SLUDGE	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	291	0	0	291
RETURN SLUDGE 1&2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	168	0	168
RETURN SLUDGE 3-4&5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	169	0	169
TOTAL	66	53	112	54	67	64	504	24	218	111	312	29	6	49	111	12	291	808	25	2,916

Ions include: Cl, SO4, NO3, NO2, Br, Ca, Mg, Na, K Metals by ICP include: Cd, Cr, Cu, Ni, Pb, Zn, Al, Mn, Fe, B

Volatile Total Solids (VS) are done on 80% of Total Solids

Volatile Suspend Solids (VSS) are done on 2% of the Total Suspended Solids samples

TORONTO WATER LABORATORY

Tel: 416-392-2894 ! Fax: 416-397-0342 !

Sampling Point:	TNT01	INFLUENT &

Group:	BOD	Minimum	Maximum	Average	Units	Reporting Limit	
Biochemica	l Oxygen Demand (BOD)	61.00	330.00	187.13	mg/L	<2	
Group:	METALS	Minimum	Maximum	Average	Units	Reporting Limit	
Arsenic		0.010000	0.01000	0.01000	mg/L	<0.01	
Cadmium		0.004000	0.00400	0.00400	mg/L	<0.004	_
Chromium		0.004000	0.00510	0.00430	mg/L	<0.004	
Copper		0.093200	0.15500	0.11578	mg/L	<0.004	
Iron		0.756000	1.74000	1.11775	mg/L	<0.02	
Lead		0.005000	0.01070	0.00701	mg/L	<0.005	
Manganese		0.041500	0.07260	0.05318	mg/L	<0.004	
Nickel		0.005000	0.00500	0.00500	mg/L	<0.005	
Zinc		0.098800	0.16500	0.12585	mg/L	<0.02	
Group:	Mercury	Minimum	Maximum	Average	Units	Reporting Limit	
Mercury		0.000100	0.00020	0.00013	mg/L	<0.00003	
Group:	NH3(as N)	Minimum	Maximum	Average	Units	Reporting Limit	
Ammonia(a	s N)	15.00	37.00	28.14	mg/L	<0.05	
Group:	Р	Minimum	Maximum	Average	Units	Reporting Limit	
Phosphorus	s (HACH)	2.70	9.50	5.33	mg/L	<0.08	
Group:	TKN(as N)	Minimum	Maximum	Average	Units	Reporting Limit	
Total Kjeld	ahl Nitrogen	24.00	46.20	38.61	mg/L	<0.2	
Group:	TSS	Minimum	Maximum	Average	Units	Reporting Limit	_
Total Suspe	nded Solids	108.00	524.00	260.80	mg/L	<2	
Volatile Sus	pended Solids				%		

Sampling Point: TNT02 PRIMARY EFFLUENT

Group:	CBOD	Minimum	Maximum	Average	Units	Reporting Limit	
Carbonace	ous Biochemical Oxygen Demand	17.00	154.00	88.95	mg/L		
Group:	TSS	Minimum	Maximum	Average	Units	Reporting Limit	
Total Suspe	ended Solids	40.00	264.00	102.00	mg/L	<2	
Volatile Sus	spended Solids				%		

Sampling Point: TNT03

FINAL EFFLUENT

Group: ALK pH DS COND	Minimum	Maximum	Average	Units	Reporting Limit
Alkalinity	55.20	76.30	68.93	mg/L	<1.6
Conductivity	799.00	847.00	821.71	µS/cm	<1.5
рН	7.60	7.90	7.71	SU	<0.10
Group: CBOD	Minimum	Maximum	Average	Units	Reporting Limit
Carbonaceous Biochemical Oxygen Demand	2.00	9.00	2.60	mg/L	<2
Group: Chlorine	Minimum	Maximum	Average	Units	Reporting Limit
Total Residual Chlorine	0.40	1.20	0.75	mg/L	<0.01
Group: ECOLI	Minimum	Maximum	Average	Units	Reporting Limit
D ()0					

Comment &							
EColi		0.00	1,500.00	96.44	CFU/100 mL		
Group: IONS		Minimum	Maximum	Average	Units	Reporting Limit	
Bromide		0.200000	2.75000	2.49865	mg/L	<0.1	
Calcium		54.400000	189.00000	85.63514	mg/L	<0.2	
Chloride		104.000000	1,540.00000	193.62162	mg/L	<0.2	
Hardness (Calculation)		192.000000	745.00000	281.29730	mg/L	<1	
Magnesium		12.800000	66.20000	16.40270	mg/L	<0.1	
Nitrate(as N)		0.275000	19.30000	13.26230	mg/L	< 0.01	
Nitrite(as N)		0.055000	1.76000	0.58873	mg/L	< 0.002	
Potassium		6.750000	270.00000	16.11973	mg/L	<0.05	
Sodium		64.000000	1,030.00000	123.43243	mg/L	<0.4	
Sulfate		39.500000	129.00000	47.05676	mg/L	<0.2	
Group: METALS		Minimum	Maximum	Average	Units	Reporting Limit	
Aluminium		0.050000	0.05000	0.05000	mg/L	<0.05	
Arsenic		0.010000	0.01000	0.01000	mg/L	< 0.01	
Cadmium		0.004000	0.00400	0.00400	mg/L	< 0.004	
Chromium		0.004000	0.00400	0.00400	mg/L	< 0.004	
Copper		0.011200	0.01830	0.01415	mg/L	< 0.004	
Iron		0.085700	0.25400	0.13759	mg/L	< 0.02	
Lead		0.005000	0.00500	0.00500	mg/L	< 0.005	
Manganese		0.019000	0.05180	0.04126	mg/L	< 0.004	
Nickel		0.005000	0.00500	0.00500	mg/L	< 0.005	
Tin		0.010000	0.01000	0.01000	mg/L	< 0.01	
Zinc		0.034200	0.04470	0.03774	mg/L	<0.02	
Group: Mercury		Minimum	Maximum	Average	Units	Reporting Limit	
Mercury		0.000100	0.00010	0.00010	mg/L	< 0.00003	
Group: NH3(as N)		Minimum	Maximum	Average	Units	Reporting Limit	
Ammonia(as N)		0.05	3.20	1.09	mg/L	< 0.05	
Group: P		Minimum	Maximum	Average	Units	Reporting Limit	
Phosphorus (HACH)		0.27	1.40	0.68	mg/L	< 0.08	
Group: Sulphite		Minimum	Maximum	Average	Units	Reporting Limit	
Sulphite_P_A					mg/L		
Group: TKN(as N)		Minimum	Maximum	Average	Units	Reporting Limit	
Total Kjeldahl Nitrogen		0.73	6.18	1.84	mg/L	<0.2	
Group: TSS		Minimum	Maximum	Average	Units	Reporting Limit	
Total Suspended Solids		2.00	6.00	2.44	mg/L	<2	
Volatile Suspended Solids					%		
Group: Toxicity		Minimum	Maximum	Average	Units	Reporting Limit	
96h Mortality		0.00	0.00	0.00		F8	
96h LC50		100.00	100.00	100.00	%		
 Un-ionized Ammonia		0.00	0.01	0.00	mg/L		
Group: Un-ionized	NH3(as N)	Minimum	Maximum	Average	Units	Reporting Limit	
Ammonia(as N)Un-ionized	l (Calculation)	0.00	0.03	0.01	mg/L	< 0.001	
Group: pH 15	()	Minimum	Mavimum	Δverage	I Inite	Reporting Limit	
оноцр. рн_13 nH 15C		7 20	7 70	7 15	SU	Acporting Dimit	
<u></u>		1.20	1.10	/. + ./	50		
Sampling Point:	TNT05 F	RAW SLUDGE					

Page 2 of 3

Average

Units Re

Reporting Limit &

Valadic Tural Solids 65:00 90:00 75:54 % Sampling Point: TNT19 MIXED LIQUOR COMPOSITE Group: TSS Minimum Average Units Reporting Limit Total Suppended Solids 1,200.00 1,460.00 2,446.73 mgl. <2 Valadic Suppended Solids 64:20 \$1.00 73.30 % Group: TSS Minimum Maximum Average Units Reporting Limit Total Suppended Solids 2,690.00 7,350.00 5,036.96 mgl. <2 Valadic Suppended Solids 2,690.00 7,350.00 5,036.96 mgl. <2 Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Group: TSS Minimum Maximum Average Units Reporting Limit Total Suppended Solids 2,500.00 7,700 6.756 % Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum	Total Solids	0.20	3.70	1.06	%			
Sampling Point: TNT19 MIXED LIQUOR COMPOSITE Group: TSS Minimum Maximum Average Units Reporting Limit Total Superaded Solids 64.20 81.00 73.10 % Sampling Point: TNT20 RETURN SLUDGE 1&2 Group: TSS Minimum Maximum Average Units Reporting Limit Total Superaded Solids 2.990.00 7.350.00 5.036.96 mgL <2 Mathic Superaded Solids 2.900.00 7.300.00 5.056.96 mgL <2 Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Group: TSS Minimum Maximum Average Units Reporting Limit Total Superaded Solids 2.500.00 7.400.00 5.258.80 mgL <2 Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: ROD Minimum Maximum Average Uni	Volatile Total Solids	63.60	90.00	75.54	%			
Group: TSS Minimum Maximum Average Units Reporting Limit Total Supended Solids 64.20 81.00 73.10 % Sampling Point: TNT20 RETURN SLUDGE 1&2 Group: TSS Minimum Maximum Average Units Reporting Limit Total Supended Solids 2.690.00 7.350.00 5.056.96 mg/L <2 Valarité Supended Solids 2.690.00 7.350.00 5.056.96 mg/L <2 Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Group: TSS Minimum Maximum Average Units Reporting Limit Total Supended Solids 2.500.00 7.400.00 5.258.80 mg/L <2 Valarité Supended Solids 2.500.00 7.400.00 5.258.80 mg/L <2 Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum Maximum Average Units Reporting Limit Group: CBOD Minimum Maximum Average Units Reporting Limit Group: CBOD Minimum Maximum Average	Sampling Point: TNT19	mpling Point: TNT19 MIXED LIQUOR COMPOSITE						
Total Suspended Solids 1,740.00 3,400.00 2,446,73 mg/L ~2 Valatile suspended Solids 64.20 81.00 73.10 % Sampling Point: TNT20 RETURN SLUDGE 1&2 Group: TSS Minimum Maximum Average Units Reporting Limit Total Suspended Solids 2,690.00 7,350.00 5,036.96 mg/L ~2 Valatile suspended Solids 2,690.00 7,400.00 5,258.80 mg/L ~2 Valatile Suspended Solids 2,200.00 7,400.00 5,258.80 mg/L ~2 Valatile Suspended Solids 2,400.00 7,400.00 5,258.80 mg/L ~2 Valatile Suspended Solids 64.40 70.70 67.56 % Sampling Point: TNT22 COMBINED SEWER OVER/ELOW Group: BOD Minimum Maximum Average Units Reporting Limit Group: COL1 Minimum Maximum Average Units Reporting Limit Group: FCOL1	Group: TSS	Minimum	Maximum	Average	Units	Reporting Limit		
Valuatie Saspended Solids 64.20 81.00 73.10 % Sampling Point: TNT20 RETURN SLUDGE 1&2 Group: TSS Minimum Maximum Average Units Reporting Limit Total Supended Solids 2.600.00 7.550.00 5.085.96 mg/L <2	Total Suspended Solids	1,740.00	3,460.00	2,446.73	mg/L	<2		
Sampling Point:TNT20RETURN SLUDGE 1&2Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids64.5071.0068.07%-2Sampling Point:TNT21RETURN SLUDGE 3-4&5Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids2,500.007,400.005,258.80mg/L<2Valatic Sanpended Solids64.4070.7067.56%Sampling Point:TNT22COMBINED SEWER OVERFLOWGroup:BODMinimumMaximumAverageUnitsReporting LimitBiachemical Oxygen Demand9.0010.00mg/L<2Group:EODMinimumMaximumAverageUnitsReporting LimitCarbonaceous Biochemical Oxygen Demand9.00120.0054.86mg/L<2Group:EOLMinimumMaximumAverageUnitsReporting LimitGroup:COLIMinimumMaximumAverageUnitsReporting LimitGroup:FCOLIMinimumMaximumAverageUnitsReporting LimitGroup:N13(08.0019.00120.007.86mg/L<0.05Group:N13(163.N)MinimumMaximumAverageUnitsReporting LimitAmonid(os N)1.9017.007.86mg/L<0.05Group:TNT28Minimum	Volatile Suspended Solids	64.20	81.00	73.10	%			
Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids64.5071.0068.07%Valatile Suspended Solids64.5071.0068.07%Sampling Point:TNT21RETURN SLUDCE 3-4&5Reporting LimitTotal Suspended Solids2,500.007,400.005,258.80mg/L<2Valatile Suspended Solids2,500.007,000.005,258.80mg/L<2Valatile Suspended Solids64.4070.7067.56%Sampling Point:TNT22COMBINED SEWER OVER ELOWReporting LimitGroup:BODMinimumMaximumAverageUnitsReporting LimitBischemical Oxygen Demand9.00120.00548.86mg/L<2Group:CBODMinimumMaximumAverageUnitsReporting LimitGroup:CBOLMinimumMaximumAverageUnitsReporting LimitGroup:CBOLMinimumMaximumAverageUnitsReporting LimitGroup:REDU131.000.002,260.000.011,263.444.44CFU/100 mLGroup:NIB(Ia N)MinimumMaximumAverageUnitsReporting LimitGroup:NIB(Ia CI)0.953.602.08mg/L<0.08Group:TKN(as N)MinimumMaximumAverageUnitsReporting LimitTotal Stephended Solids5.501.301.26	Sampling Point: TNT20	RETURN SLUI)GE 1&2					
Total Suspended Solids 2,690,00 7,250,00 5,056,96 mg/L <2 Valatile Suspended Solids 64.50 71.00 68.07 % Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Reporting Limit Group: TSS Minimum Maximum Average Units Reporting Limit Total Suspended Solids 64.40 70.70 67.36 % Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum Maximum Average Units Reporting Limit Group: COD Minimum Maximum Average Units Reporting Limit Group: COD Minimum Maximum Average Units Reporting Limit EColi 13,000.00 2,360,000.00 1,263,444.44 CTU/100 mL Group: Reporting Limit Group: PI Minimum Maximum Average Units Reporting Limit Group: N13(as N) 190 17.00 7.86 m	Group: TSS	Minimum	Maximum	Average	Units	Reporting Limit		
Valarik Suspended Solids 64.50 71.00 68.07 % Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Group: TSS Minimum Maximum Average Units Reporting Limit Total Suspended Solids 2,500.00 7,400.00 5,258.80 mg1. <2	Total Suspended Solids	2,690.00	7,350.00	5,036.96	mg/L	<2		
Sampling Point: TNT21 RETURN SLUDGE 3-4&5 Group: TSS Minimum Maximum Average Units Reporting Limit Tatal Suspended Solids 2,500,00 7,400,00 5,238,80 mgL -2 Volatile Suspended Solids 64.40 70.70 67.56 % Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum Maximum Average Units Reporting Limit Group: CBOD Minimum Maximum Average Units Reporting Limit Carbonaceous Biochemical Oxygen Demand 9.00 120.00 54.86 mgL -2 Group: COLI Minimum Maximum Average Units Reporting Limit Carbonaceous Biochemical Oxygen Demand 9.00 120.00 54.86 mgL -2 Group: COLI Minimum Maximum Average Units Reporting Limit Group: NIH3(as N) Minimum Maximum Average Units Reporting Limit Annonola(av N) 1.90	Volatile Suspended Solids	64.50	71.00	68.07	%			
Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids2,500.007,400.005,258.80mg/L<2	Sampling Point: TNT21	RETURN SLUI)GE 3-4&5					
Total Suspended Solids 2,500.00 7,400.00 5,258.80 mg/L <2	Group: TSS	Minimum	Maximum	Average	Units	Reporting Limit		
Volatile Suspended Solids 64.40 70.70 67.56 % Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum Maximum Average Units Reporting Limit Biochemical Oxygen Demand (BOD) 10.00 10.00 10.00 mg/L Group: CBOD Minimum Maximum Average Units Reporting Limit Carbonaccoss Biochemical Oxygen Demand 9.00 120.00 54.86 mg/L <2 Group: CCOLI Minimum Maximum Average Units Reporting Limit EColi 131,000.00 2,360,000.00 1,263,444.44 CFU/100 mL Group: NH3(as N) Minimum Maximum Average Units Reporting Limit Ammonia(as N) 1.90 17.00 7.86 mg/L <0.05 Group: P Minimum Maximum Average Units Reporting Limit Automotia(as N) Minimum Maximum Average Units Reporting Limit Iotal Kjeldah Nirogen 4.80 25.7	Total Suspended Solids	2,500.00	7,400.00	5,258.80	mg/L	<2		
Sampling Point: TNT22 COMBINED SEWER OVERFLOW Group: BOD Minimum Maximum Average Units Reporting Limit Biochemical Oxygen Demand (BOD) 10.00 10.00 mg/L	Volatile Suspended Solids	64.40	70.70	67.56	%			
Group: BOD Minimum Maximum Average Units Reporting Limit Biochemical Oxygen Demand (BOD) 10.00 10.00 10.00 mg/L Group: CBOD Minimum Maximum Average Units Reporting Limit Carbonaccous Biochemical Oxygen Demand 9.00 120.00 54.86 mg/L <2	Sampling Point: TNT22 COMBINED SEWER OVERFLOW							
Biochemical Oxygen Demand (BOD) 10.00 10.00 10.00 mg/L Group: CBOD Minimum Maximum Average Units Reporting Limit Carbonaceous Biochemical Oxygen Demand 9.00 120.00 54.86 mg/L <2 Group: ECOLI Minimum Maximum Average Units Reporting Limit EColi 131,000.00 2,360,000.00 1,263,444.44 CFU/100 mL Group: NH3(as N) Minimum Maximum Average Units Reporting Limit Ammonia(as N) 1.90 17.00 7.86 mg/L <0.05 Group: P Minimum Maximum Average Units Reporting Limit Phosphorus (HACH) 0.95 3.60 2.08 mg/L <0.05 Group: TKN(as N) Minimum Maximum Average Units Reporting Limit Total Kjeldahl Nitrogen 4.80 25.70 13.58 mg/L <0.2 Group: TS Minimum Maximum Average Units Reporting Limit </td <td>Group: BOD</td> <td>Minimum</td> <td>Maximum</td> <td>Average</td> <td>Units</td> <td>Reporting Limit</td> <td></td>	Group: BOD	Minimum	Maximum	Average	Units	Reporting Limit		
Group:CBODMinimumMaximumAverageUnitsReporting LimitCarbonaceous Biochemical Oxygen Demand9.00120.0054.86mg/L<2	Biochemical Oxygen Demand (BOD)	10.00	10.00	10.00	mg/L			
Carbonaccous Biochemical Oxygen Demand9.00120.0054.86mg/L<2Group:ECOLIMinimumMaximumAverageUnitsReporting LimitEColi131,000.002,360,000.001,263,444.44CFU/100 mLGroup:NH3(as N)MinimumMaximumAverageUnitsReporting LimitAmmonia(as N)1.9017.007.86mg/L<0.05Group:PMinimumMaximumAverageUnitsReporting LimitPhosphorus (HACH)0.953.602.08mg/L<0.08Group:TKN(as N)MinimumMaximumAverageUnitsReporting LimitTotal Kjeldahl Nitrogen4.8025.7013.58mg/L<0.2Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids56.00308.00179.11mg/L<2Volatile Suspended Solids56.00308.00179.11mg/L<2Sampling Point:TNT28NTTP FE SAMPLEVisReporting LimitAbsolute Difference0.000.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.221.301.261.261.26Supplier Specific Gravity1.231.301.26	Group: CBOD	Minimum	Maximum	Average	Units	Reporting Limit		
Group:ECOLIMinimumMaximumAverageUnitsReporting LimitECoi131,000.002,360,000.001,263,444.44CFU/100 mLGroup:NH3(as N)MinimumMaximumAverageUnitsReporting LimitAmmonia(as N)1.9017.007.86mg/L<0.05	Carbonaceous Biochemical Oxygen Demand	9.00	120.00	54.86	mg/L	<2		
EColi 131,000.00 2,360,000.00 1,263,444.44 CFU/100 mL Group: NH3(as N) Minimum Maximum Average Units Reporting Limit Ammonia(as N) 1.90 17.00 7.86 mg/L <0.05 Group: P Minimum Maximum Average Units Reporting Limit Phosphorus (HACH) 0.95 3.60 2.08 mg/L <0.08 Group: TKN(as N) Minimum Maximum Average Units Reporting Limit Total Kjeldahl Nitrogen 4.80 25.70 13.58 mg/L <0.2 Group: TSS Minimum Maximum Average Units Reporting Limit Total Suspended Solids 56.00 308.00 179.11 mg/L <2 Volatile Suspended Solids 56.00 308.00 179.11 mg/L <2 Sampling Point: TNT28 NTTP FE SAMPLE % Group: Ferric Chloride Minimum Maximum	Group: ECOLI	Minimum	Maximum	Average	Units	Reporting Limit		
Group:NH3(as N)MinimumMaximumAverageUnitsReporting LimitAmmonia(as N)1.9017.007.86mg/L<0.05	EColi	131,000.00	2,360,000.00	1,263,444.44	CFU/100 mL			
Ammonia(as N)1.9017.007.86mg/L<0.05Group:PMinimumMaximumAverageUnitsReporting LimitPhosphorus (HACH)0.953.602.08mg/L<0.08Group:TKN(as N)MinimumMaximumAverageUnitsReporting LimitTotal Kjeldahl Nitrogen4.8025.7013.58mg/L<0.2Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids56.00308.00179.11mg/L<2Volatile Suspended Solids56.00308.00179.11mg/L<2Sampling Point:TNT28NTTP FE SAMPLEUnitsReporting LimitBill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.231.301.26	Group: NH3(as N)	Minimum	Maximum	Average	Units	Reporting Limit		
Group:PMinimumMaximumAverageUnitsReporting LimitPhosphorus (HACH)0.953.602.08mg/L<0.08	Ammonia(as N)	1.90	17.00	7.86	mg/L	<0.05		
Phosphorus (HACH)0.953.602.08mg/L<0.08Group: TKN(as N)MinimumMaximumAverageUnitsReporting LimitTotal Kjeldahl Nitrogen4.8025.7013.58mg/L<0.2	Group: P	Minimum	Maximum	Average	Units	Reporting Limit		
Group:TKN(as N)MinimumMaximumAverageUnitsReporting LimitTotal Kjeldahl Nitrogen4.8025.7013.58mg/L<0.2	Phosphorus (HACH)	0.95	3.60	2.08	mg/L	<0.08		
Total Kjeldahl Nitrogen4.8025.7013.58mg/L<0.2Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids56.00308.00179.11mg/L<2Volatile Suspended Solids%Sampling Point:TNT28NTTP FE SAMPLEGroup:Ferric ChlorideMinimumMaximumAverageUnitsReporting LimitAbsolute Difference0.000.010.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.221.301.261.261.26	Group: TKN(as N)	Minimum	Maximum	Average	Units	Reporting Limit		
Group:TSSMinimumMaximumAverageUnitsReporting LimitTotal Suspended Solids56.00308.00179.11mg/L<2	Total Kjeldahl Nitrogen	4.80	25.70	13.58	mg/L	<0.2		
Total Suspended Solids56.00308.00179.11mg/L<2Volatile Suspended Solids%Sampling Point: TNT28NTTP FE SAMPLEGroup: Ferric ChlorideMinimumMaximumAverageUnitsReporting LimitAbsolute Difference0.000.010.010.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.5050Specific Gravity1.221.301.26Supplier Specific Gravity1.231.301.26	Group: TSS	Minimum	Maximum	Average	Units	Reporting Limit		
Volatile Suspended Solids%Sampling Point: TNT28NTTP FE SAMPLEGroup: Ferric ChlorideMinimumMaximumAverageUnitsReporting LimitAbsolute Difference0.000.010.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.221.301.26Supplier Specific Gravity1.231.301.26	Total Suspended Solids	56.00	308.00	179.11	mg/L	<2		
Sampling Point:TNT28NTTP FE SAMPLEGroup:Ferric ChlorideMinimumMaximumAverageUnitsReporting LimitAbsolute Difference0.000.010.010.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.221.301.26Supplier Specific Gravity1.231.301.26	Volatile Suspended Solids				%			
Group:Ferric ChlorideMinimumMaximumAverageUnitsReporting LimitAbsolute Difference0.000.010.010.01Bill of Lading #82,355,551.0082,438,203.0082,401,629.50Specific Gravity1.221.301.26Supplier Specific Gravity1.231.301.26	Sampling Point: TNT28	NTTP FE SAM	PLE					
Absolute Difference 0.00 0.01 0.01 Bill of Lading # 82,355,551.00 82,438,203.00 82,401,629.50 Specific Gravity 1.22 1.30 1.26 Supplier Specific Gravity 1.23 1.30 1.26	Group: Ferric Chloride	Minimum	Maximum	Average	Units	Reporting Limit		
Bill of Lading # 82,355,551.00 82,438,203.00 82,401,629.50 Specific Gravity 1.22 1.30 1.26 Supplier Specific Gravity 1.23 1.30 1.26	Absolute Difference	0.00	0.01	0.01				
Specific Gravity 1.22 1.30 1.26 Supplier Specific Gravity 1.23 1.30 1.26	Bill of Lading #	82,355,551.00	82,438,203.00	82,401,629.50				
Supplier Specific Gravity 1.23 1.30 1.26	Specific Gravity	1.22	1.30	1.26				
	Supplier Specific Gravity	1.23	1.30	1.26				

Note: Averages are based on raw data

Note: Minimum values are normally reported as < the reporting limit for that parameter.

Note: Average is calculated for ECOLI, if Geometric Mean is required ask the lab for a separate data file.

Appendix F

Flow Meter Calibration/Maintenance Record

MCCC	6415 Northam Drive Mississauga, ON L4V 1J2	VERIFICATION / CALIBRATION			Report No.:	011418-0001
שרובש	TEL: (905) 678-2882 FAX: (905) 293-9774		REPORT		Date:	October 3,2016
SITE:	North Toronto Treatr M4H 1P6	nent Plant 21 Redway	Road Toronto	_	SERVICE DATE:	September 29,2016
PROCESS AREA:	Final Effluent Flow	me	ETER.			
INSTR. TAG:	TNT-DCL-FIT-0002				TECHNICIAN:	John Yaworski
MANUFACTURER:	Siemens OCM III					
MODEL:	7ML-1002-0AA05				JOB REFERENCE:	011418
SERIAL No.:	PBD/A6070683					
INSTR. RANGE:	0 to 109,999.8 cubic	meters / day				
Input	(Parameters)	· · · · ·	Output	(Signal)	(Process)	
Туре:	Head (Meters)		Type or EGU:	mA	cubic meter /day	
Min:	0.0000		Min:	4.00	0.00	
Max:	0.59744		Max:	20.00	109999.8	
open channel type	rectangular weir wi	thout end contractors				
exponent	1.5					
constant	9928	(m3/hr)				
			Before C	alibration	After Calibration	
Input (meters)	Calc flow (cu m /day)	Calc. O/P (mA)	Actual ma Output	Error (%Rng)	Actual ma Output	Error (%Rng)
0.163	15680.30	6.28	6.24	-0.25%	6.24	-0.25%
0.184	18806.14	6.74	6.72	-0.10%	6.72	-0,10%
0.299	38956.49	9.67	9.55	-0.73%	9.55	-0.73%
0.395	59151.89	12.60	12.47	-0.84%	12.47	-0.04%
0.501	84494.73	16.29	16.15	-0.88%	10.15	-0.83%
0.518	88831.63	16.92	16.80	-0.76%	10.80	-0.7070
		Calib	oration Equipment			
Type: Manufacturer: Model: Serial No.: Last Cal. Date:						
Comments:	Unable to stop plant fi Calculated flow for th Unit did not require an	low to perform zero calil e rectangular weir witho ny calibration.	bration. out end contractors on	the Siemens OCM I	II was found within ra	nge.
	P1 Dimensional Units P3 Primary Element P4 Method of Calculation P5 Flow Units Cub	Meters Exponential Device on Ratiometric ic Meters / Day		P27 MA Damping P29 Fail Safe Timer P30 Fail Safe Analog P33 Flow Rate Displ	, 10 Sec 60 Seconds 3 Mode Hold Last Vi ay 2 Decimal Places	ilue

- P6 Flow at Max Head ---- 109999.8 Cubic Meters / Day
- P7 Height at Max Head ---- 0.59744 Meters
- P15 Relay 1 Assignment ---- De-energize on Echo Loss P18 Relay 2 Assignment ---- Not In Service P21 Relay 3 Assignment ---- Not In Service

P39 Data Logging Rate ---- 15 Minutes P46 Range at Zero Head ----- 1.437 Meters P47 Blanking Distance ----- 0.610169 Meters U0 Exponent ---- 1.5

VERIFICATION / CALIBRATION SUCCESSFULL

TNT Request for Services

Date SEpt. 19/2016

Issued by: <u>Sam Mallia</u> Tele: 392-9194

Please clean, inspect and calibrate:

ſ		1

Raw Sewage Meter Located in the Rack House

Note:

DIFFE RENTIAL	PRESSURE	TRANSMITTER	HAS BEEN	v
CALIBRATED .	D. PRESSURE	LINES WITS	FAULTY	1.110
INSIDE THE	CHAMPER	(UENTURI)	FAIL HEAT	INGS

Attention to this matter is required:

Immediately	L
As soon as possible	
When scheduling permits	
Other:	

Description of Work Performed:

Error Chart Recorder In (mA) Display
20

TRANS SIENAL TO Comments:

Work Performed by: : (Position) : SEPTENBER 2016 Date. Signature Please print of

TNTForms\CalibrReqstRawSew.doc

TNT Request for Services

Date Dove June 22 /14

Issued by: Sam Mallia

Please clean, inspect and calibrate:

Return 1-2-3 Meter Return 6-7-8 Meter

Located in the aeration basement

Waste Flow Meter In the aeration gallery

Note:

Attention to this matter is required:

Immediately As soon as possible When scheduling permits Other:

Description of Work Performed:

Return Flow 1-2-3		Return	Return Flow 6-7-8		e Flow 4-5	
0 – 10 m/	A = 0-315 L/sec	4 - 20 mA = 0 - 260 L/sec		0 – 10mA	= 0-52 L/sec	
	T		T /	A	I /sec	
mA	L/sec	mA	L/sec		L/Sec	
4	D	4	0	θ	0	
12	158	12	130.1	5	26.58	
2.0	315.2	20	260.4	10	53.1	

Comments:

Work Performed by: (Position):

OK

EICT

22 JUNE 2016 AMANDO GAN Signature Please print name

TNTForms\CalibrReqstRtmWste.doc

4

TNT Request f	or Services
Date Done July 27	Issued by: <u>Sam Mallia</u> Tele: 392-9194
Please clean, inspect and calibrate:	
By-Pass Chamber Flow Recorder Located in the Boiler Room	Primary Raw Sludge Meter (Pump # 1 & Pump #2) In Primary Pump House
Gas Flow Recorder Located in the Boiler Room	
Note:	
na en Xil	Immediately
Attention to this matter is required:	As soon as possible
Attendon to this matter is required.	When scheduling permits

Description of Work Performed:

By-Pass Chamber Flow 0 – 164000 m ³ / day Calibration Checked		Gas Flow 0 - 75.45 L/sec		Primary Pump # 1 4 - 20 mA = 0 -		Primary Pump # 2	
In 4 mA	Display 0	- mA	L/sec	mA	L/sec	mA	L/sec
. 4	0			Ý	0	ų 👘	0
2	41.1	01		12	7.9.	12	7.8
12	82	/	5	20	15.8	20	15.79
16	122.5						
20	164		-				

Other:

Comments: PRINKRY PUMPHOUSE, SIMULATE THE FLOW WITH POPTABLE FLOWMETER ~

Work Performed by: (Position): ______ELCT

AMANDO GAN	Don	27 JULY 2016
Please print name	7 Signature	Date

TNTForms\CalitrReqstByGasPRS.doc

Entity Number	Entity Name	Activity	Date/Time Activity Performed	Activity Performed By
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	01/05/2016 10:21	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	02/05/2016 10:55	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	03/10/2016 13:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	04/08/2016 12:20	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	05/03/2016 12:24	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	06/07/2016 7:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: TNT-DIS-941 for TNT-DCL-AIT-0001	07/08/2016 12:20	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi sulphate Analyzer-ORP-sensor check-Monthly, Ref: INI-DIS-941 for INI-DICL-AII-0001	08/10/2016 12:30	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Bi suphate Analyzer-ORP-sensor check-monthly, Ref: TNT-DIS-941107 TN1-DCL-AIT-0001	09/06/2016 8:21	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor Ref. DIS-936	01/08/2016 13:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-936	01/15/2016 12:44	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	01/22/2016 12:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	01/28/2016 12:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	02/05/2016 10:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	02/10/2016 9:10	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	02/24/2016 14:43	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	02/25/2016 12:37	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	03/02/2016 13:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	03/10/2016 13:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ker: UIS-936	03/10/2016 13:35	Milliwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-930	03/21/2010 8.00	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Pet: DIS-930	04/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-936	04/15/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	04/26/2016 7:47	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	04/29/2016 7:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	05/05/2016 14:36	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	05/12/2016 14:26	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	05/24/2016 13:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	05/30/2016 9:19	Area Supervisor
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	06/17/2016 7:50	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	06/20/2016 8:04	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	06/24/2016 14:18	EIUI
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-936	07/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-936	07/14/2016 12:22	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	07/21/2016 12:23	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	07/29/2016 12:02	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	08/12/2016 13:46	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	08/19/2016 12:47	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	08/25/2016 7:58	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	08/29/2016 10:30	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	09/07/2016 8:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	09/09/2016 12:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	09/23/2016 12:32	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Pet: DIS-930	10/21/2016 15:04	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-930	10/28/2016 14:03	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref. DIS-936	10/28/2016 14:03	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/02/2016 8:11	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/10/2016 14:42	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/14/2016 14:55	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/22/2016 7:42	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/29/2016 10:31	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/29/2016 11:39	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	11/29/2016 11:47	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	12/14/2016 13:28	Millwright
INT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Check the Analyzer sensor, Ref: DIS-936	12/29/2016 14:45	EICT Milluminet
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ket: DIS-939	01/08/2016 13:57	Nillwright
	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Kel: DIS-939 Clean the Bi sulphite chemical analyzer, Ref: DIS-939	01/10/2016 12:44	Millwright
TNT-DCL-AIT-0001	Transmitter Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref. DIS-939	01/28/2016 12:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	02/05/2016 10:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	02/10/2016 9:10	Millwright

Entity Number	Entity Name	Activity	Date/Time Activity Performed	Activity Performed By
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	02/24/2016 14:43	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	02/25/2016 12:37	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	03/02/2016 13:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	03/10/2016 13:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	03/10/2016 13:35	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphile chemical analyzer, Ref: DIS-939	03/21/2016 8:08	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphile chemical analyzer, Ref. DIS-939	04/08/2016 12:17	Milwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subhite chemical analyzer. Ref: DIS-939	04/15/2016 12:12	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	04/26/2016 7:47	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	04/29/2016 7:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	05/05/2016 14:36	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	05/12/2016 14:26	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	05/24/2016 13:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ker: DIS-939	05/30/2016 9:19	Area Supervisor Milluriabt
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphile chemical analyzer, Ref: DIS-939	06/20/2016 9:04	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphile chemical analyzer, Ref. DIS-939	06/24/2016 14:18	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subhite chemical analyzer, Ref: DIS-939	07/06/2016 14:27	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	07/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	07/14/2016 12:22	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	07/21/2016 12:23	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	07/29/2016 12:02	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	08/12/2016 13:46	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	08/19/2016 12:47	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	08/25/2016 7:58	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphile chemical analyzer, Ref. DIS-939	09/07/2016 8:15	Milwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subline chemical analyzer, Ref. DIS-939	09/09/2016 12:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subhite chemical analyzer. Ref: DIS-939	09/23/2016 12:32	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	09/26/2016 14:50	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	10/21/2016 15:04	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	10/28/2016 14:03	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	10/28/2016 14:23	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	11/02/2016 8:11	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ker: DIS-939	11/10/2016 14:42	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref. DIS-939	11/22/2016 7:42	FICT
TNT-DCI -AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subhite chemical analyzer, Ref. DIS-939	11/29/2016 10:31	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi subhite chemical analyzer. Ref: DIS-939	11/29/2016 11:39	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	11/29/2016 11:47	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	12/14/2016 13:28	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Clean the Bi sulphite chemical analyzer, Ref: DIS-939	12/29/2016 14:45	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref: TNT-FPW-1A6 for TNT-DCL-AIT-0002	01/08/2016 14:16	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref: INI-FPW-1A6 for INI-DCL-AII-0002	02/08/2016 7:23	EICI
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of C//ORP analyzer Sample Probe, Ref. TNT-FPW-1A6 for TNT-DCL-AIT-0002	03/11/2016 14:30	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of C//ORP analyzer Sample Probe Ref. TNT-FW-TAG for TNT-DCL-AIT-0002	05/06/2016 14:11	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of C/ORP analyzer Sample Probe, Ref. TNT-FPW-1A6 for TNT-DCL-AIT-0002	06/14/2016 8:04	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref: TNT-FPW-1A6 for TNT-DCL-AIT-0002	07/20/2016 15:16	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref. TNT-FPW-1A6 for TNT-DCL-AIT-0002	08/09/2016 9:17	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref: TNT-FPW-1A6 for TNT-DCL-AIT-0002	09/20/2016 15:23	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning and Calibration of CI/ORP analyzer Sample Probe, Ref: TNT-FPW-1A6 for TNT-DCL-AIT-0002	12/02/2016 14:53	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	01/06/2016 14:23	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: INI-DIS-0004 for INI-DCL-AII-0002	01/15/2016 15:01	EICI
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, UKP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. INT-DIS-0004 for INT-DUL-AIT-0002	01/22/2016 15:00	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe, weekly, Ref. TNT-DIS-0004 for TNT-DIC-AIT-0002	01/29/2010 13:38	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	02/12/2016 12:12	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	02/19/2016 11:00	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	02/25/2016 9:42	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	03/04/2016 14:05	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	03/07/2016 15:16	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	03/18/2016 19:33	EICT
INT-DCL-AIT-0002	I ransmitter, Analyzer Indicating, ORP	Uleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	03/21/2016 14:58	EIGT

Entity Number	Entity Name	Activity	Date/Time Activity Performed	Activity Performed By
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	04/01/2016 15:00	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	04/07/2016 18:59	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	04/15/2016 14:32	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	04/22/2016 14:55	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	04/27/2016 14:44	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	05/04/2016 18:59	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	05/13/2016 14:51	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	05/20/2016 15:03	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	05/26/2016 15:20	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	06/03/2016 8:33	EICT
INI-DCL-AII-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TN1-DIS-0004 for TN1-DCL-AI1-0002	06/09/2016 8:00	EICI
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Ci/ORP analyzer sample probe, weekin, Ref. INI-DIS-0004 for INI-DCL-AII-0002	06/17/2016 12:34	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Ci/OPD explores earning probe, weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	06/23/2016 7:49	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Ci/ORP analyzer sample probe, weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	07/06/2016 7:29	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Ci/ORP analyzer sample probe, weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	07/10/2016 7:36	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORF	Cleaning of the CI/OPP analyzer sample probe, weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	07/12/2010 7:30	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORF	Cleaning of the CI/OPP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	07/26/2016 7:44	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe-weekly, Ref. TNT-DIS-0004 for TNT-DCI-AIT-0002	08/03/2016 19:03	FICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe-weekly. Ref. TNT-DIS-0004 for TNT-DCI-AIT-0002	08/09/2016 9:09	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe-weekly. Ref. TNT-DIS-0004 for TNT-DCI-AIT-0002	08/17/2016 7:36	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	08/25/2016 18:52	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly. Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	09/01/2016 7:51	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	09/08/2016 18:57	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	09/14/2016 8:02	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	09/22/2016 8:17	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	09/28/2016 15:02	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	10/05/2016 19:01	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	10/13/2016 15:17	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	10/18/2016 19:02	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	10/27/2016 8:08	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	11/02/2016 8:20	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	11/10/2016 14:53	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe- weekly, Ref: TNT-DIS-0004 for TNT-DCL-AIT-0002	11/14/2016 14:40	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	11/22/2016 8:08	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Cl/ORP analyzer sample probe- weekly, Ref. INI-DIS-0004 for INI-DCL-AII-0002	11/29/2016 10:46	EICI
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the CI/ORP analyzer sample probe, weekly, Ref. INI-DIS-0004 for INI-DCL-AII-0002	12/09/2016 16:56	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORP	Cleaning of the Ci/ORP analyzer sample probe, weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	12/20/2016 7:55	EICT
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, ORF	Clearing of the Croker analyzer sample probe-weekly, Ref. TNT-DIS-0004 for TNT-DCL-AIT-0002	07/11/2016 14:09	EIGT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphile	Hypochionite and Sulphite Analyzer Calibration Annual, Ref. TNT-DIS-0002 for TNT-DCL-AIT-0001	07/11/2016 14:08	Millwright
TNT-DCL-AIT-0002	Transmitter, Analyzer Indicating, OKF	Hypochionic and Sulphite Analyzer carbatelion-Annual, Net. INT-Dis-9002 to TNT-DES-0002 Hypochionic and Sulphite Analyzer carba Benjacemant. Annual Def: TNT-DIS-0003 for TNT-DCI-AIT-0001	10/26/2016 8:32	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphile	Hypochionite and Sulphite Analyzer probe Replacement-Annual, Ref. TNT-DIS-0003 for TNT-DCL-AIT-0001 Hypochionite and Sulphite Analyzer probe Replacement-Annual, Ref. TNT-DIS-0003 for TNT-DCL-AIT-0001	10/20/2010 8:32	FICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Besidual Sulphite	Inspect the analyzer peristalic number of the analyzer period and the analyzer	01/08/2016 13:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristallic pump for signs of wear, Ref TNT-CLB-23	01/15/2016 12:44	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear. Ref. TNT-CLB-23	01/22/2016 12:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear. Ref.TNT-CLB-23	01/28/2016 12:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	02/05/2016 10:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. TNT-CLB-23	02/10/2016 9:10	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref.TNT-CLB-23	02/24/2016 14:43	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref.TNT-CLB-23	02/25/2016 12:37	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	03/02/2016 13:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	03/10/2016 13:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	03/10/2016 13:35	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	03/21/2016 8:08	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	04/06/2016 7:51	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	04/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	04/15/2016 12:12	Millwright
INT-DCL-AIT-0001	I ransmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	04/26/2016 7:47	IVIIIWright
TNT-DCL-AIT-0001	I ransmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	04/29/2016 7:52	IVIIIWright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer pensiatic pump for signs of wear, Ref. IN I-CLB-23	05/05/2016 14:36	Nilliwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristallic pump for signs of wear, Kett INT-OLB-23	05/12/2016 14:26	Milluright
	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. INT-OLB-23	05/24/2016 13:15	Area Supervisor
	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. TNT-CLD-23	00/30/2010 9:19	Millwright
1111-DOL-AIT-0001	Transmitter, Analyzer muleating, residual Sulphille	Impoor the unaryzer penatatite pump for aigna or wear, Net. TNT-OED-20	00/17/2010 7.30	manught

Entity Number	Entity Name	Activity	Date/Time Activity Performed Activity Performed By
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	06/20/2016 8:04 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	06/24/2016 14:18 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	07/06/2016 14:27 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. TNT-CLB-23	07/08/2016 12:17 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref: INI-CLB-23	07/14/2016 12:22 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. TNT-CLB-23	07/20/2016 12:23 Milliwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. TNT-CLB-23	07/29/2016 12:02 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. TNT-CLB-23	08/19/2016 12:47 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. TNT-CLB-23	08/25/2016 7:58 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	08/29/2016 10:30 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref.TNT-CLB-23	09/07/2016 8:15 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	09/09/2016 12:57 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	09/23/2016 12:32 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	09/26/2016 14:50 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref:TNT-CLB-23	10/21/2016 15:04 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref.TNT-CLB-23	10/28/2016 14:03 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. TNT-CLB-23	10/28/2016 14:23 EICT
INT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. INI-CLB-23	11/02/2016 8:11 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristalitic pump for signs of wear, Ref. INI-CLB-23	11/10/2016 14:42 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristatic pump for signs of wear, Ref. TNT-CLB-23	11/22/2016 7:42 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristance pump for signs of wear, Ref. TNT-CLB-23	11/20/2016 10:31 FICT
TNT-DCI -AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref. TNT-OLD-23	11/29/2016 11:39 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer periodatic pump for signs of wear, ref. TNT-CLB-23	11/29/2016 11:47 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear. Ref:TNT-CLB-23	12/14/2016 13:28 Millwriaht
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the analyzer peristaltic pump for signs of wear, Ref.TNT-CLB-23	12/29/2016 14:45 EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	01/08/2016 13:57 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	01/15/2016 12:44 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	01/22/2016 12:31 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	01/28/2016 12:15 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	02/05/2016 10:52 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	02/10/2016 9:10 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-940	02/24/2016 14:43 Milliwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-340	02/23/2016 12:37 Willwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample nump tubing Ref. DIS-940	03/10/2016 13:31 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing. Ref. DIS-940	03/10/2016 13:35 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	03/21/2016 8:08 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing. Ref. DIS-940	04/06/2016 7:51 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	04/08/2016 12:17 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	04/15/2016 12:12 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	04/26/2016 7:47 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	04/29/2016 7:52 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	05/05/2016 14:36 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-940	05/12/2016 14:26 Millwright
INT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-940	05/24/2016 13:15 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ker. DIS-940	05/30/2016 9:19 Area Supervisor
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-940	06/20/2016 8:04 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS-340	
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing Ref. DIS-940	07/06/2016 14:27 Millwright
TNT-DCI -AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tabing Ref. DIS-940	07/08/2016 12:17 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing. Ref. DIS-940	07/14/2016 12:22 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	07/21/2016 12:23 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	07/29/2016 12:02 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	08/12/2016 13:46 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	08/19/2016 12:47 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	08/25/2016 7:58 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	08/29/2016 10:30 Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	09/07/2016 8:15 Millwright
INI-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	09/09/2016 12:57 Millwright
TNT-DUL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ket: DIS-940	09/23/2016 12:32 Millwright
TNT DOL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref. DIS 940	10/20/2010 14:30 WIIIWHIGHL
TINT-DOL-ATT-0001	mansmiller, Analyzer mulcaling, Residual Sulphile	Inspect the sample pump tubing, Ref. DIS-940	10/21/2010 13.04 EIC1

Entity Number	Entity Name	Activity	Date/Time Activity Performed	Activity Performed By
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	10/28/2016 14:03	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	10/28/2016 14:23	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/02/2016 8:11	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/10/2016 14:42	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/14/2016 14:55	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/22/2016 7:42	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/29/2016 10:31	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/29/2016 11:39	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	11/29/2016 11:47	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	12/14/2016 13:28	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Inspect the sample pump tubing, Ref: DIS-940	12/29/2016 14:45	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Scheduled restoration of Analyzer-Sodium bi sulphate peristaltic tube, Ref DIS-30A1 for TNT-DCL-AIT-0001	10/28/2016 13:51	Maintenance Planner and Scheduler
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Verification check of the Analyzer-Sodium bi sulphate , Ref: TNT-DIS-30A2 for TNT-DCL-AIT-0001	10/28/2016 13:51	Maintenance Planner and Scheduler
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	01/08/2016 13:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	01/15/2016 12:44	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	01/22/2016 12:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	01/28/2016 12:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	02/05/2016 10:52	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	02/10/2016 9:10	Millwright
INI-DCL-AII-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TN1-DCLAI1-0001	02/24/2016 14:43	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TN1-DCLAI1-0001	02/25/2016 12:37	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overlow assembly, Ref. DIS-939 for TN1-DCLA11-0001	03/02/2016 13:38	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TN1-DCLAI1-0001	03/10/2016 13:31	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TN1-DCLA11-0001	03/10/2016 13:35	Milliwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. DIS-939 for TN1-DCLA11-0001	03/21/2016 8:08	Millioright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	04/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. DIS-939 101 TNT-DCLAIT-0001	04/06/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual hspection of the overflow assembly, Ref. DIS-939 101 TNT-DCLAIT-0001	04/15/2016 12.12	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. DIS-953 for TNT-DCE-AT-0001	04/20/2016 7:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. DIS-953 for TNT-DCLAT-0001	05/05/2016 14:36	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. Dis-503 for TNT-DOL-AT-0001	05/12/2016 14:30	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual impectation of the overflow assembly, ref: Dis 500 for TNT_DCL_statLoop1	05/24/2016 9:10	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, ref. Dis 500 for TNT-DCLAT-0001	05/24/2016 13:15	Millwright
TNT-DCL-AIT-0001	Transmitter Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref. DIS-039 for TNT-DCLAIT-0001	06/17/2016 7:50	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly. Ref. DIS-939 for TNT-DCLAIT-0001	06/20/2016 8:04	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	06/24/2016 14:18	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	07/06/2016 14:27	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	07/08/2016 12:17	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	07/14/2016 12:22	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	07/21/2016 12:23	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	07/29/2016 12:02	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	08/12/2016 13:46	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	08/19/2016 12:47	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	08/25/2016 7:58	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	08/29/2016 10:30	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	09/07/2016 8:15	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	09/09/2016 12:57	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	09/23/2016 12:32	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	09/26/2016 14:50	Millwright
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	10/03/2016 14:23	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	10/21/2016 15:04	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	10/28/2016 14:03	EICT
INT-DCL-AIT-0001	I ransmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	11/01/2016 8:11	EICI
INT-DCL-AIT-0001	I ransmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	11/08/2016 14:42	EICI
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	11/14/2016 14:55	EICT
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	visual inspection or the overflow assembly, Ret: DIS-939 for TN1-DCLAI1-0001	11/22/2016 7:42	EICI
INI-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection of the overflow assembly, Ref: DIS-939 for TNT-DCLAIT-0001	11/28/2016 10:31	EICI
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	visual inspection or the overflow assembly, Ret: DIS-939 for TN1-DCLAI1-0001	11/29/2016 11:39	EICI
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection or the overflow assembly, Ker: DIS-939 for TNT-DCL-AIT-0001	11/29/2016 11:4/	EIUI
TNT-DCL-AIT-0001	Transmitter, Analyzer Indicating, Residual Sulphite	Visual inspection or the overflow assembly, Ker: DIS-939 for TNT-DCL-AIT-0001	12/14/2016 13:28	FICT
TINT-DUL-AIT-0001	mansmitter, Analyzer indicating, Residual Sulphite	I visual inspection of the overnow assembly, Ref. DIS-939 for TNT-DCLAIT-0001	12/29/2016 14:45	