



NOTES:

1. SIDEWALK THICKNESS 130 mm EXCEPT ACROSS COMMERCIAL, INDUSTRIAL AND HIGH DENSITY RESIDENTIAL DRIVEWAY WHERE THICKNESS SHALL BE 180 mm.
2. t = THICKNESS OF SIDEWALK.
3. JOINTS SHALL BE ACCORDING TO T-310.010-1.
4. ON LOCAL ROADS, THE MINIMUM SIDEWALK WIDTH CAN BE REDUCED TO 1.8 m, EXCEPT FOR NEW DEVELOPMENTS, WHICH MUST ADHERE TO THE TORONTO GREEN STANDARDS AND DIPS.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

REV 2

NOV 2016

**CONCRETE SIDEWALK
WITH RETAINING CURB**

T-310.010-3

NTS

SHEET 1