



NOTES:

1.  $t$  = THICKNESS OF SIDEWALK.
2. SIDEWALK THICKNESS 150 mm EXCEPT ACROSS COMMERCIAL, INDUSTRIAL AND HIGH DENSITY RESIDENTIAL DRIVEWAY WHERE IT SHALL BE 180 mm.
3. JOINTS SHALL BE ACCORDING TO T-310.010-1.
4. ON LOCAL ROADS, THE MINIMUM SIDEWALK WIDTH CAN BE REDUCED TO 1.8M EXCEPT FOR NEW DEVELOPMENTS, WHICH MUST ADHERE TO THE TORONTO GREEN STANDARDS AND DIPS.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

REV 3

SEP 2017

**COMBINED CONCRETE CURB  
AND SIDEWALK**

**T-310.010-4**

NTS

SHEET 1