



**NOTES:**

1. BACKWATER VALVE (HUB & SPIGOT) TO BE SPECIFIED ONLY IF CONNECTING TO SANITARY.
2. USE BIBBY STE-CROIX PART No. S-69080 OR APPROVED EQUAL.
3. THE SAMPLING PORT SHALL BE LOCATED OUTSIDE OF THE BUILDING ON PRIVATE PROPERTY CLOSE TO THE PROPERTY LINE AND UPSTREAM OF THE CONTROL MAINTENANCE ACCESS HOLE.
4. NO SEPARATE SERVICE CONNECTION FOR GROUNDWATER. CONNECTION SHALL BE UPSTREAM OF THE STORM OR SANITARY CONTROL MAINTENANCE ACCESS HOLE BASED ON THE GROUNDWATER QUALITY AND SUBJECT TO APPROVAL.

All dimensions are in millimetres unless otherwise shown.

	ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING	REV 0	NOV 2016
	<b>GROUNDWATER SAMPLING PORT AND FLOW METER DETAIL WITH MAINTENANCE HOLE FRAME AND COVER</b>	<b>T-708.05</b>	
		NTS	SHEET 1