



**NOTES**

1. PRIMARY DUCTS TO BE AT LEAST 75 mm RIGID P.V.C. SCEPTER OR APPROVED EQUAL OR 75 mm HEAVY WALL DUCT WITH DIRECTIONAL BORING.
2. SECONDARY DUCTS TO BE 50 mm RIGID P.V.C. TO UTILITY POLES
3. FOR LOOP FEEDER DUCT, SEE FIGURE 6



**FIGURE 4  
TYPICAL DUCT LAYOUT**

SCALE
NOT TO SCALE
REVISION DATE
JANUARY, 2012

Traffic Plant Installation and Maintenance

APPROVED BY:  
--

DRAWN BY:  
P. B.

PLAN No.  
**801.320**