



NOTES:

1. FOR SERVICE CONNECTIONS 100mm DIA OR LARGER, THE SERVICE LINE VALVE MAY BE LOCATED AT THE WATERMAIN LOCATION ON THE STREET IF THE LENGTH OF THE SERVICE CONNECTION IS LESS THAN 3.5m
2. ALL SERVICE LINE VALVES 100mm AND LARGER WILL BE INSTALLED IN VALVE BOXES
3. WATER METER SETBACK FROM PROPERTY LINE. 30m OR GREATER WILL REQUIRE A METER CHAMBER.



TECHNICAL SERVICES
Engineering Services - Works Facilities & Structures

SCALE:	N.T.S.	STANDARD SERVICE CONNECTION - 1	DRAWING NUMBER:
DATE:	AUGUST , 2007		T-1105.02-1
DRAFTING:	V. DIDIANO		SHEET: 1 of 2