



NOTES:

1. ANY JUNCTION MADE IN SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP TO BE MADE WITH APPROVED COUPLINGS.
2. ALL WATER SERVICES TO BE INSTALLED AT RIGHT ANGLES TO THE WATERMAIN UNLESS APPROVED OTHERWISE.
3. DRY TAPPING IS PROHIBITED.
4. a) NEW METALLIC WATERMAIN DRILLED AND TAPPED A.W.W.A INLET THREAD
 b) NEW PVC WATERMAIN TAPPED THROUGH A STAINLESS STEEL SADDLE
 c) EXISTING WATERMAIN TAPPED THROUGH A STAINLESS STEEL SADDLE

All dimensions are in millimetres unless otherwise shown.



ENGINEERING AND CONSTRUCTION SERVICES STANDARD DRAWING

REV 2

APR 2013

STANDARD WATER SERVICE CONNECTION DETAILS
 19 mm AND 25 mm DIAMETER SIZES

T-1104.01

NTS

SHEET 1