



NOTES:

1. ALL CONCRETE TO BE 20 MPa.
2. ALL CONCRETE BLOCKING TO BE POURED AGAINST UNDISTURBED TRENCH WALL.
3. POLYETHYLENE BOND BREAKER TO BE USED BETWEEN CONCRETE AND FITTINGS.
4. STEEL TIE ROD TO BE USED WHEN SPECIFIED BY ENGINEER. TIE RODS AND BOLTS SHALL BE STAINLESS STEEL.
5. ANCHOR TEES MAY ONLY BE USED WHEN VALVE BOX WILL BE LOCATED IN A GRASSED AREA.
6. THE STORZ COUPLING NOZZLE SHALL ALWAYS FACE THE CURB.

METRIC
ALL DIMENSIONS SHOWN HERE ARE IN MILLIMETRES UNLESS OTHERWISE NOTED

APPROVED BY

Tom Denes
TOM DENES, P. ENG.
EXECUTIVE DIRECTOR TECHNICAL SERVICES

SCALE

N.T.S.

DATE: JUNE, 2001

REVISED:

STANDARD No.

T-1105.01