


# City of Toronto Energy Conservation & Demand Management Plan (2014 - 2019)



Report Date: July 2014



## Table of Contents

|   |     |
|---|-----|
| Executive Summary.....  | 1   |
| Introduction .....  | 2   |
| 1    Goals and Objectives.....  | 3   |
| 2    2012 Energy Use and Costs.....                                   | 3   |
| 3    Methodology.....   | 4   |
| 4    Energy Targets and Potential Savings .....                       | 6   |
| 5    Operational, Behavioural and Retrofit Measures .....             | 7   |
| 6    Renewable Energy.....  | 7   |
| 7    Forecast Costs and Return on Investment.....                     | 8   |
| 8    Program Implementation.....                                      | 9   |
| 9    Conclusion.....  | 10  |
| Administrative Offices and Related Facilities .....                   | 12  |
| 1.    Benchmarking and Conservation Potential .....                   | 15  |
| 2    Conservation Measures and Budget.....                            | 20  |
| 3    Energy Management and Retrofit Plan.....                         | 27  |
| 4    Appendix A.....  | 33  |
| 5    Appendix B - Administrative Offices and Related Facilities ..... | 38  |
| Children’s Services .....   | 47  |
| 1    Benchmarking and Conservation Potential .....                    | 50  |
| 2    Conservation Measures and Budget.....                            | 55  |
| 3    Energy Management and Retrofit Plan.....                         | 61  |
| 4    Appendix A.....  | 66  |
| 5    Appendix B - Children’s Services Buildings .....                 | 71  |
| Community Centres .....   | 76  |
| 1    Benchmarking and Conservation Potential .....                    | 79  |
| 2    Conservation Measures and Budget.....                            | 84  |
| 3    Energy Management and Retrofit Plan.....                         | 91  |
| 4    Appendix A.....  | 97  |
| 5    Appendix B - Community Centres.....                              | 102 |
| Cultural Facilities.....  | 113 |

|    |  |     |
|----|--|-----|
| 1  | Benchmarking and Conservation Potential .....              | 116 |
| 2  | Conservation Measures and Budget .....                     | 121 |
| 3  | Energy Management and Retrofit Plan.....                   | 127 |
| 4  | Appendix A .....   | 133 |
| 5  | Appendix B - Cultural Facilities .....                     | 138 |
|    | Ambulance Stations and Associated Offices/Facilities ..... | 145 |
| 1. | Benchmarking and Conservation Potential .....              | 148 |
| 2  | Conservation Measures and Budget .....                     | 153 |
| 3  | Energy Management and Retrofit Plan.....                   | 160 |
| 4  | Appendix A .....   | 166 |
| 5  | Appendix B - Ambulance stations .....                      | 171 |
|    | Fire Stations and Associated Offices/Facilities .....      | 178 |
| 1  | Benchmarking and Conservation Potential .....              | 181 |
| 2  | Conservation Measures and Budget .....                     | 187 |
| 3  | Energy Management and Retrofit Plan.....                   | 195 |
| 4  | Appendix A .....   | 200 |
| 5  | Appendix B - Fire Stations .....                           | 205 |
|    | Indoor Recreational Facilities .....                       | 216 |
| 1  | Benchmarking and Conservation Potential .....              | 219 |
| 2  | Conservation Measures and Budget .....                     | 225 |
| 3  | Energy Management and Retrofit Plan.....                   | 232 |
| 4  | Appendix A .....   | 237 |
| 5  | Appendix B - Indoor Recreational Facilities .....          | 243 |
|    | Indoor Sports Arenas .....                                 | 252 |
| 1  | Benchmarking and Conservation Potential .....              | 255 |
| 2  | Conservation Measures and Budget .....                     | 261 |
| 3  | Energy Management and Retrofit Plan.....                   | 268 |
| 4  | Appendix A .....   | 274 |
| 5  | Appendix B - Indoor Sports Arenas .....                    | 279 |
|    | Indoor Swimming Pools .....                                | 287 |
| 1  | Benchmarking and Conservation Potential .....              | 290 |

|   |   |     |
|---|---|-----|
| 2 | Conservation Measures and Budget .....              | 295 |
| 3 | Energy Management and Retrofit Plan.....            | 301 |
| 4 | Appendix A .....                                    | 306 |
| 5 | Appendix B - Indoor Swimming Pools .....            | 311 |
|   | Long-Term Care Homes and Services .....             | 316 |
| 1 | Benchmarking and Conservation Potential .....       | 319 |
| 2 | Conservation Measures and Budget .....              | 324 |
| 3 | Energy Management and Retrofit Plan.....            | 331 |
| 4 | Appendix A .....                                    | 336 |
| 5 | Appendix B - Long-term Care Homes and Services..... | 341 |
|   | Performing Arts Facilities .....                    | 346 |
| 1 | Benchmarking and Conservation Potential .....       | 349 |
| 2 | Conservation Measures and Budget .....              | 354 |
| 3 | Energy Management and Retrofit Plan.....            | 360 |
| 4 | Appendix A .....                                    | 365 |
| 5 | Appendix B - Performing Arts Facilities.....        | 370 |
|   | Police Services Facilities .....                    | 374 |
| 1 | Benchmarking and Conservation Potential .....       | 377 |
| 2 | Conservation Measures and Budget .....              | 383 |
| 3 | Energy Management and Retrofit Plan.....            | 392 |
| 4 | Appendix A .....                                    | 398 |
| 5 | Appendix B - Police Services Facilities.....        | 403 |
|   | Public Libraries .....                              | 411 |
| 1 | Benchmarking and Conservation Potential .....       | 414 |
| 2 | Conservation Measures and Budget .....              | 419 |
| 3 | Energy Management and Retrofit Plan.....            | 425 |
| 4 | Appendix A .....                                    | 431 |
| 5 | Appendix B - Public Libraries.....                  | 436 |
|   | Shelter, Support and Housing Administration .....   | 447 |
| 1 | Benchmarking and Conservation Potential .....       | 450 |
| 2 | Conservation Measures and Budget .....              | 455 |

|   |   |     |
|---|---|-----|
| 3 | Energy Management and Retrofit Plan.....                      | 459 |
| 4 | Appendix A.....   | 464 |
| 5 | Appendix B – Shelter, Support and Housing Administration..... | 469 |
|   | Service Yards and Storage Facilities.....                     | 475 |
| 1 | Benchmarking and Conservation Potential .....                 | 481 |
| 2 | Conservation Measures and Budget.....                         | 488 |
| 3 | Energy Management and Retrofit Plan.....                      | 495 |
| 4 | Appendix A.....   | 517 |
| 5 | Appendix B – Service Yards & Storage Facilities .....         | 522 |
|   | Toronto Water .....   | 534 |

# Executive Summary

---

The City of Toronto has been committed to reduction of greenhouse gas emissions, generation of renewable energy and improvement in energy efficiency. The City has been successfully investing in energy conservation demand management and renewable generation for more than a decade with a succession of projects across a number of different building types. Average energy use intensity in larger corporate facilities has been reduced by about 15% since 2004. Various renewable energy solutions have been installed in 31 facilities. Further efforts in analysis of building operations, energy efficient upgrades and training across the portfolio of City-owned facilities can further reduce energy consumption by up to 30%. These savings in energy consumption equate to the reduction of over thirty tonnes of greenhouse gas emissions. This plan will upgrade the facilities' infrastructure and energy performance while establishing Toronto as a leader among North American cities in energy efficiency and climate change mitigation.

The plan takes a systematic approach to identifying energy conservation opportunities through operational classification of buildings and energy consumption benchmarking. The results provide a framework for the City to plan its next phase of energy efficiency improvements. The scope of this Energy Conservation and Demand Management (ECDM) plan includes facilities from the City's Agencies, Boards, Commissions and Divisions which together spent over fifty three million dollars on electricity and natural gas in 2012. The 10-year plan, prepared in accordance with Ontario's Green Energy Act Regulation 397/11, projects an investment in capital and operational improvements which will be fully repaid with energy savings and utility company incentives. The analysis projects opportunities to cut facility energy consumption resulting in annual cost savings of over \$17 Million with an average payback period of less than 8 years.

Of the 528 facilities covered by this report, 37 are larger than 100,000 square feet in area and account for about 45 per cent of the total area covered by this project. Forty seven facilities with highest energy savings potential account for approximately 57% of the total projected savings. These will proceed with building-level energy audits which will define specific projects and justify the required investment based on associated energy savings. Other facilities will undergo less detailed studies based on their energy savings potential.

# Introduction

---

The Government of Ontario enacted the Green Energy Act Regulation 397/11 on January 1, 2012. This legislation requires the City of Toronto to develop and publish a five-year Energy Conservation and Demand Management (ECDM) plan by July 1, 2014. Energy & Waste Management Office within the Environment and Energy Division at the City of Toronto led efforts to complete this plan and report.

In July 2007, Toronto City Council adopted the recommendations made by the "Climate Change, Clean Air and Sustainable Energy Action Plan". This plan made a commitment to optimization of energy efficiency at City facilities. In November 2009, Toronto City Council adopted the recommendations made by the Toronto Environment Office in a report entitled "The Power to Live Green". This report requires City of Toronto to achieve an 80 per cent reduction in greenhouse gas emissions from 1990 levels by 2050. Accordingly, the City of Toronto's obligations under the Green Energy Act are in line with the commitments previously made by the City Council. The Energy Conservation and Demand Management (ECDM) Plan is another step in consolidating the associated conservation efforts within City facilities to meet previously adopted commitments by City Council.

The City of Toronto has a large quantity of facilities under its internal portfolio of buildings and operations. Accordingly, a benchmarking approach to classify opportunities and prioritize future projects was adopted for the development of the ECDM plan. The report is comprised of various building types related to individual divisions. Where sensible, internal and external facilities with similar operations were grouped for analysis and reporting. Comparison of energy consumption enabled this analysis to estimate energy savings based on potential operational improvements and equipment retrofits to achieve top quartile performance in each building category. This approach provides the information necessary for the City of Toronto to prioritize and initially focus efforts on facilities where opportunities yield the highest savings.

This report is the first Energy Conservation and Demand Management plan published by the City of Toronto. It is expected that this report will lead to increased knowledge, investigation and further discussions resulting in more complete revisions of this report in the future.

Given the timing requirements set by Regulation 391/11 of the Green Energy Act, significant effort was invested at all stages associated to the compilation of this report. The Environment and Energy Division recognizes and appreciates the contributions of numerous divisional representatives and team members in project planning, data acquisition, analysis and review of the individual sections contained within this report. We wish to recognize the significant contributions made by Enerlife Consulting in providing analysis and support in completion of this report.

To save paper, this document is password protected to prevent unintentional printing. In cases where printing is required, the password "ECDM" can be used to remove security in order to print individual sections of this report.



## 1 Goals and Objectives

The City of Toronto has been actively addressing climate change through environmental leadership for some time. Initiatives such as the Better Buildings Partnership and the City’s Energy Retrofit Program have implemented over \$100 million of energy-related projects in City and local facilities. The installation of wind, solar, hydrogen and tri-generation facilities at Exhibition Place, the Enwave Deep Lake Water Cooling system and policies such as the Toronto Green Standard are examples the City of Toronto’s leadership in reducing greenhouse gas emissions. In July 2007, Toronto City Council adopted the “Climate Change, Clean Air and Sustainable Energy Action Plan” which committed to optimize energy efficiency at City facilities. In November 2009, “The Power to Live Green” report was adopted by City Council which proposes an 80% reduction in greenhouse gas emissions from 1990 levels by 2050.

This experience and broader City goals are in line with the Energy Conservation and Demand Management plan. The plan aims to establish a performance-based approach to energy conservation and renewable energy for City facilities, which includes:

- Establishing and verifying energy reduction targets for City facilities
- Reducing energy consumption by up to 30%, while generating approximately \$17 million in energy savings and avoiding nearly thirty two thousand tonnes of greenhouse gas emissions
- Improving the City’s facility infrastructure as well as operating and maintenance practices
- Supporting established greenhouse gas emissions reduction goals

## 2 2012 Energy Use and Costs

The facilities addressed in this plan cover a total area of over 19 million square feet. Of the 528 facilities covered by this report, 37 are larger than 100,000 square feet in area and account for about 45 per cent of the total area covered by this project.

These facilities spent over \$53 million on electricity and natural gas (including buildings served by Enwave Deep Lake Water Cooling and steam) in 2012. Energy consumed by the facilities included over 326 thousand megawatt hours of electricity and nearly 30 million cubic metres of gas, resulting in nearly 92 thousand tonnes of GHG emissions.<sup>1</sup>

---

<sup>1</sup> Electricity includes chilled water use and natural gas includes steam use in a few buildings.




Figure 1: Total Energy Use and Costs

2012 Annual Energy Use by Facility Type

| Facility Type                                 | # of facilities | Total Indoor Area (ft <sup>2</sup> ) | Electricity    |                      | Natural Gas             |                     | Total Energy   |                     | GHG emissions (tonnes) |
|---|-----------------|--------------------------------------|----------------|----------------------|-------------------------|---------------------|----------------|---------------------|------------------------|
|   |                 |                                      | (MWh)          | (\$)                 | (x1000 m <sup>3</sup> ) | (\$)                | (eMWh)         | (\$)                |                        |
| Administrative offices and related facilities | 51              | 4,846,672                            | 89,648         | \$ 12,550,716        | 5,120                   | \$ 1,331,253        | 142,642        | \$13,881,969        | 19,482                 |
| Ambulance stations and associated facilities  | 24              | 216,311                              | 5,150          | \$ 720,941           | 404                     | \$ 105,076          | 9,332          | \$ 826,017          | 1,326                  |
| Children's Services                           | 9               | 64,186                               | 973            | \$ 136,214           | 150                     | \$ 38,905           | 2,522          | \$ 175,118          | 388                    |
| Community centres                             | 70              | 2,033,543                            | 31,524         | \$ 4,413,348         | 3,272                   | \$ 850,709          | 65,389         | \$ 5,264,057        | 9,616                  |
| Cultural facilities                           | 20              | 596,553                              | 9,016          | \$ 1,262,197         | 748                     | \$ 194,479          | 16,757         | \$ 1,456,676        | 2,397                  |
| Fire stations and associated facilities       | 88              | 836,816                              | 9,693          | \$ 1,357,069         | 1,716                   | \$ 446,172          | 27,454         | \$ 1,803,241        | 4,291                  |
| Indoor recreational facilities                | 46              | 1,477,712                            | 32,122         | \$ 4,497,088         | 3,783                   | \$ 983,636          | 71,278         | \$ 5,480,724        | 10,642                 |
| Indoor sports arenas                          | 27              | 862,996                              | 19,947         | \$ 2,792,519         | 1,490                   | \$ 387,434          | 35,369         | \$ 3,179,954        | 4,994                  |
| Indoor swimming pools                         | 7               | 214,077                              | 4,213          | \$ 589,783           | 996                     | \$ 258,854          | 14,517         | \$ 848,637          | 2,334                  |
| Long-Term Care Homes and Services             | 10              | 1,622,285                            | 29,095         | \$ 4,073,310         | 3,452                   | \$ 897,539          | 64,824         | \$ 4,970,849        | 9,687                  |
| Performing arts facilities                    | 3               | 430,370                              | 6,061          | \$ 848,554           | 271                     | \$ 70,567           | 8,870          | \$ 919,121          | 1,177                  |
| Police services facilities                    | 39              | 2,589,421                            | 38,388         | \$ 5,374,327         | 2,622                   | \$ 681,774          | 65,528         | \$ 6,056,101        | 9,150                  |
| Public libraries                              | 73              | 1,548,904                            | 28,795         | \$ 4,031,287         | 1,823                   | \$ 473,963          | 47,662         | \$ 4,505,251        | 6,593                  |
| Service Yards & Storage Facilities            | 50              | 1,740,016                            | 17,760         | \$ 2,486,411         | 3,127                   | \$ 813,148          | 50,130         | \$ 3,299,559        | 7,830                  |
| Shelter, Support and Housing Administration   | 11              | 280,617                              | 4,280          | \$ 599,157           | 860                     | \$ 223,699          | 13,185         | \$ 822,856          | 2,087                  |
| <b>TOTAL</b>                                  | <b>528</b>      | <b>19,360,480</b>                    | <b>326,664</b> | <b>\$ 45,732,922</b> | <b>29,835</b>           | <b>\$ 7,757,209</b> | <b>635,460</b> | <b>\$53,490,130</b> | <b>91,994</b>          |

Utility rates: \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of natural gas  
 GHG emission factors: 110 g GHG / kWh of electricity, 1879 g GHG / m<sup>3</sup> of natural gas

Table 1: 2012 Annual Energy Use by Facility Type

### 3 Methodology

The plan has been developed using the principles of performance-based conservation. This data-driven approach relies on benchmarking large data sets of comparable buildings to identify the energy efficient buildings of each type. Target setting methodology used for the ECDM report was based on building energy consumption from top-quartile energy performers under individual building types. The corresponding result was used to set energy performance targets for the remaining 75 percent of the buildings within the group. The target-setting methodology breaks down potential savings into year-round and seasonal (winter or summer) electricity and gas use, which help narrow down measures most

likely to be appropriate for each scenario. Measurement and verification of actual savings finalizes the process, validating the actions taken and guiding continuous improvement. The details of the process are outlined in the diagram below.

An initial set of possible energy conservation measures has been included in individual reports, customized to each building type. These measures have been organized by type (mechanical, lighting, electrical, envelope and process) and categorized as behavioural, operational or retrofit/capital. Other factors such as ease of implementation, savings potential and suggested timeline have been also accounted for.

Performance based conservation is particularly well suited to large portfolios of buildings, providing a basis for estimation of financial opportunities and implementation strategies for maximizing economic and environmental benefits. This plan sets the stage for application of this methodology across the largest part of the City’s portfolio.




Figure 2: Performance-based Conservation Methodology for the ECDM Plan

## 4 Energy Targets and Potential Savings

Within each building type there is a range of energy intensities, from low (highly efficient) to high (inefficient). The most efficient compare favourably with the best performers from other Canadian municipalities. For example, Metro Hall is now among the energy performance leaders in Toronto & Region Conservation’s (TRCA’s) national Town Hall Challenge. Toronto City Hall has recently moved into the top quartile of Canadian city and town halls through a 20% reduction in energy consumption. Toronto City Hall won the Race to Reduce 2012 Award for greatest energy reduction from 2010 – 2011 in a facility over three hundred thousand square feet. The City’s Thistleton Community Centre and Firehall 425 are also leaders in TRCA’s national database of municipal building energy efficiency.

The measures taken to achieve high levels of energy efficiency in many of the City’s facilities can be extended to similar facilities. An energy use target has been established for each of the 16 building types, based on achievement of top-quartile energy performance. The targets do not presume that all buildings can be top performing. However, based on experience and on average, facilities can reach an energy intensity level which has already been achieved by the top 25% of facilities in their group. To ensure fair comparison individual building targets were adjusted for significant, site-specific differences such as data centres, pools, ice rinks, and renewable energy. The target-setting methodology and results for each building type are described fully in Appendix B of the individual reports.

The initial targeted savings potentials for each building type are summarized below. Natural gas savings create the largest energy and emissions reductions, while electricity accounts for 78% of the targeted cost savings because of higher prices relative to gas.




Figure 3: Actual and Target Energy Use Intensities




Figure 4: Actual and Target Energy Use Intensities with Electricity and Gas Targets

## 5 Operational, Behavioural and Retrofit Measures

A set of energy conservation measures is presented in the individual, customized reports for each building type. At a minimum, this set of opportunities will be considered for individual buildings based on their particular energy savings profile. The high-potential facilities have very large savings and justify significant project investment, while other facilities are already relatively efficient and require little further improvement. The target-setting methodology breaks down potential savings into year-round and seasonal (winter or summer) electricity and gas use, which helps to further narrow down those measures and projects most likely to be appropriate for each facility.

The measures for each building type are laid out in “Proposed Energy Efficiency Measures” section in the individual reports. Energy saving measures are organized by type (mechanical, lighting, electrical, envelope and process) and categorized as behavioural, operational or retrofit/capital. Measures are sorted by ease of implementation, savings potential and suggested timeline for implementation.

## 6 Renewable Energy

The City has implemented 35 renewable energy generation installations across multiple facilities covered by this report. Additional renewable energy installations have not been included due to the scope of the operation types defined for reporting by the Ontario Ministry of Energy. In addition to solar and geothermal systems, deep lake water cooling has been implemented at 4 facilities. The City is reviewing feasibility and planning to install renewable energy generation installations at 64 additional locations. Existing and proposed future installations are summarized in the following chart.




Figure 6: Summary of Existing and Planned Renewable Energy Generation Installations

## 7 Forecast Costs and Return on Investment

Past project costs combined with implementation information were used to establish preliminary timelines and budgetary financial analysis. The budgets allow for saving measures such as:

- Lighting retrofits and associated controls
- Mechanical system modifications and efficiency improvements
- Appliance replacement and controls
- Localized efficiency measures for the building envelope

Estimated project costs also include energy audits, staff training, measurement and verification of actual savings as well as additional maintenance costs associated with incorporation of new technology and operating practices. Projected borrowing costs and inflation have also been accounted for in cash flow analyses presented throughout the report.

Financing of the capital costs are provided for based on an interest rate of 4%. Energy cost savings will fully repay the capital costs and financing of the necessary work. An annual inflation factor of 2% is applied to costs and 5% annual escalation is applied to utility cost savings. Accordingly, the overall ECDM project cost is estimated at just over \$142 million.

The 10-year summary of total program costs, accumulated savings and payback period is provided below.

| Facility Type                                 | No. of Facilities | Total Indoor Area (Square feet) | Current Utility Costs | Potential Cost Savings | Current GHG Emissions (Tonnes) |
|---|-------------------|---------------------------------|-----------------------|------------------------|--------------------------------|
| Administrative offices and related facilities | 51                | 4,846,672                       | \$13,881,969          | \$ 4,549,000           | 6,868                          |
| Ambulance stations and associated facilities  | 24                | 216,311                         | \$ 826,017            | \$ 347,000             | 421                            |
| Children's Services                           | 9                 | 64,186                          | \$ 175,118            | \$ 48,000              | 146                            |
| Community centres                             | 70                | 2,033,543                       | \$ 5,264,057          | \$ 2,348,000           | 4,365                          |
| Cultural facilities                           | 20                | 596,553                         | \$ 1,456,676          | \$ 448,000             | 926                            |
| Fire stations and associated facilities       | 88                | 836,816                         | \$ 1,803,241          | \$ 581,000             | 1,250                          |
| Indoor recreational facilities                | 46                | 1,477,712                       | \$ 5,480,724          | \$ 2,585,000           | 5,022                          |
| Indoor sports arenas                          | 27                | 862,996                         | \$ 3,179,954          | \$ 1,210,000           | 1,672                          |
| Indoor swimming pools                         | 7                 | 214,077                         | \$ 848,637            | \$ 267,000             | 854                            |
| Long-Term Care Homes and Services             | 10                | 1,622,285                       | \$ 4,970,849          | \$ 335,000             | 1,877                          |
| Performing arts facilities                    | 3                 | 430,370                         | \$ 919,121            | \$ 155,000             | 323                            |
| Police services facilities                    | 39                | 2,589,421                       | \$ 6,056,101          | \$ 1,200,000           | 1,467                          |
| Public libraries                              | 73                | 1,548,904                       | \$ 4,505,251          | \$ 1,879,000           | 2,887                          |
| Service Yards & Storage Facilities            | 50                | 1,740,016                       | \$ 3,299,559          | \$ 1,059,000           | 2,904                          |
| Shelter, Support and Housing Administration   | 11                | 280,617                         | \$ 822,856            | \$ 228,000             | 911                            |
| <b>TOTAL</b>                                  | <b>528</b>        | <b>19,360,480</b>               | <b>\$53,490,130</b>   | <b>\$17,239,000</b>    | <b>31,893</b>                  |

Table 2: 10-Year Financial Picture

## 8 Program Implementation

### 8.1 Strategy

The starting point of the implementation strategy is the energy savings potential for each building. Approximately 9% of the facilities were categorized as those with high savings potential based on annual savings of more than one hundred thousand dollars. These buildings will be focused on first as they are associated to over 57% of the projected energy savings. Medium potential was based on annual savings between five to one hundred thousand dollars. Facilities with medium savings potential constitute about 50% of the buildings in this plan and account for about 41% of total projected savings. The remaining facilities, each with potential annual savings of less than five thousand dollars, contribute just 2% of total potential savings.

#### High-Potential Facilities

For facilities with target annual savings of more than one hundred thousand dollars, the step-by-step approach to validating and delivering the potential savings is as follows:

- i) **Verification of Building Information**  
This will confirm the building area, percentages of electric heating and cooling, and other parameters used to set the energy target for the building.
- ii) **In-Depth Energy Assessment**

More sophisticated analysis of actual energy billing data for the past 3 years will refine the high-level energy metrics used for setting the energy target, and provide a range of diagnostic indicators which clearly point to specific conservation opportunities.

**iii) Building-level Energy Audits**

Detailed studies on operational and retrofit opportunities along with the required analysis and engineering to assess technical and financial benefits.

**iv) Divisional Review**

This will include finalizing project selection, designing and specifying measures, and preparing tender packages for the work.

**v) Procurement and implementation**

**vi) Measurement and Verification of Performance and Energy Savings**

**vii) Engagement**

Engage operators and occupants in operational changes and energy efficient maintenance practices.

### Medium-Potential Facilities

The implementation process for these facilities, with target annual savings between five thousand and one hundred thousand dollars, is similar to that outlined above for higher potential facilities. However, it is simplified to streamline and lower the cost of measure development, procurement and implementation. Consideration is given to grouping facilities with similar measures in order to achieve economies of scale.

### Low-Potential Facilities

For buildings with less than five thousand dollars in annual savings, the process is further simplified to a standardized checklist of measures. The checklist will be used by City staff for the corresponding building type and measures identified through this process will be implemented by competitively procured installers. Operational changes, maintenance practices and behavioural change engagement will be implemented by staff.

## 9 Conclusion

The City of Toronto has a strong history in raising energy efficiency and lowering the carbon footprint of its own buildings. Over the past 10 years, the Energy & Waste Management Office has cumulatively avoided costs of approximately \$43 million attributed to the implementation of energy retrofit projects.

The Energy Conservation and Demand Management reports have been shared with divisional representatives to allow an open and transparent approach and to ensure inclusivity in the planning and application of energy conservation projects. Associated investment in additional capital and operational improvements will further reduce corporate energy consumption and greenhouse gas emissions. Building level analysis will define specific projects and justify the required investments based on associated savings.



The plan has identified facilities with high, medium and low energy saving potential. By taking a strategic implementation approach, the City can achieve a high economic return on investment while upgrading the buildings' infrastructure and improving energy performance. The results will reinforce City of Toronto's position as a leader in energy efficiency and climate change mitigation among North American cities, while upgrading the energy performance of the City's facilities.

# Administrative Offices and Related Facilities

---

## Table of Contents

|       |   |    |
|-------|---|----|
| 1.    | Benchmarking and Conservation Potential .....   | 15 |
| 1.1   | Energy Use and Building Characteristics.....  | 15 |
| 1.1.1 | Building Characteristics.....   | 15 |
| 1.1.2 | Summary of Energy Use and Costs .....   | 15 |
| 1.2   | Energy Targets.....   | 18 |
| 1.3   | Savings Potential .....   | 19 |
| 2     | Conservation Measures and Budget.....   | 20 |
| 2.1   | Previous Energy Efficiency Initiatives.....   | 20 |
| 2.2   | Proposed Energy Efficiency Measures .....   | 21 |
| 3     | Energy Management and Retrofit Plan .....   | 27 |
| 3.1   | Implementation Costs and Modeled Savings .....  | 27 |
| 3.2   | Implementation Process and Tools – Determining the specific measures for each building..... | 27 |
| 3.2.1 | Building Performance Audit.....   | 28 |
| 3.2.2 | Energy Assessment .....   | 29 |
| 3.2.3 | Energy Savings Checklist .....  | 29 |
| 3.3   | Implementation Budget.....  | 30 |
| 3.4   | 10-Year Implementation Plan .....   | 31 |
| 4     | Appendix A.....   | 33 |
| 4.1   | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....       | 33 |
| 4.2   | Determining Energy Use Components.....  | 33 |
| 4.3   | Determining Targets .....   | 33 |
| 4.4   | Calculating Potential Savings .....   | 35 |
| 4.5   | Implementation Costs by Measure Type and Modeled Savings.....                               | 35 |
| 4.6   | Assessment Tools.....   | 36 |
| 5     | Appendix B - Administrative Offices and Related Facilities .....                            | 38 |
| 5.1   | Buildings and Building Characteristics .....  | 38 |
| 5.2   | Energy Use Intensities.....   | 39 |
| 5.3   | Target-setting Method and Metrics.....  | 41 |
| 5.4   | Savings Potential by Energy Use Component .....   | 44 |

### List of Tables

|   |    |
|---|----|
| Table 3: Current Renewable Energy Systems on Administrative Offices and Related Facilities .....          | 15 |
| Table 4: 2012 Energy Use and Costs for City of Toronto Administrative Offices and Related Facilities .... | 16 |
| Table 5: Top Quartile Targets.....  | 18 |
| Table 6: Savings Potential Summary.....   | 19 |
| Table 7: Savings Potential for Administrative Offices and Facilities .....                                | 20 |
| Table 8: 2004 Civic Centres and Related Facilities Project Estimated Project Costs and Savings .....      | 20 |
| Table 7: Energy Saving Measures for Administrative Offices and Related Facilities .....                   | 25 |
| Table 10 : Proposed Renewable Energy Systems for Administrative Offices and Related Facilities .....      | 26 |
| Table 11: Estimated Implementation Costs and Modeled Savings .....  | 27 |
| Table 12: Assessment Tools Used to Determine Specific Energy-saving Measures .....                        | 28 |
| Table 13: Total Budget - Energy Management and Retrofit Plan .....  | 31 |
| Table 14: Cash Flow for 10-Year Implementation Plan .....   | 32 |
| Table 15: Implementation Costs by Measure Type .....  | 36 |
| Table 16: Administrative Office and Related Facility Building Information.....                            | 39 |
| Table 17: Administrative Office and Related Facility 2012 Energy Intensity.....                           | 40 |
| Table 18: Excluded Facilities .....   | 41 |
| Table 19: Savings Potential for 16 High Savings Potential Administrative Facilities .....                 | 44 |
| Table 20: Savings Potential for 21 Medium Savings Potential Administrative Facilities .....               | 45 |
| Table 21: Savings Potential for 14 Low Savings Potential Administrative Facilities .....                  | 45 |

### List of Figures

|   |    |
|---|----|
| Figure 7: 2012 Energy Use and Cost Breakdown for City of Toronto Administrative Facilities..... | 16 |
| Figure 8: 2012 Total Energy Intensity Benchmark .....   | 17 |
| Figure 9: 2012 Total Electricity Intensity Benchmark .....                                      | 17 |
| Figure 10: 2012 Total Gas Intensity Benchmark .....   | 18 |
| Figure 11: Cash Flow for 10-Year Implementation Plan .....                                      | 32 |
| Figure 12: 2012 Electric Baseload Intensity Benchmark.....                                      | 41 |
| Figure 13: 2012 Electric Cooling Intensity Benchmark .....                                      | 42 |
| Figure 14: 2012 Electric Heating Intensity Benchmark.....                                       | 42 |
| Figure 15: 2012 Gas Baseload Intensity Benchmark.....   | 43 |
| Figure 16: 2012 Gas Heating Intensity Benchmark.....  | 43 |

## 1. Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 51 administrative offices and related facilities in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B.

The total area for all of the buildings is 4,846,672 ft<sup>2</sup>. Administrative offices and related facilities range in size from just over 2,500 ft<sup>2</sup> to over 787,000 ft<sup>2</sup>.

The facilities equipped with a renewable energy system are listed below:

| Building Name          | Building Address     | Renewable Installation  | System Size | Unit |
|------------------------|----------------------|-------------------------|-------------|------|
| City Hall              | 100 Queen St W       | Deep Lake Water Cooling | 700         | kW   |
| Coronation Park        | 711 Lakeshore Blvd W | Geothermal              | 13.4        | kW   |
| East York Civic Centre | 850 Coxwell Ave      | Solar Photovoltaic      | 40          | kW   |
| Metro Hall             | 55 John St           | Deep Lake Water Cooling | 1200        | kW   |
| Old City Hall          | 60 Queen St W        | Deep Lake Water Cooling |             |      |

**Table 3: Current Renewable Energy Systems on Administrative Offices and Related Facilities**

The facilities range from 0% to 100% air-conditioned. One facility (Etobicoke Civic Centre Court 2) is fully served by electric heat. There are a number of other facilities using between 5 and 40% electric heat. Two facilities (21 Panorama and York Civic Center) are served by water source heat pumps. There are food services at a number of facilities, ranging from 1 to 5% of building served. There are data/call centres serving a small portion of the following facilities: 60 Tiffield Rd, Consolidated Communication Ctr, Metro Hall, Old City Hall, Scarborough Civic Centre and Dyas Rd 18. The Dyas Road Archive Building is 100% data/call centre. There are outdoor ice rinks at City Hall, North York Civic Centre and Scarborough Civic Centre.

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 51 buildings are summarized below.

|                               | 2012 Energy Use |                     |
|-------------------------------|-----------------|---------------------|
|                               | Unit            | \$                  |
| Electricity (kWh)             | 89,647,971      | \$12,550,716        |
| Natural Gas (m <sup>3</sup> ) | 5,120,203       | \$1,331,253         |
| <b>Total</b>                  |                 | <b>\$13,881,969</b> |

Table 4: 2012 Energy Use and Costs for City of Toronto Administrative Offices and Related Facilities




Figure 5: 2012 Energy Use and Cost Breakdown for City of Toronto Administrative Facilities

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 51 buildings. Total energy use ranges from approximately 6.8 to 128.4 ekWh/ft<sup>2</sup>. There are also wide ranges for electricity and gas use per ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 6: 2012 Total Energy Intensity Benchmark




Figure 7: 2012 Total Electricity Intensity Benchmark




Figure 8: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for administrative offices and related facilities are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each administrative office and related facility to achieve its target over the duration of the ECDM Plan.

| Energy type  | Component    | Value       | Unit                            |
|--------------|--------------|-------------|---------------------------------|
| Electricity  | Base         | 10.9        | kWh/ft <sup>2</sup> /year       |
|              | Cooling      | 0.7         | kWh/ft <sup>2</sup> /year       |
|              | Heating      | 0.3         | kWh/ft <sup>2</sup> /year       |
|              | <b>Total</b> | <b>12.0</b> | <b>kWh/ft<sup>2</sup>/year</b>  |
| Gas          | Base         | 1.0         | ekWh/ft <sup>2</sup> /year      |
|              | Heating      | 7.2         | ekWh/ft <sup>2</sup> /year      |
|              | <b>Total</b> | <b>8.2</b>  | <b>ekWh/ft<sup>2</sup>/year</b> |
| Total energy | Total        | 20.1        | ekWh/ft <sup>2</sup> /year      |

Table 5: Top Quartile Targets

The data set for target-setting is made up of 52 administrative offices and related facilities with complete and reliable data, 44 of which are City of Toronto buildings and 8 are from other municipalities. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), % of the area which is air conditioned, % of the area served by a data



centre, % of the area served by food services and presence of an outdoor ice rink. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each administrative office and related facility. The total savings potential for each administrative office and related facility is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 51 administrative offices and related facilities are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are 16 administrative office and related facilities with annual savings potential greater than \$100,000. 21 administrative offices and related facilities have annual savings potential between \$5,000 and \$100,000, and 14 administrative offices and related facilities have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 51 buildings is \$4,549,651 (\$4,038,390 for electricity and \$511,261 for gas) with an average total energy savings of 34%.

For the 16 high-potential savings facilities, the total annual savings potential is \$3,779,833 (\$3,470,009 for electricity and \$309,824 for gas) with an average total energy savings of 39%.

For the 21 mid-potential savings facilities, the total annual savings potential is \$739,852 (\$559,425 for electricity and \$180,427 for gas) with an average total energy savings of 25%.

For the 14 low-potential savings facilities, the total annual savings potential is \$29,965 (\$8,955 for electricity and \$21,010 for gas) with an average total energy savings of 23%.


|  | Electricity Savings Potential |            |            |            | Gas Savings Potential |            |            |            | Total Energy Savings Potential |            | Incentives         |                    | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |                  |
|--|-------------------------------|------------|------------|------------|-----------------------|------------|------------|------------|--------------------------------|------------|--------------------|--------------------|--------------------------------|------------------------|------------------|
|  | Average %                     |            |            |            | \$/yr                 | Average %  |            |            | \$/yr                          | Avg %      | \$/yr              | Electricity        |                                |                        | Gas              |
|  | Base-load                     | Cooling    | Heating    | Total      |                       | Base-load  | Heating    | Total      |                                |            |                    |                    |                                |                        |                  |
| <b>TOTAL: 51 facilities</b>            | <b>28%</b>                    | <b>52%</b> | <b>20%</b> | <b>32%</b> | <b>\$4,038,390</b>    | <b>82%</b> | <b>30%</b> | <b>38%</b> | <b>\$511,261</b>               | <b>34%</b> | <b>\$4,549,651</b> | <b>\$2,307,651</b> | <b>\$196,639</b>               | <b>4,846,672</b>       | <b>6,867,864</b> |
| High potential savings facilities (16) | 35%                           | 49%        | 21%        | 39%        | \$3,470,009           | 82%        | 27%        | 41%        | \$309,824                      | 39%        | \$3,779,833        | \$1,982,862        | \$119,163                      | 2,660,621              | 4,965,509        |
| Mid-potential savings facilities (21)  | 14%                           | 58%        | 17%        | 16%        | \$ 559,425            | 81%        | 32%        | 36%        | \$180,427                      | 25%        | \$ 739,852         | \$ 319,672         | \$ 69,395                      | 1,938,902              | 1,743,479        |
| Low potential savings facilities (14)  | 01%                           | 53%        | 07%        | 04%        | \$ 8,955              | 54%        | 33%        | 35%        | \$ 21,010                      | 23%        | \$ 29,965          | \$ 5,117           | \$ 8,081                       | 247,149                | 158,876          |

**Table 6: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 51 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 16.6        | 11.9        | 28%                 | \$ 2,896,272         |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 1.0         | 0.5         | 52%                 | \$ 291,339           |
| Electric Heating (kWh/ft <sup>2</sup> )   | 0.5         | 0.4         | 20%                 | \$ 47,807            |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 24.4        | 11.2        | 54%                 | \$ 802,972           |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 2.2         | 0.4         | 82%                 | \$ 194,302           |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 9.1         | 6.4         | 30%                 | \$ 295,642           |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 9.1         | 7.1         | 21%                 | \$ 21,317            |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>29.4</b> | <b>19.3</b> | <b>34%</b>          | <b>\$ 4,549,651</b>  |



**Table 7: Savings Potential for Administrative Offices and Facilities**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2004, the City of Toronto undertook a study to identify building improvement measures that would improve energy and water efficiency and reduce the operating cost and environmental impact of Civic Centres located throughout the City of Toronto.

Table 5 below summarizes the estimated overall project costs, savings and estimated energy reduction for 13 Civic Centres and related facilities as a result of the 2004 project.

| Project Name & Start Year | Completion Year | Num. of Bldgs | Total Floor Area (m <sup>2</sup> ) | Project Cost & Savings (estimated) |                 |                    |  | Estimated Annual Energy Reduction |           |         |                             |                 |
|---------------------------|-----------------|---------------|------------------------------------|------------------------------------|-----------------|--------------------|--|-----------------------------------|-----------|---------|-----------------------------|-----------------|
|                           |                 |               |                                    | Retrofit Cost                      | Total \$Savings | Total ekWh Savings | Total CO <sub>2</sub> Savings (tonnes) | Payback                           | Save kWh  | Save kW | Save Nat.Gas m <sup>3</sup> | Save Steam mlbs |
| Civic Centers 2004        | 2006            | 13            | 253,804                            | \$4,465,481                        | \$567,973       | 7,260,336          | 1,797                                  | 7.9                               | 6,112,271 | 4,268   | 110,972                     | 1,453           |

**Table 8: 2004 Civic Centres and Related Facilities Project Estimated Project Costs and Savings**

## 2.2 Proposed Energy Efficiency Measures

Table 6 below shows the full range of possible energy efficiency measures for the entire portfolio of administrative offices and related facilities. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 51 facilities indicate that the larger part of the savings will come from measures associated with electric cooling and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### Timelines

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).

| Gas Baseload Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round</b> |  |                        |                          |             |          |                       |                    |
| B17  | Optimize dishwasher operation (only run when full) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| P3   | Test and tune DHW boiler efficiency                | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M16  | Investigate and repair possible gas leaks          | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P1   | Optimize DHW temperature control                   | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| P2   | Implement DHW circulation pump control             | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P4   | Install low flow showerheads and faucet aerators   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| M14  | Insulate DHW tanks and distribution piping         | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M15  | Replace DHW boilers with more efficient models     | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off machines, office and kitchen equipment when not needed                                  | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B2   | Unplug machines, office and kitchen equipment if not actively used                               | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off computer monitors when not in use   | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B4   | Enable ENERGY STAR power settings on your computer   | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B5   | Unplug chargers when not in use  | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B6   | Turn off lights when areas not in use  | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| B7   | Make use of natural light instead of turning on lights where possible                            | 4                      | 2                        | 6           | Year 1   | Annual Review         | Building Occupants |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 2                        | 5           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 2                        | 5           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 2                        | 5           | Year 3   | 15+                   |                    |
| L1   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L2   | Install motion sensors in washrooms/occasional use spaces to shut off lights when unoccupied     | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L3   | Install photo-sensors and/or a timer on outdoor and daylight interior area lighting              | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L4   | Replace HID lighting with high efficiency fluorescent  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L5   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L6   | Replace festive lighting with LED  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| L7   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 2                        | 3           | Year 5   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 2                        | 3           | Year 5   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 2                        | 3           | Year 5   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| EL5  | Submeter data and call centres   | 1                      | 2                        | 3           | Year 5   | Seasonal Review       |                    |
| M3   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 2                        | 3           | Year 5   | 10 to 20              |                    |
| M4   | Convert electric hot water heaters to natural gas  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
|  | Other:   |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Electric Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes</b> |  |                        |                          |             |          |                       |                    |
| B8   | Adjust blinds (to retain heat in winter)   | 4                      | 2                        | 6           | Year 1   | annual review         | Building Occupants |
| B9   | Avoid use of electric heaters  | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B10  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| M8   | Control fan coil and entrance heaters to optimize run-times                                | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M9   | Evaluate conversion from electric heating to natural gas                                   | 2                      | 2                        | 4           | Year 2   | n/a                   |                    |
| M5   | Install snow sensors to control the snow-melting system                                    | 1                      | 2                        | 3           | Year 5   | seasonal review       |                    |
| M6   | Upgrade base building heating system to avoid use of electric heaters                      | 1                      | 2                        | 3           | Year 5   | seasonal review       |                    |
| M7   | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1                      | 2                        | 3           | Year 5   | seasonal review       |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

| Electric Cooling Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes</b> |  |                        |                          |             |          |                       |                    |
| B11  | Winterize room air-conditioners  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B12  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B13  | Only cool rooms that are being used  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B14  | Install and use energy efficient ceiling fans  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B15  | Close blinds (to shade space from direct sunlight)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B16  | Install window film, solar screens or awnings on south and west facing windows               | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M12  | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M13  | Test and tune the air conditioning units   | 3                      | 4                        | 7           | Year 2   | 3                     |                    |
| M10  | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M11  | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

| Gas Heating Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS HEATING - refers to the additional energy used in winter for heating and humidification</b> |  |                        |                          |             |          |                       |                    |
| B18  | Check and clear baseboard heaters of obstructions  | 4                      | 3                        | 7           | Year 1   |                       | Building Occupants |
| B19  | Adjust blinds (to retain heat in winter)   | 4                      | 3                        | 7           | Year 1   |                       | Building Occupants |
| B20  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 3                        | 7           | Year 1   |                       | Building Occupants |
| M17  | Optimize operating periods of ventilation systems supplying heated spaces                  | 2                      | 3                        | 5           | Year 2   | seasonal review       |                    |
| M18  | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 3                        | 6           | Year 2   | seasonal review       |                    |
| M20  | Test and tune boiler efficiency  | 3                      | 3                        | 6           | Year 2   | seasonal review       |                    |
| M22  | Check heating system for flow balancing and air venting                                    | 3                      | 3                        | 6           | Year 2   | seasonal review       |                    |
| EN1  | Check and seal exterior walls and openings   | 3                      | 3                        | 6           | Year 2   | 10 to 15              |                    |
| EN5  | Seal window and door frames  | 3                      | 3                        | 6           | Year 2   | 5                     |                    |
| M23  | Optimize fan-coil unit and entrance heater controls  | 3                      | 3                        | 6           | Year 2   | seasonal review       |                    |
| M24  | Consider heating system zoning   | 2                      | 3                        | 5           | Year 2   | n/a                   |                    |
| M19  | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 3                        | 5           | Year 3   | 10 to 15              |                    |
| M21  | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| EN2  | Insulate the attic adequately  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| EN3  | Reclad the building's exterior   | 1                      | 3                        | 4           | Year 4   | 20 to 24              |                    |
| EN4  | Replace single-pane windows with double-pane windows                                       | 1                      | 3                        | 4           | Year 4   | 20 to 24              |                    |
| EN6  | If replacing the roof, ensure R-value at least 22  | 1                      | 3                        | 4           | Year 4   | n/a                   |                    |
| M25  | Install high efficiency burners  | 1                      | 3                        | 4           | Year 4   | 15 to 20              |                    |
| M26  | Replace boilers with more efficient models   | 1                      | 3                        | 4           | Year 4   | 15 to 20              |                    |
| M27  | Replace old rooftop units with energy efficient units                                      | 1                      | 3                        | 4           | Year 4   | 15 to 20              |                    |
| M28  | Install heat recovery or solar heating units   | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
|  | Other:   |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
Operational Measures  
Retrofit/Capital Measures

**Table 9: Energy Saving Measures for Administrative Offices and Related Facilities**

The specific measures and implementation timeline for each individual administrative office and related facility will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

**Proposed / Future Renewable Energy Installations**

| <b>Building Name</b>        | <b>Building Address</b> | <b>Renewable Installation</b> | <b>System Size</b> | <b>Unit</b> |
|-----------------------------|-------------------------|-------------------------------|--------------------|-------------|
| Elections Building          | 89 Northline Rd         | Solar PV                      | 100                | kW          |
| Etobicoke Civic Centre      | 2 Civic Centre Crt      | Solar PV                      | 40                 | kW          |
| Etobicoke Civic Centre      | 2 Civic Centre Crt      | Geothermal                    | 600                | kW          |
| Survey and Mapping Services | 18 Dyas Rd              | Solar PV                      | 60                 | kW          |
| East York Civic Centre      | 850 Coxwell Ave         | Geothermal                    | 700                | kW          |
| Eastville Training Centre   | 1 Eastville Ave         | Geothermal                    | 140                | kW          |
| Etobicoke Civic Centre      | 399 The West Mall       | Geothermal                    | 265                | kW          |

**Table 10 : Proposed Renewable Energy Systems for Administrative Offices and Related Facilities**



### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities, is \$4.20/ft<sup>2</sup> (see Appendix A). The budget allows for lighting audits, lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low potential buildings is set at 40 percent of the basic amount to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium and low potential administrative offices and related facilities are summarized in Table 7 below.

| Annual Savings Potential | Number of facilities | Average Area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | % of total savings | Payback     |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|--------------------|-------------|
| > \$100,000              | 16                   | 166,289                         | 5.04   | \$ 13,409,531                    | \$ 3,779,833                   | 83.1%              | 3.55        |
| \$5,000 - \$100,000      | 21                   | 92,329                          | 4.20   | \$ 8,143,386                     | \$ 739,852                     | 16.3%              | 11.01       |
| < \$5,000                | 14                   | 17,654                          | 1.68   | \$ 415,211                       | \$ 29,965                      | 0.7%               | 13.86       |
|                          | <b>51</b>            |                                 |  | <b>\$ 21,968,128</b>             | <b>\$ 4,549,651</b>            |                    | <b>4.83</b> |

**Table 11: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the specific measures for each building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.

- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 9 below.

|                |                                  | #         | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|-----------|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 16        | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 21        | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 14        | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | <b>51</b> |          |                     |                             |

**Table 12: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Building Performance Audit

There are 16 administrative offices and related facilities with over \$100,000 in annual energy saving potential. Over 83% of the total energy savings for all administrative offices and related facilities can be found at these 16 facilities.

These 16 administrative offices and related facilities can save an average of 39% of their total energy use. The total annual energy savings are estimated to be over \$3,779,800 and individual building annual savings range from approximately \$110,000 to over \$531,000. The annual GHG savings are estimated to be approximately 4,965,500 kg.

These 16 administrative offices and related facilities can save an average of 39% of their total electricity use (35% Electric Baseload, 49% Electric Cooling and 21% Electric Heating). The total annual electricity savings are estimated to be approximately \$3,470,009 and individual building annual savings range from just over \$92,350 to over \$519,000.

These 16 administrative offices and related facilities can save an average of 41% of their total gas use (82% Gas Baseload and 27% Gas Heating). The total annual gas savings are estimated to be approximately \$309,800 and individual building annual savings range from \$0 to over \$135,200.

These 16 administrative offices and related facilities will undergo Building Performance Audits (see the Implementation Plan for further details). For a complete description of the Building Performance Audit, refer to Appendix A.

See Appendix B for the associated energy savings potential by energy use component.

The highest percentage reductions for these facilities can be found in Gas Baseload and Electric Cooling. After the implementation of the proposed measures, these facilities are eligible to receive over \$2,100,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Assessment

There are 21 administrative offices and related facilities with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 16% of the total energy savings for all 51 administrative offices and related facilities can be found in these 21 facilities.

These 21 administrative offices and related facilities can save an average of 25% of their total energy use. The total annual energy savings are estimated to be almost \$740,000 and individual building annual savings range from approximately \$5,900 to almost \$90,700. The annual GHG savings are approximately 1,743,500 kg.

These 21 administrative offices and related facilities can save an average of 16% of their total electricity use (14% Electric Baseload, 58% Electric Cooling and 17% Electric Heating). The total annual electricity savings are estimated to be approximately \$559,400 and individual building annual savings range from \$0 to over \$76,500.

These 21 administrative offices and related facilities can save an average of 36% of their total gas use (81% Gas Baseload and 32% Gas Heating). The total annual gas savings are estimated to be approximately \$180,430 and individual building annual savings range from \$0 to over \$43,700.

These 21 facilities will undergo an Energy Assessment with highest potential administrative offices and related facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 21 administrative offices and related facilities and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 21 administrative offices and related facilities can be found in Electric Cooling and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these administrative offices and related facilities are eligible to receive over \$389,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.3 Energy Savings Checklist

There are 14 administrative offices and related facilities with less than \$5,000 in savings potential. Less than 1% of the total energy savings for all 51 administrative offices and related facilities can be found in these 14 facilities.

These 14 administrative offices and related facilities can save an average of 23% of their total energy use. The total annual energy savings are estimated to be approximately \$29,960 and individual building annual savings range from \$0 to almost \$5,000. The annual GHG savings are approximately 158,880 kg.

These 14 administrative offices and related facilities can save an average of 4% of their total electricity use (1% Electric Baseload, 53% Electric Cooling and 7% Electric Heating). The total annual electricity savings are estimated to be approximately \$8,955 and individual building annual savings range from \$0 to over \$4,000.

These 14 administrative offices and related facilities can save an average of 35% of their total gas use (54% Gas Baseload and 33% Gas Heating). The total annual gas savings are estimated to be approximately \$21,000 and individual building annual savings range from \$0 to over \$4,400.

These 14 facilities will undergo a checklist approach with highest potential administrative offices and related facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 14 administrative offices and related facilities and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 14 administrative offices and related facilities can be found in Electric Cooling and Gas Baseload.

The energy savings checklist will be used by the Division Champion for the administrative offices and related facilities in conjunction with the building operator and/or service contractor for each administrative office and related facility. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### **3.3 Implementation Budget**

Table 9 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 51 facilities. The total costs to implement the energy management and retrofit plan for administrative offices and related facilities are estimated to be \$22,105,978. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                      |
|----------------------------------|----------------------|
| Building Performance Audit (BPA) | \$ 120,000           |
| Energy Assessment                | \$ 15,750            |
| Checklist                        | \$ 2,100             |
| Implementation                   | \$ 21,968,128        |
| <b>Total</b>                     | <b>\$ 22,105,978</b> |

**Table 13: Total Budget - Energy Management and Retrofit Plan**

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 10 and Figure 5 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from the Building Performance Audit will occur in Year 1, with all 16 Building Performance Audits completed by the end of Year 4. The implementation of these measures will begin in Year 2 and will be completed by the end of Year 5. Identification of measures from Energy Assessments will begin in Year 1, with all 21 Energy Assessments completed by the end of Year 6. The implementation of these measures will begin in Year 2, and will be completed by the end of Year 7. Identification of measures from the Checklists will begin in Year 2, with all 17 Checklists completed by the end of Year 6. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification, and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$12,916,515. The cumulative net cash flow becomes positive in Year 8.

The implementation plan includes the following assumptions:

- Approximately 76% of the project budget will be spent in the first 5 years, and the other 24% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 76% of facilities will be retrofitted in the first 5 years and 24% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.

- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1     | Year 2        | Year 3        | Year 4         | Year 5         | Year 6        | Year 7        | Year 8       | Year 9       | Year 10       | Totals        |
|---|------------|---------------|---------------|----------------|----------------|---------------|---------------|--------------|--------------|---------------|---------------|
| High Potential - Building Performance Audit                           | 4          | 4             | 4             | 4              | 0              | 0             | 0             | 0            | 0            | 0             | 16            |
| Mid Potential - Energy Assessment                                     | 4          | 4             | 4             | 4              | 4              | 1             | 0             | 0            | 0            | 0             | 21            |
| Low Potential - Checklist   | 0          | 3             | 3             | 3              | 3              | 2             | 0             | 0            | 0            | 0             | 14            |
| Assessment Costs  | \$ 33,000  | \$ 33,468     | \$ 33,478     | \$ 33,487      | \$ 3,497       | \$ 1,088      | \$ -          | \$ -         | \$ -         | \$ -          | \$ 138,018    |
| Implementation Costs  | \$ -       | \$ 5,101,606  | \$ 5,298,057  | \$ 5,404,018   | \$ 5,512,099   | \$ 1,847,013  | \$ 513,573    | \$ -         | \$ -         | \$ -          | \$ 23,676,366 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 3,300   | \$ 513,507    | \$ 533,153    | \$ 543,751     | \$ 551,560     | \$ 184,810    | \$ 51,357     | \$ -         | \$ -         | \$ -          | \$ 2,381,438  |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -       | \$ 255,080    | \$ 519,983    | \$ 790,184     | \$ 1,065,789   | \$ 1,158,140  | \$ 1,183,818  | \$ 1,183,818 | \$ 1,183,818 | \$ 1,183,818  | \$ 1,183,818  |
| Annual Costs  | \$ 36,300  | \$ 5,903,661  | \$ 6,384,671  | \$ 6,771,440   | \$ 7,132,944   | \$ 3,191,051  | \$ 1,748,749  | \$ 1,183,818 | \$ 1,183,818 | \$ 1,183,818  | \$ 34,720,271 |
| Estimated Achieved Annual Savings                                     | \$ -       | \$ 612,263    | \$ 2,155,591  | \$ 3,897,953   | \$ 5,025,710   | \$ 5,869,444  | \$ 6,382,916  | \$ 6,719,716 | \$ 7,058,001 | \$ 7,410,901  | \$ 45,132,496 |
| Estimated Incentives  | \$ -       | \$ 1,232,629  | \$ 606,410    | \$ 346,303     | \$ 300,664     | \$ 15,643     | \$ 2,641      | \$ -         | \$ -         | \$ -          | \$ 2,504,290  |
| Annual Savings and Incentives   | \$ -       | \$ 1,844,892  | \$ 2,762,001  | \$ 4,244,257   | \$ 5,326,373   | \$ 5,885,087  | \$ 6,385,557  | \$ 6,719,716 | \$ 7,058,001 | \$ 7,410,901  | \$ 47,636,787 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       | \$ -       | \$ 1,452      | \$ 163,803    | \$ 308,710     | \$ 409,797     | \$ 482,060    | \$ 374,298    | \$ 188,826   | \$ -         | \$ -          | \$ 1,928,945  |
| Net Cash Flow incl borrowing costs                                    | -\$ 36,300 | -\$ 4,060,221 | -\$ 3,786,473 | -\$ 2,835,893  | -\$ 2,216,368  | -\$ 2,211,977 | -\$ 4,262,510 | \$ 5,347,072 | \$ 5,874,183 | \$ 6,227,083  | \$ 10,987,570 |
| Cumulative Net Cash Flow  | -\$ 36,300 | -\$ 4,095,069 | -\$ 7,717,739 | -\$ 10,244,923 | -\$ 12,051,494 | -\$ 9,357,458 | -\$ 4,720,649 | \$ 815,249   | \$ 6,689,432 | \$ 12,916,515 |               |

Table 14: Cash Flow for 10-Year Implementation Plan




Figure 9: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above). Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for administrative office and related facilities is determined as the average kWh/day for March, April, October and November multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from May to September, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

## Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Deep Lake Water Cooling:** Multiply Electric Cooling Target by 0.29

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

**Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:**

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>))+ Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup>



- (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Fire stations and associated offices and facilities
- Shelter, Support and Housing Administration
- Ambulance stations and associated offices and facilities
- Storage facilities where equipment or vehicles are maintained, repaired or stored
- Public libraries
- Long-Term Care Homes and Services
- Police Services facilities
- Children's Services
- Administrative offices and related facilities, including municipal council chambers

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 1.80                    | 100%       | 6.5           | 2.3                     |                                     |
| Mechanical   | 1.50                    | 30%        | 6             | 0.6                     | 0.7                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 0%         | 10            |                         | 0.2                                 |
| Process      | 0.15                    | 0%         | 5             |                         | 0.1                                 |
| <b>Total</b> | <b>4.20</b>             |            | <b>6.8</b>    | <b>3.19</b>             | <b>1.02</b>                         |

**Table 15: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls. They also include lighting audits.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process (domestic hot water) measures include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building’s existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers

- Performance based target setting customized for your building
- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### **Initial Energy Targets**

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available, the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.

## 5 Appendix B - Administrative Offices and Related Facilities

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 51 administrative office and related facility buildings included in this report and Plan.

| <b>Building</b>                 | <b>Address</b>        | <b>Building Area (ft<sup>2</sup>)</b> |
|---------------------------------|-----------------------|---------------------------------------|
| 21 Panorama                     | 21 Panorama Crt       | 96,369                                |
| 277 Victoria                    | 277 Victoria St       | 111,385                               |
| 505 Richmond                    | 505 Richmond St W     | 94,561                                |
| 52 Hillcrest Ave                | 52 Hillcrest Ave      | 4,585                                 |
| 60 Tiffield Rd                  | 60 Tiffield Rd        | 64,831                                |
| 75-81 Elizabeth                 | 77 Elizabeth St       | 14,768                                |
| 88 Sunrise Ave                  | 88 Sunrise Ave        | 34,843                                |
| 89 Northline Road               | 89 Northline Road     | 55,004                                |
| Archives and Records Centre     | 255 Spadina Rd        | 39,590                                |
| Atlantic Ave Storage Bldg       | 98 Atlantic Ave       | 43,002                                |
| Central Services Office         | 329 Chaplin Cres      | 18,299                                |
| Central Water Services          | 545 Commissioners St  | 32,679                                |
| City Hall                       | 100 Queen St W        | 780,060                               |
| Civic Centre Court 2            | 2 Civic Centre Crt    | 46,145                                |
| College Dovercourt Office       | 455 Dovercourt Rd     | 19,138                                |
| Consolidated Communication Ctr  | 703 Don Mills Rd      | 132,999                               |
| Dee Avenue Lab                  | 30 Dee Ave            | 14,994                                |
| Dyas Rd 18                      | 18 Dyas Rd            | 73,926                                |
| Dyas Road Archive Bldg          | 14 Dyas Rd            | 28,589                                |
| East York Civic Centre          | 850 Coxwell Ave       | 67,543                                |
| Eastern District Office         | 1 Eastville Ave       | 19,849                                |
| Etobicoke Civic Centre          | 399 The West Mall     | 154,925                               |
| Etobicoke North Office          | 220 Attwell Dr        | 20,279                                |
| Etobicoke South Office          | 779 The Queensway     | 22,497                                |
| Gunn Building                   | 1138 Bathurst Street  | 39,297                                |
| Health HQ                       | 524 Oakwood Ave       | 14,144                                |
| Health Office                   | 662 Jane St           | 2,540                                 |
| Inglis and Subway Ops Buildings | 1138 Bathurst Street  | 253,623                               |
| Markham Rd 1530                 | 1530 Markham Rd       | 120,104                               |
| McBrien Building                | 1900 Yonge Street     | 92,751                                |
| Memorial Park Ave 175           | 175 Memorial Park Ave | 6,394                                 |
| Metro Hall                      | 55 John St            | 787,186                               |
| North District Office           | 275 Merton St         | 66,748                                |

|                               |                          |         |
|-------------------------------|--------------------------|---------|
| North York Central Office     | 1117 Finch Ave W         | 18,934  |
| North York Civic Centre       | 5100 Yonge Street        | 303,510 |
| Old City Hall                 | 60 Queen St W            | 350,494 |
| Pape Avenue Multiuse Building | 126 Pape Ave             | 9,365   |
| Patten Building               | 835 Davenport Road       | 33,164  |
| Property Dept Workshop        | 786 Dundas St E          | 39,170  |
| Property Maintenance Office   | 149 River St             | 13,487  |
| Queen Street Office           | 1631 Queen St E          | 25,327  |
| Scarborough Admin Office      | 1076 Ellesmere Rd        | 20,398  |
| Scarborough Civic Centre      | 150 Borough Dr           | 372,861 |
| Scarborough North Office      | 5639 Finch Ave E         | 49,385  |
| Scarborough West Office       | 1225 Kennedy Rd          | 19,999  |
| St Lawrence Hall              | 157 King St East         | 55,413  |
| Support Services Building     | 1138 Bathurst Street     | 8,158   |
| Toronto Admin Office          | 281 Front St E           | 54,638  |
| Toronto Island Service Office | 0 Hanlans Pt, B22 Office | 20,968  |
| Western District Office       | 61 Edgehill Rd           | 4,844   |
| York Civic Center             | 2700 Eglinton Ave W      | 72,915  |

**Table 16: Administrative Office and Related Facility Building Information**

## 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 51 administrative office and related facility buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| Building                      | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|-------------------------------|---|--|---|
| 52 Hillcrest Ave              | 1.45  | 5.39   | 6.84  |
| Health Office                 | 5.81  | 3.40   | 9.21  |
| Toronto Island Service Office | 3.11  | 6.25   | 9.37  |
| Atlantic Ave Storage Bldg     | 1.84  | 7.69   | 9.53  |
| North District Office         | 4.51  | 5.21   | 9.72  |
| Patten Building               | 14.79   | 0.00   | 14.79   |
| Support Services Building     | 14.79   | 0.00   | 14.79   |
| Central Services Office       | 7.89  | 9.77   | 17.66   |
| Old City Hall                 | 9.48  | 8.70   | 18.19   |
| Eastern District Office       | 5.03  | 14.18  | 19.21   |
| 21 Panorama                   | 9.87  | 9.40   | 19.27   |
| Dyas Rd 18                    | 17.55   | 4.19   | 21.74   |

|                                 |       |       |        |
|---------------------------------|-------|-------|--------|
| 277 Victoria                    | 19.82 | 2.01  | 21.82  |
| Scarborough Admin Office        | 5.90  | 16.08 | 21.97  |
| 89 Northline Road               | 7.07  | 15.08 | 22.15  |
| Inglis and Subway Ops Buildings | 14.79 | 7.78  | 22.57  |
| Health HQ                       | 11.82 | 10.88 | 22.70  |
| 75-81 Elizabeth                 | 12.21 | 11.07 | 23.28  |
| Scarborough Civic Centre        | 18.72 | 6.12  | 24.84  |
| Scarborough North Office        | 20.80 | 4.14  | 24.94  |
| Property Maintenance Office     | 8.12  | 18.64 | 26.77  |
| College Dovercourt Office       | 2.43  | 25.42 | 27.85  |
| Etobicoke South Office          | 19.04 | 9.29  | 28.33  |
| Queen Street Office             | 15.03 | 13.49 | 28.52  |
| Metro Hall                      | 22.07 | 6.70  | 28.77  |
| Memorial Park Ave 175           | 11.43 | 17.63 | 29.05  |
| Civic Centre Court 2            | 29.85 | 0.00  | 29.85  |
| 505 Richmond                    | 4.63  | 25.38 | 30.01  |
| Toronto Admin Office            | 12.32 | 17.75 | 30.07  |
| Western District Office         | 3.92  | 26.52 | 30.44  |
| Markham Rd 1530                 | 17.14 | 13.44 | 30.58  |
| 88 Sunrise Ave                  | 17.77 | 13.49 | 31.26  |
| Property Dept Workshop          | 3.26  | 28.47 | 31.73  |
| City Hall                       | 23.94 | 8.39  | 32.33  |
| Etobicoke Civic Centre          | 16.83 | 16.24 | 33.07  |
| Etobicoke North Office          | 25.56 | 9.12  | 34.69  |
| East York Civic Centre          | 23.62 | 11.51 | 35.14  |
| Dyas Road Archive Bldg          | 19.45 | 16.14 | 35.59  |
| Pape Avenue Multiuse Building   | 8.82  | 26.94 | 35.77  |
| St Lawrence Hall                | 23.97 | 11.83 | 35.80  |
| North York Central Office       | 19.89 | 20.23 | 40.12  |
| Central Water Services          | 36.13 | 7.84  | 43.97  |
| York Civic Center               | 22.63 | 21.52 | 44.15  |
| Scarborough West Office         | 25.66 | 20.99 | 46.65  |
| North York Civic Centre         | 24.12 | 22.87 | 46.99  |
| Archives and Records Centre     | 24.07 | 28.60 | 52.67  |
| McBrien Building                | 42.04 | 13.72 | 55.76  |
| Gunn Building                   | 58.14 | 14.97 | 73.12  |
| 60 Tiffield Rd                  | 44.49 | 29.20 | 73.69  |
| Consolidated Communication Ctr  | 65.16 | 9.69  | 74.85  |
| Dee Avenue Lab                  | 96.35 | 32.50 | 128.85 |

**Table 17: Administrative Office and Related Facility 2012 Energy Intensity**

### 5.3 Target-setting Method and Metrics

7 administrative offices and related facilities were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.


| Facility                        | Days in 2012  | Energy type |
|---------------------------------|---|-------------|
| Gunn Building                   | TTC buildings for which only annual usage numbers were made available |             |
| Inglis and Subway Ops Buildings | TTC buildings for which only annual usage numbers were made available |             |
| McBrien Building                | TTC buildings for which only annual usage numbers were made available |             |
| Patten Building                 | TTC buildings for which only annual usage numbers were made available |             |
| Support Services Building       | TTC buildings for which only annual usage numbers were made available |             |
| Memorial Park Ave 175           | 330   | Electricity |
| Health Office                   | 396   | Electricity |

**Table 18: Excluded Facilities**

After excluding these 7 facilities, 44 City of Toronto facilities and 8 facilities from other municipalities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.

The red line on each chart indicates the top quartile for each component which is the target for that component.



**Figure 10: 2012 Electric Baseload Intensity Benchmark**

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for administrative offices and related facilities ranges from 4.2 to 88.2 ekWh/ft<sup>2</sup> and the top-quartile is 10.92 ekWh/ft<sup>2</sup>.




Figure 11: 2012 Electric Cooling Intensity Benchmark

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for administrative offices and related facilities ranges from 0.2 to 4.0 ekWh/ft<sup>2</sup> and the top-quartile is 0.69 ekWh/ft<sup>2</sup>.





Figure 12: 2012 Electric Heating Intensity Benchmark


Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for administrative offices and related facilities ranges from 0.2 to 6.9 ekWh/ft<sup>2</sup> and the top-quartile is 0.34 ekWh/ft<sup>2</sup>.





**Figure 13: 2012 Gas Baseload Intensity Benchmark**

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for administrative offices and related facilities ranges from 0.9 to 18.4 ekWh/ft<sup>2</sup> and the top-quartile is 1.01 ekWh/ft<sup>2</sup>.



**Figure 14: 2012 Gas Heating Intensity Benchmark**

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for administrative offices and related facilities ranges from 1.8 to 30.2 ekWh/ft<sup>2</sup> and the top-quartile is 7.15 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of administrative offices and related facilities, the factors are % of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps, % of the area served by electric air

conditioning, % of the area served by a data centre, % of area served by food services and presence of an outdoor ice rink.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 16 High Savings Potential Administrative Offices and Related Facilities

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 16 administrative offices and related facilities with over \$100,000 in annual savings potential.

| Operation name                         | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         | Total Energy Savings Potential |           | Incentives  |             | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |           |           |
|--|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|--------------------------------|-----------|-------------|-------------|--------------------------------|------------------------|-----------|-----------|
|  | Average %                     |         |         |       | Average %             |           |         | Avg %                          | \$/yr     | Electricity | Gas         |                                |                        |           |           |
|  | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating |                                |           |             |             | Total                          | \$/yr                  |           |           |
| High potential savings facilities (16) | 35%                           | 49%     | 21%     | 39%   | \$3,470,009           | 82%       | 27%     | 41%                            | \$309,824 | 39%         | \$3,779,833 | \$1,982,862                    | \$119,163              | 2,660,621 | 4,965,509 |
| City Hall                              | 29%                           |         |         | 29%   | \$ 519,242            | 24%       | 4%      |                                | \$ 11,875 | 21%         | \$ 531,117  | \$ 296,710                     | \$ 4,567               | 780,060   | 493,795   |
| North York Civic Centre                | 37%                           | 45%     | 17%     | 38%   | \$ 385,207            | 100%      |         | 78%                            | \$135,263 | 57%         | \$ 520,470  | \$ 220,118                     | \$ 52,024              | 303,510   | 1,280,196 |
| Consolidated Communication Ctr         | 36%                           | 100%    |         | 37%   | \$ 450,826            | 100%      | 16%     | 26%                            | \$ 8,501  | 36%         | \$ 459,327  | \$ 257,615                     | \$ 3,270               | 132,999   | 415,658   |
| McBrien Building                       |                               |         |         | 73%   | \$ 399,603            |           |         | 41%                            | \$ 12,956 | 65%         | \$ 412,559  | \$ 228,344                     | \$ 4,983               | 92,751    | 407,606   |
| 60 Tiffield Rd                         | 58%                           |         |         | 58%   | \$ 235,420            | 73%       | 84%     | 83%                            | \$ 39,544 | 68%         | \$ 274,965  | \$ 134,526                     | \$ 15,209              | 64,831    | 470,755   |
| Gunn Building                          |                               |         |         | 81%   | \$ 257,914            |           |         | 46%                            | \$ 6,725  | 73%         | \$ 264,639  | \$ 147,379                     | \$ 2,587               | 39,297    | 251,250   |
| Scarborough Civic Centre               | 23%                           |         | 51%     | 23%   | \$ 228,332            |           |         | 0%                             | \$ -      | 18%         | \$ 228,332  | \$ 130,476                     | \$ -                   | 372,861   | 179,404   |
| 277 Victoria                           | 40%                           | 100%    |         | 43%   | \$ 132,766            |           |         | 0%                             | \$ -      | 39%         | \$ 132,766  | \$ 75,867                      | \$ -                   | 111,385   | 104,316   |
| York Civic Center                      | 41%                           | 57%     |         | 43%   | \$ 99,202             | 87%       | 55%     | 72%                            | \$ 28,309 | 57%         | \$ 127,510  | \$ 56,687                      | \$ 10,888              | 72,915    | 282,528   |
| Inglis and Subway Ops Buildings        |                               |         |         | 24%   | \$ 125,074            |           |         | 0%                             | \$ -      | 16%         | \$ 125,074  | \$ 71,471                      | \$ -                   | 253,623   | 98,272    |
| Etoibcoke Civic Centre                 | 24%                           | 36%     |         | 25%   | \$ 92,356             | 23%       | 52%     | 50%                            | \$ 31,461 | 37%         | \$ 123,817  | \$ 52,775                      | \$ 12,100              | 154,925   | 299,930   |
| East York Civic Centre                 | 45%                           | 100%    | 43%     | 52%   | \$ 116,772            | 32%       | 29%     | 29%                            | \$ 5,685  | 45%         | \$ 122,457  | \$ 66,727                      | \$ 2,186               | 67,543    | 132,833   |
| Dee Avenue Lab                         | 53%                           |         | 64%     | 53%   | \$ 106,886            | 100%      | 86%     | 86%                            | \$ 10,480 | 61%         | \$ 117,366  | \$ 61,078                      | \$ 4,031               | 14,994    | 159,717   |
| Markham Rd 1530                        | 28%                           | 100%    |         | 34%   | \$ 99,285             |           | 44%     | 41%                            | \$ 16,755 | 37%         | \$ 116,040  | \$ 56,734                      | \$ 6,444               | 120,104   | 199,094   |
| Civic Centre Court 2                   | 62%                           |         |         | 59%   | \$ 113,307            |           |         |                                | \$ -      | 59%         | \$ 113,307  | \$ 64,747                      | \$ -                   | 46,145    | 89,027    |
| Central Water Services                 | 67%                           |         | 25%     | 65%   | \$ 107,816            |           | 36%     | 35%                            | \$ 2,271  | 60%         | \$ 110,087  | \$ 61,609                      | \$ 874                 | 32,679    | 101,125   |

Table 19: Savings Potential for 16 High Savings Potential Administrative Facilities

### Savings Potential by Energy Use Component for the 21 Mid Savings Potential Administrative Offices and Related Facilities

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 21 administrative offices and related facilities with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |            | Indoor Area | GHG Emissions |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|------------|-------------|---------------|-----------|
|                                       | Average %                     |         |         |       | Average %             |           |         |       | Avg %                          | \$/yr | Electricity | Gas        |             |               |           |
|                                       | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating | Total |                                |       |             |            | \$/yr       |               |           |
| Mid-potential savings facilities (21) | 14%                           | 58%     | 17%     | 16%   | \$ 559,425            | 81%       | 32%     | 36%   | \$180,427                      | 25%   | \$ 739,852  | \$ 319,672 | \$ 69,395   | 1,938,902     | 1,743,479 |
| Archives and Records Centre           | 48%                           | 67%     |         | 53%   | \$ 70,407             | 95%       | 29%     | 71%   | \$ 20,264                      | 63%   | \$ 90,671   | \$ 40,233  | \$ 7,794    | 39,590        | 201,764   |
| St Lawrence Hall                      | 38%                           | 62%     |         | 41%   | \$ 76,537             | 83%       |         |       | \$ 6,993                       | 42%   | \$ 83,530   | \$ 43,735  | \$ 2,690    | 55,413        | 110,676   |
| Scarborough North Office              | 45%                           |         |         | 46%   | \$ 65,966             |           | 14%     | 14%   | \$ 714                         | 41%   | \$ 66,680   | \$ 37,695  | \$ 274      | 49,385        | 56,987    |
| Dyas Rd 18                            | 28%                           | 100%    |         | 31%   | \$ 57,010             |           |         | 0%    | \$ -                           | 25%   | \$ 57,010   | \$ 32,577  | \$ -        | 73,926        | 44,793    |
| Metro Hall                            | 4%                            |         |         | 4%    | \$ 56,721             |           |         |       | \$ -                           | 3%    | \$ 56,721   | \$ 32,412  | \$ -        | 787,186       | 44,567    |
| Scarborough West Office               | 50%                           | 54%     |         | 49%   | \$ 35,330             | 100%      | 75%     | 80%   | \$ 8,422                       | 63%   | \$ 43,752   | \$ 20,188  | \$ 3,239    | 19,999        | 88,623    |
| 505 Richmond                          |                               |         |         | 0%    | \$ -                  |           | 72%     | 73%   | \$ 43,737                      | 61%   | \$ 43,737   | \$ -       | \$ 16,822   | 94,561        | 316,084   |
| Old City Hall                         |                               | 73%     | 23%     | 8%    | \$ 30,600             |           | 17%     |       | \$ 12,646                      | 12%   | \$ 43,245   | \$ 17,486  | \$ 4,864    | 350,494       | 115,431   |
| Etobicoke North Office                | 53%                           | 67%     | 71%     | 55%   | \$ 39,562             |           | 18%     | 17%   | \$ 806                         | 45%   | \$ 40,368   | \$ 22,607  | \$ 310      | 20,279        | 36,912    |
| 88 Sunnyside Ave                      | 36%                           |         |         | 34%   | \$ 29,897             |           | 46%     | 45%   | \$ 5,372                       | 39%   | \$ 35,269   | \$ 17,084  | \$ 2,066    | 34,843        | 62,315    |
| North York Central Office             | 37%                           | 64%     |         | 38%   | \$ 20,138             |           | 73%     | 71%   | \$ 6,868                       | 55%   | \$ 27,006   | \$ 11,507  | \$ 2,642    | 18,934        | 65,460    |
| Toronto Admin Office                  |                               | 100%    |         | 14%   | \$ 12,745             | 62%       | 53%     | 55%   | \$ 13,331                      | 38%   | \$ 26,076   | \$ 7,283   | \$ 5,127    | 54,638        | 106,356   |
| Etobicoke South Office                | 35%                           | 100%    | 40%     | 41%   | \$ 24,415             |           | 22%     | 22%   | \$ 1,149                       | 35%   | \$ 25,564   | \$ 13,951  | \$ 442      | 22,497        | 27,486    |
| 89 Northline Road                     |                               | 100%    |         | 23%   | \$ 12,716             |           | 53%     | 53%   | \$ 10,994                      | 43%   | \$ 23,709   | \$ 7,266   | \$ 4,228    | 55,004        | 89,443    |
| Property Dept Workshop                |                               |         |         | 0%    | \$ -                  | 100%      | 73%     | 74%   | \$ 20,718                      | 66%   | \$ 20,718   | \$ -       | \$ 7,968    | 39,170        | 149,726   |
| Patten Building                       |                               |         |         | 24%   | \$ 16,356             |           |         |       | \$ -                           | 24%   | \$ 16,356   | \$ 9,346   | \$ -        | 33,164        | 12,851    |
| Dyas Road Archive Bldg                |                               | 100%    |         | 5%    | \$ 4,197              |           | 55%     | 54%   | \$ 6,314                       | 28%   | \$ 10,511   | \$ 2,398   | \$ 2,428    | 28,589        | 48,928    |
| College Dovercourt Office             |                               |         |         | 0%    | \$ -                  |           | 72%     | 71%   | \$ 8,653                       | 65%   | \$ 8,653    | \$ -       | \$ 3,328    | 19,138        | 62,534    |
| 21 Panorama                           |                               | 14%     |         | 2%    | \$ 2,869              |           | 23%     | 23%   | \$ 5,137                       | 12%   | \$ 8,006    | \$ 1,640   | \$ 1,976    | 96,369        | 39,378    |
| Scarborough Admin Office              |                               | 100%    | 7%      | 12%   | \$ 2,030              |           | 54%     | 52%   | \$ 4,318                       | 42%   | \$ 6,348    | \$ 1,160   | \$ 1,661    | 20,398        | 32,801    |
| Queen Street Office                   |                               | 29%     |         | 4%    | \$ 1,931              | 100%      | 35%     | 47%   | \$ 3,992                       | 24%   | \$ 5,923    | \$ 1,104   | \$ 1,535    | 25,327        | 30,365    |

Table 20: Savings Potential for 21 Medium Savings Potential Administrative Facilities

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

**Savings Potential by Energy Use Component for the 14 Low Savings Potential Administrative Offices and Related Facilities**

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 14 administrative offices and related facilities with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |          | Indoor Area | GHG Emissions |         |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|----------|-------------|---------------|---------|
|                                       | Average %                     |         |         |       | Average %             |           |         |       | Avg %                          | \$/yr | Electricity | Gas      |             |               |         |
|                                       | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating | Total |                                |       |             |          | \$/yr       |               |         |
| Low potential savings facilities (14) | 01%                           | 53%     | 07%     | 04%   | \$ 8,955              | 54%       | 33%     | 35%   | \$ 21,010                      | 23%   | \$ 29,965   | \$ 5,117 | \$ 8,081    | 247,149       | 158,876 |
| Pape Avenue Multiuse Building         |                               | 100%    |         | 5%    | \$ 578                | 76%       | 69%     | 69%   | \$ 4,404                       | 54%   | \$ 4,983    | \$ 331   | \$ 1,694    | 9,365         | 32,283  |
| Property Maintenance Office           |                               |         | 29%     | 3%    | \$ 471                |           | 63%     | 62%   | \$ 3,887                       | 44%   | \$ 4,358    | \$ 269   | \$ 1,495    | 13,487        | 28,464  |
| Eastern District Office               |                               |         |         | 0%    | \$ -                  | 100%      | 55%     | 58%   | \$ 4,073                       | 43%   | \$ 4,073    | \$ -     | \$ 1,567    | 19,849        | 29,436  |
| Support Services Building             |                               |         |         | 24%   | \$ 4,026              |           |         |       | \$ -                           | 24%   | \$ 4,026    | \$ 2,301 | \$ -        | 8,158         | 3,163   |
| 75-81 Elizabeth                       | 8%                            | 100%    | 2%      | 8%    | \$ 1,972              |           | 32%     | 30%   | \$ 1,238                       | 18%   | \$ 3,210    | \$ 1,127 | \$ 476      | 14,768        | 10,495  |
| Western District Office               |                               |         |         | 0%    | \$ -                  |           | 77%     | 76%   | \$ 2,443                       | 66%   | \$ 2,443    | \$ -     | \$ 940      | 4,844         | 17,656  |
| Memorial Park Ave 175                 |                               |         |         | 0%    | \$ -                  |           |         | 58%   | \$ 1,635                       | 35%   | \$ 1,635    | \$ -     | \$ 629      | 6,394         | 11,819  |
| Central Services Office               |                               |         |         | 0%    | \$ -                  |           | 36%     | 35%   | \$ 1,552                       | 19%   | \$ 1,552    | \$ -     | \$ 597      | 18,299        | 11,219  |
| Toronto Island Service Office         |                               | 100%    |         | 14%   | \$ 1,259              |           |         | 0%    | \$ -                           | 5%    | \$ 1,259    | \$ 719   | \$ -        | 20,968        | 989     |
| Health HQ                             | 0%                            |         | 14%     | 1%    | \$ 146                |           | 28%     | 25%   | \$ 978                         | 12%   | \$ 1,124    | \$ 83    | \$ 376      | 14,144        | 7,184   |
| Atlantic Ave Storage Bldg             |                               | 100%    |         | 5%    | \$ 503                |           | 5%      | 5%    | \$ 415                         | 5%    | \$ 918      | \$ 288   | \$ 160      | 43,002        | 3,395   |
| North District Office                 |                               |         |         | 0%    | \$ -                  | 100%      |         | 4%    | \$ 378                         | 2%    | \$ 378      | \$ -     | \$ 145      | 66,748        | 2,729   |
| 52 Hillcrest Ave                      |                               |         |         | 0%    | \$ -                  | 100%      |         | 1%    | \$ 6                           | 1%    | \$ 6        | \$ -     | \$ 2        | 4,585         | 45      |
| Health Office                         |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -     | \$ -        | 2,540         | 0       |

Table 21: Savings Potential for 14 Low Savings Potential Administrative Facilities

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) / \text{Actual Energy Use}$  and \$/year savings for each component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) * \text{utility company rates}$  \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Children's Services

---

## Table of Contents

|          |   |           |
|----------|---|-----------|
| <b>1</b> | <b>Benchmarking and Conservation Potential .....</b>  | <b>50</b> |
| 1.1      | Energy Use and Building Characteristics.....  | 50        |
| 1.1.1    | Building Characteristics.....   | 50        |
| 1.1.2    | Summary of Energy Use and Costs .....   | 50        |
| 1.2      | Energy Targets.....   | 53        |
| 1.3      | Savings Potential.....  | 53        |
| <b>2</b> | <b>Conservation Measures and Budget.....</b>  | <b>55</b> |
| 2.1      | Proposed Energy Efficiency Measures .....   | 55        |
| <b>3</b> | <b>Energy Management and Retrofit Plan .....</b>  | <b>61</b> |
| 3.1      | Implementation Costs and Modeled Savings .....  | 61        |
| 3.2      | Implementation Process and Tools – Determining the Specific Measures for Each Building .... | 61        |
| 3.2.1    | Energy Assessment .....   | 62        |
| 3.2.2    | Energy Savings Checklist .....  | 63        |
| 3.3      | Implementation Budget.....  | 63        |
| 3.4      | 10-Year Implementation Plan .....   | 64        |
| <b>4</b> | <b>Appendix A.....</b>  | <b>66</b> |
| 4.1      | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....       | 66        |
| 4.2      | Determining Energy Use Components.....  | 66        |
| 4.3      | Determining Targets .....   | 66        |
| 4.4      | Calculating Potential Savings .....   | 68        |
| 4.5      | Implementation Costs by Measure Type and Modeled Savings.....                               | 68        |
| 4.6      | Assessment Tools.....   | 69        |
| <b>5</b> | <b>Appendix B - Children’s Services Buildings .....</b>                                     | <b>71</b> |
| 5.1      | Buildings and Building Characteristics .....  | 71        |
| 5.2      | Energy Use Intensities.....   | 71        |
| 5.3      | Target-setting Method and Metrics.....  | 72        |
| 5.4      | Savings Potential by Energy Use Component .....   | 74        |

## List of Tables

|   |    |
|---|----|
| Table 22: 2012 Energy Use and Costs for 9 City of Toronto Children’s Services Buildings.....        | 50 |
| Table 23: Top Quartile Targets.....   | 53 |
| Table 24: Savings Potential Summary.....  | 54 |
| Table 25: Savings Potential Based on Energy Use Component for 9 Children’s Services Buildings ..... | 54 |
| Table 24: Energy Saving Measures for Children’s Services Buildings .....                            | 60 |
| Table 27: Estimated Implementation Costs and Modeled Savings .....                                  | 61 |
| Table 28: Assessment Tools Used to Determine Specific Energy-saving Measures .....                  | 62 |
| Table 29: Total Budget - Energy Management and Retrofit Plan .....                                  | 64 |
| Table 30: Cash Flow for 10-Year Implementation Plan .....   | 65 |
| Table 31: Implementation Costs by Measure Type .....  | 69 |
| Table 32: Children’s Services Building Information .....  | 71 |
| Table 33: Children’s Services 2012 Energy Intensity .....   | 71 |
| Table 34: Savings Potential for 4 Medium Savings Potential Children’s Services Buildings .....      | 75 |
| Table 35: Savings Potential for 5 Low-Savings Potential Children’s Services Buildings.....          | 75 |

## List of Figures

|  |    |
|--|----|
| Figure 15: 2012 Energy Use and Cost Breakdown for City of Toronto Children’s Services Buildings..... | 51 |
| Figure 16: 2012 Total Energy Intensity Benchmark .....   | 51 |
| Figure 17: 2012 Total Electricity Intensity Benchmark .....  | 52 |
| Figure 18: 2012 Total Gas Intensity Benchmark .....  | 52 |
| Figure 19: Cash Flow for 10-Year Implementation Plan .....   | 65 |
| Figure 20: 2012 Electric Baseload Intensity Benchmark.....   | 72 |
| Figure 21: 2012 Electric Cooling Intensity Benchmark .....   | 72 |
| Figure 22: 2012 Electric Heating Intensity Benchmark.....  | 73 |
| Figure 23: 2012 Gas Baseload Intensity Benchmark.....  | 73 |
| Figure 24: 2012 Gas Heating Intensity Benchmark.....   | 74 |

# 1 Benchmarking and Conservation Potential

## 1.1 Energy Use and Building Characteristics

### 1.1.1 Building Characteristics

The City of Toronto is reporting on 9 children’s services buildings in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B. All 9 buildings are childcare centres.

The total area for all buildings is 64,186 ft<sup>2</sup>. The children’s services buildings range in size from less than 5,000 ft<sup>2</sup> to over 11,000 ft<sup>2</sup>.

There is one geothermal installation at Yonge Hearts Child Care Centre located at 5176 Yonge Street.

The majority of the children’s services buildings are 100% air-conditioned, with the exception of Woodbine Childcare Centre (which is not air-conditioned). Three facilities are served by less than 10% of electric heat (City Kids Childcare Centre, Albion Road Childcare and Malvern Childcare Centre). Even though they are not reported to be using electric heat, the electricity profiles show that the majority of the other children’s services buildings have significant additional use of electricity in winter months. While some of this usage may be due to longer hours of lighting or electric motors, use of electric heaters is indicated and should be further explored. Identifying and limiting electricity use associated with space heating will be one of the first measures recommended in the plan (see section on proposed energy efficiency measures). Most of the children’s services buildings (with the exception of Woodbine Childcare Centre and Jesse Ketchum Childcare Centre) are partially served by water source heat pumps.

### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 9 buildings are summarized below.

|                                    | 2012 Energy Use |                  |
|------------------------------------|-----------------|------------------|
|                                    | Unit            | \$               |
| <b>Electricity (kWh)</b>           | 972,955         | \$136,214        |
| <b>Natural Gas (m<sup>3</sup>)</b> | 149,634         | \$38,905         |
| <b>Total</b>                       |                 | <b>\$175,118</b> |

Table 22: 2012 Energy Use and Costs for 9 City of Toronto Children’s Services Buildings






Figure 15: 2012 Energy Use and Cost Breakdown for City of Toronto Children’s Services Buildings

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 9 buildings. Total energy use ranges from approximately 17 to over 100 ekWh/ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 16: 2012 Total Energy Intensity Benchmark




Figure 17: 2012 Total Electricity Intensity Benchmark




Figure 18: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for children’s services buildings are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each children’s services building to achieve its target over the duration of the ECDM Plan.

| Energy type         | Component    | Value       | Unit                            |
|---------------------|--------------|-------------|---------------------------------|
| Electricity         | Base         | 11.3        | kWh/ft <sup>2</sup> /year       |
|                     | Cooling      | 0.5         | kWh/ft <sup>2</sup> /year       |
|                     | Heating      | 0.4         | kWh/ft <sup>2</sup> /year       |
|                     | <b>Total</b> | <b>12.3</b> | <b>kWh/ft<sup>2</sup>/year</b>  |
| Gas                 | Base         | 3.1         | ekWh/ft <sup>2</sup> /year      |
|                     | Heating      | 7.6         | ekWh/ft <sup>2</sup> /year      |
|                     | <b>Total</b> | <b>10.7</b> | <b>ekWh/ft<sup>2</sup>/year</b> |
| <b>Total energy</b> | <b>Total</b> | <b>23.0</b> | <b>ekWh/ft<sup>2</sup>/year</b> |

**Table 23: Top Quartile Targets**

9 children’s services buildings made up the data set for target-setting, all of which are City of Toronto buildings with complete and reliable data. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), and % of the area which is air conditioned. The specific target adjustments are found in Appendix A.

## 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each children’s services building. The total savings potential for each children’s services building is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 9 children’s services buildings are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are no children’s services buildings with annual savings potential greater than \$100,000. 4 children’s services buildings have annual savings potential between \$5,000 and \$100,000 and 5 children’s services buildings have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 9 buildings is \$48,045 (\$31,311 for electricity and \$16,733 for gas) with an average total energy savings of 35%.

For the 4 mid-potential savings facilities, the total annual savings potential is \$39,803 (\$29,522 for electricity and \$10,281 for gas) with an average total energy savings of 46%.

For the 5 low-potential savings facilities, the total annual savings potential is \$8,242 (\$1,790 for electricity and \$6,453 for gas) with an average total energy savings of 23%.

| Operation name                       | Electricity Savings Potential |            |            |            | \$/yr            | Gas Savings Potential |            |            | \$/yr            | Total Energy Savings Potential |                  | Incentives       |                 | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|--------------------------------------|-------------------------------|------------|------------|------------|------------------|-----------------------|------------|------------|------------------|--------------------------------|------------------|------------------|-----------------|--------------------------------|------------------------|
|                                      | Average %                     |            |            |            |                  | Average %             |            |            |                  | Avg %                          | \$/yr            | Electricity      | Gas             |                                |                        |
|                                      | Base-load                     | Cooling    | Heating    | Total      |                  | Base-load             | Heating    | Total      |                  |                                |                  |                  |                 |                                |                        |
| <b>TOTAL: 9 facilities</b>           | <b>16%</b>                    | <b>45%</b> | <b>70%</b> | <b>23%</b> | <b>\$ 31,311</b> | <b>72%</b>            | <b>24%</b> | <b>43%</b> | <b>\$ 16,733</b> | <b>35%</b>                     | <b>\$ 48,045</b> | <b>\$ 17,892</b> | <b>\$ 6,436</b> | <b>64,186</b>                  | <b>145,533</b>         |
| Mid-potential savings facilities (4) | 27%                           | 55%        | 80%        | 35%        | \$ 29,522        | 83%                   | 14%        | 55%        | \$ 10,281        | 46%                            | \$ 39,803        | \$ 16,870        | \$ 3,954        | 24,714                         | 97,495                 |
| Low potential savings facilities (5) | 02%                           | 20%        | 26%        | 03%        | \$ 1,790         | 45%                   | 29%        | 32%        | \$ 6,453         | 23%                            | \$ 8,242         | \$ 1,023         | \$ 2,482        | 39,472                         | 48,038                 |

**Table 24: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest percentage savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 9 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 12.9        | 10.8        | 16%                 | \$ 18,830            |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 0.7         | 0.4         | 45%                 | \$ 2,820             |
| Electric Heating (kWh/ft <sup>2</sup> )   | 2.0         | 0.6         | 70%                 | \$ 9,661             |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 0.0         | 0.0         | 0%                  | \$ -                 |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 9.5         | 2.6         | 72%                 | \$ 11,107            |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 14.6        | 11.1        | 24%                 | \$ 5,627             |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 0.0         | 0.0         | 0%                  | \$ -                 |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>39.3</b> | <b>25.4</b> | <b>35%</b>          | <b>\$ 48,045</b>     |

High savings

Moderate

Low savings

**Table 25: Savings Potential Based on Energy Use Component for 9 Children’s Services Buildings**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (Electric Heating (i.e. higher electricity use in winter months as described above under Building Characteristics) and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Proposed Energy Efficiency Measures

Table 5 below shows the full range of possible energy efficiency measures for the entire portfolio of children's services buildings. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 9 facilities indicate that the largest percentage reductions will come from measures associated with electric cooling, electric heating and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).

| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off machines, office and kitchen equipment when not needed                                  | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B2   | Unplug machines, office and kitchen equipment if not actively used                               | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off computer monitors when not in use   | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B4   | Enable ENERGY STAR power settings on your computer   | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B5   | Unplug chargers when not in use  | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B6   | Turn off lights when areas not in use  | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| B7   | Make use of natural light instead of turning on lights where possible                            | 4                      | 1                        | 5           | Year 1   | Annual Review         | Building Occupants |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 1                        | 4           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 1                        | 4           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 1                        | 4           | Year 4   | 15+                   |                    |
| L1   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L2   | Install motion sensors in washrooms/occasional use spaces to shut off lights when unoccupied     | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L3   | Install photo-sensors and/or a timer on outdoor and daylit interior area lighting                | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L4   | Replace HID lighting with high efficiency fluorescent  | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L5   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L6   | Replace festive lighting with LED  | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| L7   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 1                        | 2           | Year 5   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 1                        | 2           | Year 5   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 1                        | 2           | Year 5   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| M3   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 1                        | 2           | Year 5   | 10 to 20              |                    |
| M4   | Convert electric hot water heaters to natural gas  | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Electric Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes</b> |  |                        |                          |             |          |                       |                    |
| B8   | Adjust blinds (to retain heat in winter)   | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B9   | Avoid use of electric heaters  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B10  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M8   | Control fan coil and entrance heaters to optimize run-times                                | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M9   | Evaluate conversion from electric heating to natural gas                                   | 2                      | 4                        | 6           | Year 2   | n/a                   |                    |
| M5   | Install snow sensors to control the snow-melting system                                    | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| M6   | Upgrade base building heating system to avoid use of electric heaters                      | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| M7   | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Electric Cooling Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes</b> |  |                        |                          |             |          |                       |                    |
| B11  | Winterize room air-conditioners  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B12  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B13  | Only cool rooms that are being used  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B14  | Install and use energy efficient ceiling fans  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B15  | Close blinds (to shade space from direct sunlight)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B16  | Install window film, solar screens or awnings on south and west facing windows               | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M10  | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M12  | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M13  | Test and tune the air conditioning units   | 3                      | 4                        | 7           | Year 2   | 3                     |                    |
| M11  | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures



| Gas Baseload Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round</b> |  |                        |                          |             |          |                       |                    |
| B17  | Optimize dishwasher operation (only run when full) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| P3   | Test and tune DHW boiler efficiency                | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M16  | Investigate and repair possible gas leaks          | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P1   | Optimize DHW temperature control                   | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| P2   | Implement DHW circulation pump control             | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P4   | Install low flow showerheads and faucet aerators   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| M14  | Insulate DHW tanks and distribution piping         | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M15  | Replace DHW boilers with more efficient models     | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other: _____   |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Heating Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS HEATING - refers to the additional energy used in winter for heating and humidification</b> |  |                        |                          |             |          |                       |                    |
| B18  | Check and clear baseboard heaters of obstructions  | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B19  | Adjust blinds (to retain heat in winter)   | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B20  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| M17  | Optimize operating periods of ventilation systems supplying heated spaces                  | 2                      | 2                        | 4           | Year 2   | seasonal review       |                    |
| M18  | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M20  | Test and tune boiler efficiency  | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M22  | Check heating system for flow balancing and air venting                                    | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| EN1  | Check and seal exterior walls and openings   | 3                      | 2                        | 5           | Year 2   | 10 to 15              |                    |
| EN5  | Seal window and door frames  | 3                      | 2                        | 5           | Year 2   | 5                     |                    |
| M23  | Optimize fan-coil unit and entrance heater controls  | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M24  | Consider heating system zoning   | 2                      | 2                        | 4           | Year 2   | n/a                   |                    |
| M19  | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 2                        | 4           | Year 4   | 10 to 15              |                    |
| M21  | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| EN2  | Insulate the attic adequately  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| EN3  | Reclad the building's exterior   | 1                      | 2                        | 3           | Year 5   | 20 to 24              |                    |
| EN4  | Replace single-pane windows with double-pane windows                                       | 1                      | 2                        | 3           | Year 5   | 20 to 24              |                    |
| EN6  | If replacing the roof, ensure R-value at least 22  | 1                      | 2                        | 3           | Year 5   | n/a                   |                    |
| M25  | Install high efficiency burners  | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M26  | Replace boilers with more efficient models   | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M27  | Replace old rooftop units with energy efficient units                                      | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M28  | Install heat recovery or solar heating units   | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

**Table 26: Energy Saving Measures for Children’s Services Buildings**

The specific measures and implementation timeline for individual children’s services buildings will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities is \$4.20/ft<sup>2</sup> (see Appendix A). The budget allows for lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high-potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low potential buildings is set at 40 percent of the basic amount to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium, and low potential children’s services buildings are summarized in Table 6 below.

| Annual Savings Potential | Number of facilities | Average Area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | % of total savings | Payback |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|--------------------|---------|
| > \$100,000              | 0                    | -                               | 5.04   | \$ -                             | \$ -                           | 0.0%               |         |
| \$5,000 - \$100,000      | 4                    | 6,179                           | 4.20   | \$ 103,799                       | \$ 39,803                      | 82.8%              | 2.61    |
| < \$5,000                | 5                    | 7,894                           | 1.68   | \$ 66,312                        | \$ 8,242                       | 17.2%              | 8.05    |
|                          | 9                    |                                 |  | \$ 170,112                       | \$ 48,045                      |                    | 3.54    |

**Table 27: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.

- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 7 below.

|                |                                  | # | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|---|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 0 | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 4 | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 5 | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | 9 |          |                     |                             |

**Table 28: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Energy Assessment

There are 4 children’s services buildings with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 83% of the total energy savings for all 9 children’s services buildings can be found in these 4 facilities.

These 4 children’s services buildings can save an average of 46% of their total energy use. The total annual energy savings are estimated to be over \$39,800 and individual building annual savings range from approximately \$5,560 to over \$15,300. The annual GHG savings are approximately 97,500 kg.

These 4 children’s services buildings can save an average of 35% of their total electricity use (27% Electric Baseload, 55% Electric Cooling and 80% Electric Heating). The total annual electricity savings are estimated to be approximately \$29,500 and individual building annual savings range from about \$3,300 to almost \$15,000.

These 4 children’s services buildings can save an average of 55% of their total gas use (83% Gas Baseload and 14% Gas Heating). The total annual gas savings are estimated to be approximately \$10,300 and individual building annual savings range from approximately \$400 to approximately \$8,650.

These 4 facilities will undergo an Energy Assessment with highest potential children’s services buildings focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 4 children’s services buildings and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 4 children’s services buildings can be found in Electric Heating and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these children’s services buildings are eligible to receive over \$20,000 in incentives based on current incentives available from the Ontario Power Authority.

### **3.2.2 Energy Savings Checklist**

There are 5 children’s services buildings with less than \$5,000 in savings potential. Approximately 17% of the total energy savings for all 9 children’s services buildings can be found in these 5 facilities.

These 5 children’s services buildings can save an average of 23% of their total energy use. The total annual energy savings are estimated to be approximately \$8,200 and individual building annual savings range from \$0 to approximately \$4,200. The annual GHG savings are approximately 48,000 kg.

These 5 children’s services buildings can save an average of 3% of their total electricity use (2% Electric Baseload, 20% Electric Cooling and 26% Electric Heating). The total annual electricity savings are estimated to be approximately \$1,800 and individual building annual savings range from \$0 to around \$1,000.

These 5 children’s services buildings can save an average of 32% of their total gas use (45% Gas Baseload and 29% Gas Heating). The total annual gas savings are estimated to be approximately \$6,400 and individual building annual savings range from \$0 to over \$4,200.

These 5 facilities will undergo a checklist approach with highest potential children’s services buildings focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 5 children’s services buildings and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 5 children’s services buildings can be found in Gas Baseload and Gas Heating.

The energy savings checklist will be used by the Division Champion for the children’s services buildings in conjunction with the building operator and/or service contractor for each children’s services building. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### **3.3 Implementation Budget**

Table 8 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 9 facilities. The total costs to

implement the energy management and retrofit plan for children’s services buildings is estimated to be \$173,862. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                   |
|----------------------------------|-------------------|
| Building Performance Audit (BPA) | \$ -              |
| Energy Assessment                | \$ 3,000          |
| Checklist                        | \$ 750            |
| Implementation                   | \$ 170,112        |
| <b>Total</b>                     | <b>\$ 173,862</b> |

**Table 29: Total Budget - Energy Management and Retrofit Plan**

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 9 and Figure 51 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from Energy Assessments will begin in Year 1, with all 4 Energy Assessments completed by the end of Year 4. The implementation of these measures will begin in Year 2, and be completed by the end of Year 5. Identification of measures from the Checklists will begin in Year 2, with all 5 Checklists completed by the end of Year 6. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$214,091. The cumulative net cash flow becomes positive in Year 7.

The implementation plan includes the following assumptions:

- Approximately 71% of the project budget will be spent in the first 5 years, and the other 29% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 71% of medium and low potential savings facilities will be retrofitted in the first 5 years and 29% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.

- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1   | Year 2     | Year 3     | Year 4     | Year 5     | Year 6     | Year 7    | Year 8    | Year 9     | Year 10    | Totals     |
|---|----------|------------|------------|------------|------------|------------|-----------|-----------|------------|------------|------------|
| Mid Potential - Energy Assessment                                     | 1        | 1          | 1          | 1          | 0          | 0          | 0         | 0         | 0          | 0          | 4          |
| Low Potential - Checklist   | 0        | 1          | 1          | 1          | 1          | 1          | 0         | 0         | 0          | 0          | 5          |
| Assessment Costs  | \$ 750   | \$ 906     | \$ 909     | \$ 912     | \$ 166     | \$ 169     | \$ -      | \$ -      | \$ -       | \$ -       | \$ 3,812   |
| Implementation Costs  | \$ -     | \$ 26,998  | \$ 41,612  | \$ 42,445  | \$ 43,294  | \$ 14,936  | \$ 15,234 | \$ -      | \$ -       | \$ -       | \$ 184,519 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 75    | \$ 2,790   | \$ 4,252   | \$ 4,336   | \$ 4,346   | \$ 1,510   | \$ 1,523  | \$ -      | \$ -       | \$ -       | \$ 18,833  |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -     | \$ 1,350   | \$ 3,431   | \$ 5,553   | \$ 7,717   | \$ 8,464   | \$ 9,226  | \$ 9,226  | \$ 9,226   | \$ 9,226   |            |
| Annual Costs  | \$ 825   | \$ 32,045  | \$ 50,204  | \$ 53,245  | \$ 55,523  | \$ 25,079  | \$ 25,984 | \$ 9,226  | \$ 9,226   | \$ 9,226   | \$ 270,583 |
| Estimated Achieved Annual Savings                                     | \$ 4,237 | \$ 17,409  | \$ 36,071  | \$ 36,071  | \$ 50,660  | \$ 60,981  | \$ 67,210 | \$ 70,984 | \$ 74,533  | \$ 78,260  | \$ 460,346 |
| Estimated Incentives  | \$ -     | \$ 8,708   | \$ 6,869   | \$ 4,444   | \$ 3,677   | \$ 630     | \$ -      | \$ -      | \$ -       | \$ -       | \$ 24,328  |
| Annual Savings and Incentives   | \$ -     | \$ 12,945  | \$ 24,278  | \$ 40,515  | \$ 54,337  | \$ 61,611  | \$ 67,210 | \$ 70,984 | \$ 74,533  | \$ 78,260  | \$ 484,674 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       |          | -\$ 33     | -\$ 797    | -\$ 1,834  | -\$ 2,343  | -\$ 2,391  | -\$ 929   | \$ -      | \$ -       | \$ -       | -\$ 8,327  |
| Net Cash Flow incl borrowing costs                                    | -\$ 825  | -\$ 19,133 | -\$ 26,724 | -\$ 14,565 | -\$ 3,528  | \$ 34,141  | \$ 40,297 | \$ 61,758 | \$ 65,307  | \$ 69,034  | \$ 205,764 |
| Cumulative Net Cash Flow  | -\$ 825  | -\$ 19,925 | -\$ 45,851 | -\$ 58,582 | -\$ 59,767 | -\$ 23,236 | \$ 17,991 | \$ 79,749 | \$ 145,057 | \$ 214,091 |            |

Table 30: Cash Flow for 10-Year Implementation Plan




Figure 19: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above) and facilities of the same type from other municipalities. Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for children's services buildings is determined as the average kWh/day for April, May, September and October multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from June to August, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February, March, November and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-



standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

### Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

### Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>))+ Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Fire stations and associated offices and facilities
- Shelter, Support and Housing Administration
- Ambulance stations and associated offices and facilities
- Storage facilities where equipment or vehicles are maintained, repaired or stored
- Public libraries
- Long-Term Care Homes and Services
- Police stations and associated offices and facilities
- Children's Services
- Administrative offices and related facilities, including municipal council chambers

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 1.80                    | 100%       | 6.5           | 2.3                     |                                     |
| Mechanical   | 1.50                    | 30%        | 6             | 0.6                     | 0.7                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 0%         | 10            |                         | 0.2                                 |
| Process      | 0.15                    | 0%         | 5             |                         | 0.1                                 |
| <b>Total</b> | <b>4.20</b>             |            | <b>6.8</b>    | <b>3.19</b>             | <b>1.02</b>                         |

**Table 31: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process (domestic hot water) measures include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building’s existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved, and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building

- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### **Initial Energy Targets**

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available, the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.

## 5 Appendix B - Children's Services Buildings

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 9 children's services buildings included in this report and Plan.

| Building                       | Address                 | Building Area (ft <sup>2</sup> ) |
|--------------------------------|-------------------------|----------------------------------|
| Ancaster Childcare             | 45 Ancaster Rd.         | 7,018                            |
| Albion Road Childcare          | 1545 Albion Rd.         | 5,543                            |
| City Kids Childcare Centre     | 34 Bathurst St.         | 8,461                            |
| Danforth Childcare Centre      | 1125 Danforth Ave.      | 6,351                            |
| Jesse Ketchum Childcare Centre | 7 Berryman St.          | 11,550                           |
| Malvern Childcare Centre       | 1321 Neilson Rd.        | 6,501                            |
| Thomas Berry Childcare Centre  | 3495 Lakeshore Blvd. W. | 9,117                            |
| Willowridge Childcare Centre   | 30 Earldown Dr.         | 4,844                            |
| Woodbine Childcare Centre      | 1100 Woodbine Ave.      | 4,801                            |

**Table 32: Children's Services Building Information**

### 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 9 children's services buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| Building                       | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|--------------------------------|---|--|---|
| Woodbine Childcare Centre      | 13.24   | 3.80   | 17.04   |
| City Kids Childcare Centre     | 10.41   | 10.81  | 21.22   |
| Jesse Ketchum Childcare Centre | 2.91  | 23.67  | 26.57   |
| Albion Road Childcare          | 15.44   | 21.31  | 36.75   |
| Ancaster Childcare             | 20.76   | 21.31  | 42.07   |
| Malvern Childcare Centre       | 31.98   | 10.21  | 42.19   |
| Danforth Childcare Centre      | 23.08   | 21.69  | 44.76   |
| Thomas Berry Childcare Centre  | 11.66   | 33.47  | 45.14   |
| Willowridge Childcare Centre   | 19.50   | 81.33  | 100.83  |

**Table 33: Children's Services 2012 Energy Intensity**

### 5.3 Target-setting Method and Metrics

No children’s services buildings were determined to be ineligible for determination of energy components or target-setting. See Appendix A.

9 City of Toronto facilities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.

The red line on each chart indicates the top quartile for each component which is the target for that component.




Figure 20: 2012 Electric Baseload Intensity Benchmark

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for children’s services buildings ranges from 2.3 to 22.8 ekWh/ft<sup>2</sup> and the top-quartile is 11.3 ekWh/ft<sup>2</sup>.




Figure 21: 2012 Electric Cooling Intensity Benchmark

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for children’s services buildings ranges from 0.2 to 1.8 ekWh/ft<sup>2</sup> and the top-quartile is 0.53 ekWh/ft<sup>2</sup>.




Figure 22: 2012 Electric Heating Intensity Benchmark

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for children’s services buildings ranges from 0.3 to 7.9 ekWh/ft<sup>2</sup> and the top-quartile is 0.4 ekWh/ft<sup>2</sup>.





Figure 23: 2012 Gas Baseload Intensity Benchmark

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for children’s services buildings ranges from 1.8 to 74.2 ekWh/ft<sup>2</sup> and the top-quartile is 3.1 ekWh/ft<sup>2</sup>.



**Figure 24: 2012 Gas Heating Intensity Benchmark**

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for children’s services buildings ranges from 0.3 to 31.4 ekWh/ft<sup>2</sup> and the top-quartile is 7.65 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of children’s services buildings, the factors are % of the facility area served by electric heat, %of DHW heated by electricity, use of ground-source or water-source heat pumps, and % of the area served by electric air conditioning.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 4 Mid-Savings Potential Children’s Services Buildings

Buildings are sorted by total annual savings potential, starting with the highest saving potential buildings.

There are 4 children’s services buildings with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.



High savings Moderate savings Low savings

| Operation name                       | Electricity Savings Potential |         |         |       | \$/yr     | Gas Savings Potential |         |       | \$/yr     | Total Energy Savings Potential |           | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|--------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|-----------|--------------------------------|-----------|-------------|----------|--------------------------------|------------------------|
|                                      | Average %                     |         |         |       |           | Average %             |         |       |           | Avg %                          | \$/yr     | Electricity | Gas      |                                |                        |
|                                      | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |           |                                |           |             |          |                                |                        |
| Mid-potential savings facilities (4) | 27%                           | 55%     | 80%     | 35%   | \$ 29,522 | 83%                   | 14%     | 55%   | \$ 10,281 | 46%                            | \$ 39,803 | \$ 16,870   | \$ 3,954 | 24,714                         | 97,495                 |
| Malvern Childcare Centre             | 37%                           | 55%     | 91%     | 51%   | \$ 14,963 | 45%                   |         | 25%   | \$ 409    | 45%                            | \$ 15,372 | \$ 8,551    | \$ 157   | 6,501                          | 14,711                 |
| Willowridge Childcare Centre         | 22%                           | 61%     |         | 25%   | \$ 3,352  | 96%                   |         | 87%   | \$ 8,652  | 75%                            | \$ 12,004 | \$ 1,916    | \$ 3,328 | 4,844                          | 65,158                 |
| Danforth Childcare Centre            | 27%                           | 66%     | 38%     | 30%   | \$ 6,250  |                       | 21%     | 18%   | \$ 614    | 24%                            | \$ 6,864  | \$ 3,571    | \$ 236   | 6,351                          | 9,349                  |
| Ancaster Childcare                   | 17%                           | 18%     | 70%     | 24%   | \$ 4,956  | 21%                   | 15%     | 16%   | \$ 606    | 20%                            | \$ 5,563  | \$ 2,832    | \$ 233   | 7,018                          | 8,277                  |

Table 34: Savings Potential for 4 Medium Savings Potential Children’s Services Buildings

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

### Savings Potential by Energy Use Component for the 5 Low-Savings Potential Children’s Services Buildings

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 5 children’s services buildings with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                       | Electricity Savings Potential |         |         |       | \$/yr    | Gas Savings Potential |         |       | \$/yr    | Total Energy Savings Potential |          | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|--------------------------------------|-------------------------------|---------|---------|-------|----------|-----------------------|---------|-------|----------|--------------------------------|----------|-------------|----------|--------------------------------|------------------------|
|                                      | Average %                     |         |         |       |          | Average %             |         |       |          | Avg %                          | \$/yr    | Electricity | Gas      |                                |                        |
|                                      | Base-load                     | Cooling | Heating | Total |          | Base-load             | Heating | Total |          |                                |          |             |          |                                |                        |
| Low potential savings facilities (5) | 02%                           | 20%     | 26%     | 03%   | \$ 1,790 | 45%                   | 29%     | 32%   | \$ 6,453 | 23%                            | \$ 8,242 | \$ 1,023    | \$ 2,482 | 39,472                         | 48,038                 |
| Thomas Berry Childcare Centre        |                               |         |         | 0%    | \$ -     | 100%                  | 53%     | 55%   | \$ 4,228 | 41%                            | \$ 4,228 | \$ -        | \$ 1,626 | 9,117                          | 30,556                 |
| Jesse Ketchum Childcare Centre       |                               |         |         | 0%    | \$ -     | 58%                   | 9%      | 24%   | \$ 1,654 | 21%                            | \$ 1,654 | \$ -        | \$ 636   | 11,550                         | 11,956                 |
| Albion Road Childcare                |                               | 3%      | 57%     | 6%    | \$ 720   | 33%                   | 13%     | 18%   | \$ 521   | 13%                            | \$ 1,241 | \$ 411      | \$ 201   | 5,543                          | 4,334                  |
| Woodbine Childcare Centre            | 9%                            | 100%    |         | 12%   | \$ 1,070 | 12%                   |         | 11%   | \$ 49    | 12%                            | \$ 1,119 | \$ 611      | \$ 19    | 4,801                          | 1,193                  |
| City Kids Childcare Centre           |                               |         |         | 0%    | \$ -     |                       |         | 0%    | \$ -     | 0%                             | \$ -     | \$ -        | \$ -     | 8,461                          | 0                      |

Table 35: Savings Potential for 5 Low-Savings Potential Children’s Services Buildings

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as (Actual Energy Use – Target Energy Use)/Actual Energy Use and \$/year savings for each component are calculated as (Actual Energy Use – Target Energy Use) \* utility company rates \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Community Centres

---

## Table of Contents

|          |   |            |
|----------|---|------------|
| <b>1</b> | <b>Benchmarking and Conservation Potential .....</b>  | <b>79</b>  |
| 1.1      | Energy Use and Building Characteristics.....  | 79         |
| 1.1.1    | Building Characteristics.....   | 79         |
| 1.1.2    | Summary of Energy Use and Costs .....   | 79         |
| 1.2      | Energy Targets.....   | 81         |
| 1.3      | Savings Potential.....  | 82         |
| <b>2</b> | <b>Conservation Measures and Budget.....</b>  | <b>84</b>  |
| 2.1      | Previous Energy Efficiency Initiatives.....   | 84         |
| 2.2      | Proposed Energy Efficiency Measures .....   | 84         |
| <b>3</b> | <b>Energy Management and Retrofit Plan .....</b>  | <b>91</b>  |
| 3.1      | Implementation Costs and Modeled Savings .....  | 91         |
| 3.2      | Implementation Process and Tools – Determining the Specific Measures for Each Building .... | 91         |
| 3.2.1    | Building Performance Audit.....   | 92         |
| 3.2.2    | Energy Assessment .....   | 93         |
| 3.2.3    | Energy Savings Checklist .....  | 93         |
| 3.3      | Implementation Budget.....  | 94         |
| 3.4      | 10-Year Implementation Plan .....   | 94         |
| <b>4</b> | <b>Appendix A.....</b>  | <b>97</b>  |
| 4.1      | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....       | 97         |
| 4.2      | Determining Energy Use Components.....  | 97         |
| 4.3      | Determining Targets .....   | 97         |
| 4.4      | Calculating Potential Savings .....   | 99         |
| 4.5      | Implementation Costs by Measure Type and Modeled Savings.....                               | 99         |
| 4.6      | Assessment Tools.....   | 100        |
| <b>5</b> | <b>Appendix B - Community Centres.....</b>  | <b>102</b> |
| 5.1      | Buildings and Building Characteristics .....  | 102        |
| 5.2      | Energy Use Intensities.....   | 104        |
| 5.3      | Target-setting Method and Metrics.....  | 106        |
| 5.4      | Savings Potential by Energy Use Component .....   | 109        |

## List of Tables

|   |     |
|---|-----|
| Table 36 : Current Renewable Energy Systems on Community Centres .....                  | 79  |
| Table 37: 2012 Energy Use and Costs for 69 City of Toronto Community Centres .....      | 80  |
| Table 38: Top Quartile Targets.....   | 82  |
| Table 39: Savings Potential Summary .....   | 83  |
| Table 40: Savings Potential Based on Energy Use Component for 69 Community Centres..... | 83  |
| Table 41: 2006 Community Centre Project Estimated Project Costs and Savings.....        | 84  |
| Table 39: Energy Saving Measures for Community Centres.....                             | 89  |
| Table 43 : Future Proposed Renewable Energy Systems on Community Centres.....           | 90  |
| Table 44: Estimated Implementation Costs and Modeled Savings .....                      | 91  |
| Table 45: Assessment Tools Used to Determine Specific Energy-saving Measures .....      | 92  |
| Table 46: Total Budget - Energy Management and Retrofit Plan .....                      | 94  |
| Table 47: Cash Flow for 10-Year Implementation Plan .....                               | 95  |
| Table 48: Implementation Costs by Measure Type .....                                    | 99  |
| Table 49: Community Centre Building Information.....                                    | 103 |
| Table 50: Community Centre 2012 Energy Intensity .....                                  | 105 |
| Table 51: Excluded Facilities .....   | 106 |
| Table 52: Savings Potential for 9 High Savings Potential Community Centres.....         | 109 |
| Table 53: Savings Potential for 41 Medium Savings Potential Community Centres .....     | 111 |

## List of Figures

|  |     |
|--|-----|
| Figure 25: 2012 Energy Use and Cost Breakdown for 69 City of Toronto Community Centres ..... | 80  |
| Figure 26: 2012 Total Energy Intensity Benchmark .....                                       | 80  |
| Figure 27: 2012 Total Electricity Intensity Benchmark .....                                  | 81  |
| Figure 28: 2012 Total Gas Intensity Benchmark .....  | 81  |
| Figure 29: Cash Flow for 10-Year Implementation Plan .....                                   | 96  |
| Figure 30: 2012 Electric Baseload Intensity Benchmark.....                                   | 106 |
| Figure 31: 2012 Electric Cooling Intensity Benchmark .....                                   | 107 |
| Figure 32: 2012 Electric Heating Intensity Benchmark.....                                    | 107 |
| Figure 33: 2012 Gas Baseload Intensity Benchmark.....  | 108 |
| Figure 34: 2012 Gas Heating Intensity Benchmark.....   | 108 |

## 1 Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 69 community centres in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B.

The total area for all of the buildings is 2,000,971 ft<sup>2</sup>. Community centres range in size from approximately 1,400 ft<sup>2</sup> to over 250,000 ft<sup>2</sup>.

The facilities equipped with a renewable energy system are as follows:

| Building Name                   | Building Address    | Renewable Installation | System Size | Unit |
|---------------------------------|---------------------|------------------------|-------------|------|
| Albion Community Centre         | 1485 Albion Rd      | Solar Pool Heating     | 67          | KW   |
| Armour Heights Community Centre | 2140 Avenue Rd      | Solar Air              | 120         | KW   |
| Birchmount RC (Solar Utility)   | 93 Birchmount Rd    | Solar Hot Water        | 245         | KW   |
| Grandravine CC                  | 23 Grandravine Dr   | Solar Photovoltaic     | 100         | kW   |
| McGregor Arena                  | 2231 Lawrence Ave E | Solar Photovoltaic     | 75          | kW   |
| Scadding Court Community Centre | 707 Dundas St W     | Solar Air              | 115         | kW   |

**Table 36 : Current Renewable Energy Systems on Community Centres**

The facilities range from 0% to 100% air-conditioned. No facilities are fully served by electric heat and there are a number of other facilities using between 5 and 30% electric heat. Only one facility (Forest Hill CC) is served by a water source heat pump. There are food services at a number of facilities, ranging from 1 to 10% of building served.

The community centres fall into four types:

- Facilities with indoor ice rinks only
- Facilities with indoor pools only
- Facilities with both indoor rinks and indoor pools
- Facilities without indoor rinks or indoor pools

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of

electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 69 buildings are summarized below.

|                               | 2012 Energy Use |                    |
|-------------------------------|-----------------|--------------------|
|                               | Unit            | \$                 |
| Electricity (kWh)             | 31,387,377      | \$4,394,233        |
| Natural Gas (m <sup>3</sup> ) | 3,349,628       | \$870,903          |
| <b>Total</b>                  |                 | <b>\$5,265,136</b> |

Table 37: 2012 Energy Use and Costs for 69 City of Toronto Community Centres




Figure 25: 2012 Energy Use and Cost Breakdown for 69 City of Toronto Community Centres

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 69 buildings. Total energy use ranges from approximately 4.3 to 94.8 ekWh/ft<sup>2</sup>. There are also wide ranges for electricity and gas use per ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 26: 2012 Total Energy Intensity Benchmark




Figure 27: 2012 Total Electricity Intensity Benchmark




Figure 28: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for community centres are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each community centre to achieve its target over the duration of the ECDM Plan.

| Energy type         | Component    | Value       | Unit                            |
|---------------------|--------------|-------------|---------------------------------|
| Electricity         | Base         | 9.2         | kWh/ft <sup>2</sup> /year       |
|                     | Cooling      | 0.8         | kWh/ft <sup>2</sup> /year       |
|                     | Heating      | 1.8         | kWh/ft <sup>2</sup> /year       |
|                     | <b>Total</b> | <b>11.8</b> | <b>kWh/ft<sup>2</sup>/year</b>  |
| Gas                 | Base         | 1.8         | ekWh/ft <sup>2</sup> /year      |
|                     | Heating      | 9.7         | ekWh/ft <sup>2</sup> /year      |
|                     | <b>Total</b> | <b>11.5</b> | <b>ekWh/ft<sup>2</sup>/year</b> |
| <b>Total energy</b> | <b>Total</b> | <b>23.3</b> | <b>ekWh/ft<sup>2</sup>/year</b> |

**Table 38: Top Quartile Targets**

The data set for target-setting is made up of 87 community centres and indoor recreational facilities with complete and reliable data, all of which are City of Toronto facilities. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), % of the area which is air conditioned and % of the area served by food services. The targets for facilities with indoor rinks are adjusted for size of the ice surface and time period that the ice is in. The targets for facilities with indoor pools are adjusted for the size of the pool. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each community centre. The total savings potential for each community centre is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 69 community centres are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are 9 community centres with annual savings potential greater than \$100,000. 41 community centres have annual savings potential between \$5,000 and \$100,000, and 19 community centres have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 69 buildings is \$2,369,391 (\$1,955,930 for electricity and \$413,462 for gas) with an average total energy savings of 46%.

For the 9 high-potential savings facilities, the total annual savings potential is \$1,181,804 (\$1,025,079 for electricity and \$156,725 for gas) with an average total energy savings of 61%.



For the 41 mid-potential savings facilities, the total annual savings potential is \$1,151,047 (\$914,751 for electricity and \$236,296 for gas) with an average total energy savings of 45%.

For the 19 low-potential savings facilities, the total annual savings potential is \$36,541 (\$16,100 for electricity and \$20,441 for gas) with an average total energy savings of 11%.

| Operation name                        | Electricity Savings Potential |            |            |            | Gas Savings Potential |            |            |            | Total Energy Savings Potential |            | Incentives         |                    | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |                  |
|---------------------------------------|-------------------------------|------------|------------|------------|-----------------------|------------|------------|------------|--------------------------------|------------|--------------------|--------------------|--------------------------------|------------------------|------------------|
|                                       | Average %                     |            |            |            | \$/yr                 | Average %  |            |            | \$/yr                          | Avg %      | \$/yr              | Electricity        |                                |                        | Gas              |
|                                       | Base-load                     | Cooling    | Heating    | Total      |                       | Base-load  | Heating    | Total      |                                |            |                    |                    |                                |                        |                  |
| <b>TOTAL: 69 facilities</b>           | <b>44%</b>                    | <b>74%</b> | <b>40%</b> | <b>45%</b> | <b>\$1,955,930</b>    | <b>70%</b> | <b>40%</b> | <b>47%</b> | <b>\$413,462</b>               | <b>46%</b> | <b>\$2,369,391</b> | <b>\$1,117,674</b> | <b>\$159,024</b>               | <b>2,000,971</b>       | <b>4,524,858</b> |
| High potential savings facilities (9) | 64%                           | 100%       | 13%        | 65%        | \$1,025,079           | 77%        | 49%        | 58%        | \$156,725                      | 61%        | \$1,181,804        | \$ 585,759         | \$ 60,279                      | 420,191                | 1,938,059        |
| Mid-potential savings facilities (41) | 37%                           | 77%        | 47%        | 40%        | \$ 914,751            | 69%        | 42%        | 49%        | \$236,296                      | 45%        | \$1,151,047        | \$ 522,715         | \$ 90,883                      | 1,166,121              | 2,426,424        |
| Low potential savings facilities (19) | 02%                           | 17%        | 06%        | 03%        | \$ 16,100             | 36%        | 12%        | 18%        | \$ 20,441                      | 11%        | \$ 36,541          | \$ 9,200           | \$ 7,862                       | 414,659                | 160,374          |

**Table 39: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 69 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 14.4        | 8.1         | 44%                 | \$ 1,723,201         |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 1.1         | 0.3         | 74%                 | \$ 168,249           |
| Electric Heating (kWh/ft <sup>2</sup> )   | 1.1         | 0.7         | 40%                 | \$ 64,480            |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 9.1         | 9.1         | 0%                  | \$ -                 |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 4.5         | 1.3         | 70%                 | \$ 148,868           |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 13.1        | 7.8         | 40%                 | \$ 260,114           |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 13.0        | 8.6         | 34%                 | \$ 4,479             |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>33.0</b> | <b>17.8</b> | <b>46%</b>          | <b>\$ 2,369,391</b>  |

High savings
Moderate savings
Low savings

**Table 40: Savings Potential Based on Energy Use Component for 69 Community Centres**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2006, the City of Toronto undertook a study to identify improvement measures that would improve energy efficiency and reduce the operating cost and environmental impact of community centers located throughout the City of Toronto.

Table 5 below summarizes the estimated overall project costs, savings and estimated energy reduction for 51 community centers as a result of the 2006 project.

| Project Name & Year   | Num. of Bldgs | Total Floor Area (m2) | Project Cost & Annual Savings (estimated) |                 |                    |                            |         | Estimated Energy Reduction |                        |                        |                  |
|-----------------------|---------------|-----------------------|---|-----------------|--------------------|----------------------------|---------|----------------------------|------------------------|------------------------|------------------|
|                       |               |                       | Retrofit Cost                             | Total \$Savings | Total ekWh Savings | Total CO2 Savings (tonnes) | Payback | Electricity Savings kWh    | Electricity Savings kW | Natural Gas Savings m3 | Water Savings m3 |
| Community Center 2006 | 51            | 128,494               | \$6,021,021                               | \$750,000       | 13,334,358         | 2,664                      | 8.0     | 1,536,340                  | 223                    | 1,140,820              | 0                |

**Table 41: 2006 Community Centre Project Estimated Project Costs and Savings**

### 2.2 Proposed Energy Efficiency Measures

Table 6 below shows the full range of possible energy efficiency measures for the entire portfolio of community centres. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 69 facilities indicate that the largest percentage reductions will come from measures associated with electric cooling and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of ‘Energy Savings Potential’ and ‘Ease of Implementation’. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%

1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

4 – Measure can be done immediately by building occupants or service contractors (little/no cost)

3 – Measure involves testing, tuning, measuring (low cost)

2 – Measure involves significant investigation/optimization (more significant costs)

1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).

| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off/unplug machines, office and kitchen equipment, chargers when not needed                 | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B2   | Enable ENERGY STAR power settings, turn off computers when not in use                            | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off lights when areas not in use  | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B4   | Make use of natural light instead of turning on lights where possible                            | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| P1   | Upgrade control of under-pad heating   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P3   | Upgrade/adjust ice temperature control   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P6   | Repair low-emissivity ceiling  | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P10  | Install compressor head pressure control   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P2   | Lower water use for ice resurfacing  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P4   | Implement ice temperature reset based on types of use  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P5   | Reduce ice thickness   | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P7   | Reduce brine pump operation  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 4                        | 7           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 4                        | 7           | Year 2   | Seasonal Review       |                    |
| P8   | Reduce rink lighting operation   | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 4                        | 7           | Year 2   | 15+                   |                    |
| P11  | Insulate brine headers   | 3                      | 4                        | 7           | Year 2   | 5 to 10               |                    |
| P9   | Install/make better use of multi-level rink lighting control                                     | 2                      | 4                        | 6           | Year 3   | Seasonal Review       |                    |
| L1   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L2   | Install motion sensors in washrooms/occasional use spaces to shut                                | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L3   | Install photo-sensors and/or a timer on outdoor and daylight interior area lighting              | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L4   | Replace HID lighting with high efficiency fluorescent  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L5   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L6   | Replace festive lighting with LED  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L7   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 4                        | 5           | Year 4   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 4                        | 5           | Year 4   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 4                        | 5           | Year 4   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| EN1  | Install low-emissivity ceiling   | 1                      | 4                        | 5           | Year 4   | 10 to 12              |                    |
| M3   | Replace/right-size pumps   | 1                      | 4                        | 5           | Year 4   | 10 to 20              |                    |
| M4   | Install variable speed drive on brine pump   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M5   | Install multi-pass refrigerant pipe configuration  | 1                      | 4                        | 5           | Year 4   | 20 to 30              |                    |
| M6   | Install de-ionized water system  | 1                      | 4                        | 5           | Year 4   | 5 to 10               |                    |
| M7   | Replace ice resurfer with high efficiency unit   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M8   | Replace ice plant with high efficiency unit  | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M9   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 4                        | 5           | Year 4   | 10 to 20              |                    |
| M10  | Convert electric hot water heaters to natural gas  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
Operational Measures  
Retrofit/Capital Measures

| Electric Heating Measures |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility |
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|

**ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes**

|     |  |   |   |   |        |                 |                    |
|-----|--|---|---|---|--------|-----------------|--------------------|
| B5  | Adjust blinds (to retain heat in winter)   | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B6  | Avoid use of electric heaters  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B7  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| M11 | Control fan coil and entrance heaters to optimize run-times                                | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M12 | Evaluate conversion from electric heating to natural gas                                   | 2 | 4 | 6 | Year 2 | n/a             |                    |
| M13 | Convert electric to gas dehumidifiers  | 1 | 4 | 5 | Year 2 | 15 to 20        |                    |
| P12 | Control car plug-in outlets  | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M14 | Install snow sensors to control the snow-melting system                                    | 1 | 4 | 5 | Year 4 | seasonal review |                    |
| M15 | Upgrade base building heating system to avoid use of electric heaters                      | 1 | 4 | 5 | Year 4 | seasonal review |                    |
| M16 | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1 | 4 | 5 | Year 4 | seasonal review |                    |
|     | Other: _____   |   |   |   |        |                 |                    |
|     | _____  |   |   |   |        |                 |                    |
|     | _____  |   |   |   |        |                 |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Electric Cooling Measures |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility |
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|

**ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes**

|     |  |   |   |   |        |                 |                    |
|-----|--|---|---|---|--------|-----------------|--------------------|
| B8  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B9  | Only cool rooms that are being used  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B10 | Install and use energy efficient ceiling fans  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B11 | Close blinds (to shade space from direct sunlight)   | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B12 | Install window film, solar screens or awnings on south and west facing windows               | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| P13 | Upgrade/adjust dehumidifier controls   | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M18 | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M19 | Test and tune the air conditioning units   | 3 | 4 | 7 | Year 2 | 3               |                    |
| M17 | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2 | 4 | 6 | Year 2 | seasonal review |                    |
| M20 | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1 | 4 | 5 | Year 4 | 10 to 15        |                    |
|     | Other: _____   |   |   |   |        |                 |                    |
|     | _____  |   |   |   |        |                 |                    |
|     | _____  |   |   |   |        |                 |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Baseload Measures   |   | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|---|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round |   |                        |                          |             |          |                       |                    |
| B13   | Optimize dishwasher operation (only run when full)          | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| P16   | Identify and repair hot water leaks                         | 4                      | 4                        | 8           | Year 1   | annual review         |                    |
| P15   | Test and tune DHW boiler efficiency                         | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M21   | Investigate and repair possible gas leaks                   | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P19   | Optimize pool water temperature control, reset based on use | 4                      | 4                        | 8           | Year 2   | seasonal review       |                    |
| P14   | Optimize DHW temperature control                            | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| M22   | Insulate DHW tanks and distribution piping                  | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| P17   | Implement DHW circulation pump control                      | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P18   | Install low flow showerheads and faucet aerators            | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M23   | Install ice plant heat recovery                             | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M24   | Install solar hot water heating                             | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M25   | Install heat recovery dehumidification system               | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M26   | Replace DHW boilers with more efficient models              | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| Other:  |   |                        |                          |             |          |                       |                    |
|   |   |                        |                          |             |          |                       |                    |
|   |   |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

| Gas Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS HEATING - refers to the additional energy used in winter for heating and humidification |  |                        |                          |             |          |                       |                    |
| B14   | Check and clear baseboard heaters of obstructions  | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B15   | Adjust blinds (to retain heat in winter)   | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B16   | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| P21   | Isolate idle boilers   | 4                      | 4                        | 8           | Year 1   | seasonal review       |                    |
| P22   | Reduce circulating pump operation in mild weather  | 4                      | 4                        | 8           | Year 1   | seasonal review       |                    |
| M27   | Optimize operating periods of ventilation systems  | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M28   | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M29   | Test and tune boiler efficiency  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M30   | Check heating system for flow balancing and air venting                                    | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| EN2   | Check and seal exterior walls and openings   | 3                      | 4                        | 7           | Year 2   | 10 to 15              |                    |
| EN3   | Seal window and door frames  | 3                      | 4                        | 7           | Year 2   | 5                     |                    |
| EN4   | Insulate and seal dividing walls between arena and heated areas                            | 3                      | 4                        | 7           | Year 2   | 5                     |                    |
| M29   | Optimize fan-coil unit and entrance heater controls  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| P20   | Control loading dock heating   | 4                      | 4                        | 8           | Year 2   | annual review         |                    |
| M32   | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M31   | Replace spectator heating system with radiant heat   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M33   | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| EN5   | Replace single-pane windows with double-pane windows                                       | 1                      | 4                        | 5           | Year 4   | 20 to 25              |                    |
| EN6   | If replacing the roof, ensure R-value at least 22  | 1                      | 4                        | 5           | Year 4   | n/a                   |                    |
| M34   | Install high efficiency burners  | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M35   | Replace boilers with more efficient models   | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M36   | Replace old rooftop units with energy efficient units                                      | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M37   | Install heat recovery or solar heating units   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| Other:  |  |                        |                          |             |          |                       |                    |
|   |  |                        |                          |             |          |                       |                    |
|   |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

**Table 42: Energy Saving Measures for Community Centres**

The specific measures and implementation timeline for each individual community centre will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

**Proposed / Future Renewable Energy Installations**

| <b>Building Name</b>                 | <b>Building Address</b> | <b>Renewable Installation</b> | <b>System Size</b> | <b>Unit</b> |
|--------------------------------------|-------------------------|-------------------------------|--------------------|-------------|
| Birchmount Community Centre          | 101 Ridgetop Rd         | Solar PV                      | 10                 | kW          |
| Commander Park Community Centre      | 140 Commander Blvd      | Solar PV                      | 248                | kW          |
| Cummer Community Centre              | 6000 Leslie St          | Solar PV                      | 100                | kW          |
| Forest Hill Library Community Centre | 700 Eglinton Ave W      | Solar PV                      | 75                 | kW          |
| Heron Park Community Centre          | 292 Manse Rd            | Solar PV                      | 187                | kW          |
| Scadding Court Community Centre      | 707 Dundas St W         | Geothermal                    | 42                 | kW          |

**Table 43 : Future Proposed Renewable Energy Systems on Community Centres**



### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities, is \$9.38/ft<sup>2</sup> (see Appendix A). The budget allows for lighting audits, lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low potential buildings is set \$0.75 to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium and low potential community centres are summarized in Table 7 below.

| Annual Savings Potential | Number of facilities | Average Area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | % of total savings | Payback     |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|--------------------|-------------|
| > \$100,000              | 9                    | 46,688                          | 11.25  | \$ 4,727,152                     | \$ 1,181,804                   | 49.9%              | 4.00        |
| \$5,000 - \$100,000      | 41                   | 28,442                          | 9.38   | \$ 10,932,388                    | \$ 1,151,047                   | 48.6%              | 9.50        |
| < \$5,000                | 19                   | 21,824                          | 0.75   | \$ 310,994                       | \$ 36,541                      | 1.5%               | 8.51        |
|                          | <b>69</b>            |                                 |  | <b>\$ 15,970,534</b>             | <b>\$ 2,369,391</b>            |                    | <b>6.74</b> |

**Table 44: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.

- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 8 below.

|                |                                  | #         | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|-----------|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 9         | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 41        | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 19        | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | <b>69</b> |          |                     |                             |

**Table 45: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Building Performance Audit

There are 9 community centres with over \$100,000 in annual energy saving potential. Approximately 50% of the total energy savings for all 69 community centres can be found at these 9 facilities.

These 9 community centres can save an average of 61% of their total energy use. The total annual energy savings are estimated to be over \$1,181,800 and individual building annual savings range from approximately \$104,100 to over \$172,900. The annual GHG savings are estimated to be approximately 1,938,000 kg.

These 9 community centres can save an average of 65% of their total electricity use (64% Electric Baseload, 100% Electric Cooling and 13% Electric Heating). The total annual electricity savings are estimated to be approximately \$1,025,079 and individual building annual savings range from almost \$78,000 to over \$145,000.

These 9 community centres can save an average of 58% of their total gas use (77% Gas Baseload and 49% Gas Heating). The total annual gas savings are estimated to be approximately \$156,700 and individual building annual savings range from \$0 to over \$43,000.

These 9 community centres will undergo Building Performance Audits (see the Implementation Plan for further details). For a complete description of the Building Performance Audit, refer to Appendix A.

See Appendix B for the associated energy savings potential by energy use component.

The highest percentage reductions for these facilities can be found in Gas Baseload and Electric Cooling. After the implementation of the proposed measures, these facilities are eligible to receive over \$646,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Assessment

There are 41 community centres with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 49% of the total energy savings for all 69 community centres can be found in these 41 facilities.

These 41 community centres can save an average of 45% of their total energy use. The total annual energy savings are estimated to be over \$1,151,000 and individual building annual savings range from approximately \$6,500 to almost \$80,000. The annual GHG savings are approximately 2,426,400 kg.

These 41 community centres can save an average of 40% of their total electricity use (37% Electric Baseload, 77% Electric Cooling and 47% Electric Heating). The total annual electricity savings are estimated to be approximately \$914,750 and individual building annual savings range from \$0 to over \$79,000.

These 41 community centres can save an average of 49% of their total gas use (69% Gas Baseload and 42% Gas Heating). The total annual gas savings are estimated to be approximately \$236,300 and individual building annual savings range from \$0 to over \$25,000.

These 41 facilities will undergo an Energy Assessment with highest potential community centres focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 41 community centres and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 41 community centres can be found in Electric Cooling and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these community centres are eligible to receive over \$613,500 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.3 Energy Savings Checklist

There are 19 community centres with less than \$5,000 in savings potential. Approximately 1.5% of the total energy savings for all 69 community centres can be found in these 19 facilities.

These 19 community centres can save an average of 11% of their total energy use. The total annual energy savings are estimated to be approximately \$36,540 and individual building annual savings range from \$0 to over \$4,980. The annual GHG savings are approximately 160,370 kg.

These 19 community centres can save an average of 3% of their total electricity use (2% Electric Baseload, 17% Electric Cooling and 6% Electric Heating). The total annual electricity savings are estimated to be approximately \$16,100 and individual building annual savings range from \$0 to almost \$4,000.

These 19 community centres can save an average of 18% of their total gas use (36% Gas Baseload and 12% Gas Heating). The total annual gas savings are estimated to be approximately \$20,440 and individual building annual savings range from \$0 to over \$4,900.

These 19 facilities will undergo a checklist approach with highest potential community centres focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 19 community centres and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 19 community centres can be found in Electric Cooling and Gas Baseload.

The energy savings checklist will be used by the Division Champion for the community centres in conjunction with the building operator and/or service contractor for each community centre. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### 3.3 Implementation Budget

Table 9 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 69 facilities. The total costs to implement the energy management and retrofit plan for community centres are estimated to be \$16,071,634. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                      |
|----------------------------------|----------------------|
| Building Performance Audit (BPA) | \$ 67,500            |
| Energy Assessment                | \$ 30,750            |
| Checklist                        | \$ 2,850             |
| Implementation                   | \$ 15,970,534        |
| <b>Total</b>                     | <b>\$ 16,071,634</b> |

Table 46: Total Budget - Energy Management and Retrofit Plan

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 10 and Figure 5 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from the Building Performance Audits will occur in Year 1, with all 9 Building Performance Audits completed by the end of Year 3. The implementation of these measures will begin in Year 2 and will be completed by the end of Year 4. Identification of measures from Energy

Assessments will begin in Year 1, with all 41 Energy Assessments completed by the end of Year 5. The implementation of these measures will begin in Year 2, and will be completed by the end of Year 6. Identification of measures from the Checklists will begin in Year 2, with all 20 Checklists completed by the end of Year 5. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$-583,239. The cumulative net cash flow becomes positive in Year 11.

The implementation plan includes the following assumptions:

- Approximately 76% of the project budget will be spent in the first 5 years, and the other 24% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 76% of facilities will be retrofitted in the first 5 years and 24% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.
- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1     | Year 2        | Year 3          | Year 4          | Year 5          | Year 6          | Year 7          | Year 8          | Year 9          | Year 10         | Totals        |
|---|------------|---------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|---------------|
| High Potential - Building Performance Audit                           | 3          | 3             | 3               | 0               | 0               | 0               | 0               | 0               | 0               | 0               | 9             |
| Mid Potential - Energy Assessment                                     | 9          | 9             | 9               | 9               | 5               | 0               | 0               | 0               | 0               | 0               | 41            |
| Low Potential - Checklist   | 0          | 5             | 5               | 5               | 4               | 0               | 0               | 0               | 0               | 0               | 19            |
| Assessment Costs  | \$ 29,250  | \$ 30,030     | \$ 30,046       | \$ 7,562        | \$ 4,412        | \$ -            | \$ -            | \$ -            | \$ -            | \$ -            | \$ 101,300    |
| Implementation Costs  | \$ -       | \$ 4,136,120  | \$ 4,305,693    | \$ 4,391,807    | \$ 2,739,923    | \$ 1,575,153    | \$ -            | \$ -            | \$ -            | \$ -            | \$ 17,148,696 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 2,925   | \$ 416,615    | \$ 433,574      | \$ 439,937      | \$ 274,434      | \$ 157,515      | \$ -            | \$ -            | \$ -            | \$ -            | \$ 1,725,000  |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -       | \$ 206,806    | \$ 422,091      | \$ 641,681      | \$ 778,677      | \$ 857,435      | \$ 857,435      | \$ 857,435      | \$ 857,435      | \$ 857,434.79   |               |
| Annual Costs  | \$ 32,175  | \$ 4,789,572  | \$ 5,191,403    | \$ 5,480,986    | \$ 3,797,447    | \$ 2,590,103    | \$ 857,435      | \$ 857,435      | \$ 857,435      | \$ 857,435      | \$ 25,311,425 |
| Estimated Achieved Annual Savings                                     |            | \$ 269,234.47 | \$ 1,015,501.55 | \$ 1,999,469.15 | \$ 2,697,601.16 | \$ 3,098,523.53 | \$ 3,321,147.83 | \$ 3,500,670.27 | \$ 3,675,703.78 | \$ 3,859,488.97 | \$ 23,437,341 |
| Estimated Incentives  | \$ -       | \$ 531,790    | \$ 378,847      | \$ 288,737      | \$ 57,541       | \$ 19,783       | \$ -            | \$ -            | \$ -            | \$ -            | \$ 1,276,698  |
| Annual Savings and Incentives   | \$ -       | \$ 801,025    | \$ 1,394,348    | \$ 2,288,206    | \$ 2,755,142    | \$ 3,118,307    | \$ 3,321,148    | \$ 3,500,670    | \$ 3,675,704    | \$ 3,859,489    | \$ 24,714,039 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       |            | -\$ 1,287     | -\$ 160,829     | -\$ 312,711     | -\$ 440,422     | -\$ 482,114     | -\$ 460,986     | -\$ 362,438     | -\$ 256,708     | -\$ 143,978     | -\$ 2,621,474 |
| Net Cash Flow incl borrowing costs                                    | -\$ 32,175 | -\$ 3,989,834 | -\$ 3,957,884   | -\$ 3,505,491   | -\$ 1,482,727   | -\$ 46,090      | \$ 2,002,727    | \$ 2,280,798    | \$ 2,561,561    | \$ 2,858,077    | -\$ 3,218,860 |
| Cumulative Net Cash Flow  | -\$ 32,175 | -\$ 4,020,722 | -\$ 7,817,777   | -\$ 11,010,558  | -\$ 12,052,862  | -\$ 11,524,658  | -\$ 9,060,945   | -\$ 6,417,709   | -\$ 3,599,440   | -\$ 597,386     |               |

Table 47: Cash Flow for 10-Year Implementation Plan




Figure 29: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above). Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for community centres is determined as the average kWh/day for March, April, October and November multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from May to September, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

## Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

### Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Community Centres:

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>



Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Indoor swimming pools
- Indoor sports arenas
- Community centres
- Recreational facilities

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 2.25                    | 100%       | 6.5           | 2.9                     |                                     |
| Mechanical   | 1.88                    | 30%        | 6             | 0.8                     | 0.9                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 100%       | 10            |                         | 0.0                                 |
| Process      | 4.5                     | 30%        | 5             |                         | 2.5                                 |
| <b>Total</b> | <b>9.38</b>             |            | <b>5.9</b>    | <b>3.93</b>             | <b>3.40</b>                         |

**Table 48: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls. They also include lighting audits.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process measures (for facilities with rinks or pools) include cost effective retrofits to the pool circulation pump, dehumidification, heat recovery, retrofits to ice plant and related equipment and controls (if applicable). Costs for process measures (for facilities without rinks or pools) include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building's existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building
- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### Initial Energy Targets

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and

low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available, the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.

## 5 Appendix B - Community Centres

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 69 community centre buildings included in this report and Plan.

| <b>Building</b>                         | <b>Address</b>       | <b>Building Area (ft<sup>2</sup>)</b> |
|---|----------------------|---------------------------------------|
| 519 Church St Community Centre          | 519 Church St        | 15,554                                |
| Albion Community Centre & Pool (indoor) | 1485 Albion Rd       | 20,688                                |
| Amesbury Community Center               | 1507 Lawrence Ave W  | 37,975                                |
| Armour Height C.C                       | 2140 Avenue Rd       | 19,773                                |
| Banbury C.C.                            | 120 Banbury Rd       | 9,537                                 |
| Berner Trail C.C                        | 120 Berner Trail     | 10,204                                |
| Birchmount C.C                          | 93 Birchmount Rd     | 46,167                                |
| Birkdale C.C                            | 1299 Ellesmere Rd    | 11,733                                |
| Burrows Hall Community Complex          | 1081 Progress Ave    | 252,952                               |
| Cecil Community Centre                  | 58 Cecil St          | 5,769                                 |
| Cedar Brook C.C                         | 91 Eastpark Blvd     | 14,951                                |
| Cedar Ridge C.C                         | 225 Confederation Dr | 13,110                                |
| Chapley C.C / Wilmington Park           | 205 Wilmington Ave   | 6,997                                 |
| Commander Park C.C                      | 140 Commander Blvd   | 56,317                                |
| Community Centre 55                     | 97 Main St           | 8,999                                 |
| Curran Hall C.C                         | 277 Orton Park Rd    | 2,508                                 |
| Davenport C.C                           | 1347 Davenport Rd    | 2,282                                 |
| David Appleton Community Centre         | 33A Pritchard Ave    | 2,906                                 |
| Driftwood C.C                           | 4401 Jane St         | 25,015                                |
| Earl Bales C.C & Senior                 | 4169 Bathurst St     | 31,953                                |
| East Scar Boys/Girls Club               | 100 Galloway Rd      | 13,972                                |
| East York Community Centre              | 1081A Pape Ave       | 31,000                                |
| Eastview Neighbourhood Community Centre | 86 Blake St          | 25,510                                |
| Edithvale C.C                           | 7 Edithvale Dr       | 24,725                                |
| Ellesmere C.C                           | 20 Canadian Rd       | 24,402                                |
| Elmbank Community Centre                | 10 Rampart Rd        | 14,725                                |
| Fairbanks Community Centre              | 2213 Dufferin St     | 19,364                                |
| Falstaff C.C                            | 50 Falstaff Ave      | 13,853                                |
| Flemingdon C.C                          | 150 Grenoble Dr      | 10,000                                |
| Forest Hill C.C                         | 666 Eglinton Ave W   | 32,841                                |
| Franklin Horner                         | 432 Horner Ave       | 39,500                                |
| Glenlong C.C & A.I.R                    | 35 Glen Long Ave     | 10,236                                |
| Harbourfront Community Centre           | 627 Queens Quay West | 123,214                               |

|                                  |                         |        |
|----------------------------------|-------------------------|--------|
| Harwood Hall Community Centre    | 85 Cayuga Ave           | 4,306  |
| Heron Park C.C                   | 4285 Lawrence Ave E     | 52,377 |
| Humber Sheppard Community Centre | 3100 Weston Rd          | 57,867 |
| Jenner Jean-Marie C.C.           | 48 Thorncliffe Park Dr  | 13,207 |
| L'Amoreaux Tennis Club           | 200 Silver Springs Blvd | 31,474 |
| Lamp Senior Centre               | 185 Fifth St            | 26,318 |
| Lawrence Heights C.C.            | 9 Replin Rd             | 22,152 |
| Ledbury Community Center         | 160 Ledbury St          | 5,780  |
| Leslie Grove Park                | 1158 Queen St E         | 1,389  |
| Main Square Community Centre     | 245 Main St             | 35,123 |
| Masaryk-Cowan C.R.C              | 220-224 Cowan Av        | 32,270 |
| McGregor Park C.C                | 2231 Lawrence Ave E     | 45,262 |
| Metro Track And Field            | 4700 Keele St.          | 96,338 |
| Mid-Scarborough C.C              | 2467 Eglinton Ave E     | 89,125 |
| Mount Dennis Community Centre    | 4 Hollis St             | 3,003  |
| Northwood C.C                    | 15 Clubhouse Crt        | 36,167 |
| North York Memorial Hall         | 5120 Yonge              | 10,473 |
| Oakdale Community Center         | 350 Grandravine Dr      | 10,000 |
| Oakridge C.C                     | 63 Pharmacy Ave         | 18,600 |
| O'Connor C.C                     | 1386 Victoria Park Ave  | 16,253 |
| Ourland Community Centre         | 18 Ourland Ave          | 9,451  |
| Port Union C.C                   | 5450 Lawrence Ave E     | 19,978 |
| Ralph Thornton Community Centre  | 765 Queen St E          | 17,061 |
| Scadding Court Community Centre  | 707 Dundas St W         | 46,694 |
| Scarborough Village C.C          | 3600 Kingston Rd        | 58,125 |
| Sir Adam Beck                    | 525 Horner Ave          | 7,341  |
| St James Town C.C.               | 495 Sherbourne St       | 23,002 |
| St Lawrence C.C                  | 224 The Esplanade       | 46,113 |
| Stanley C.C                      | 25 Stanley Rd           | 12,895 |
| Sunnybrook Park                  | 1070 Leslie St          | 43,702 |
| Sunshine Center for Seniors      | 0 Wards Isl Bdg60       | 2,250  |
| Tall Pines C.C                   | 64 Rylander Blvd        | 5,188  |
| Tam Heather C.C                  | 730 Military Trail      | 28,546 |
| Thistletown C.C                  | 925 Albion Rd           | 44,810 |
| West Rouge C.C                   | 270 Rouge Hills Dr      | 24,402 |
| West Scarborough N.C             | 313 Pharmacy Ave        | 25,199 |

**Table 49: Community Centre Building Information**

## 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 69 community centre buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| Building                        | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|---------------------------------|---|--|---|
| Burrows Hall Community Complex  | 3.56  | 0.67   | 4.23  |
| Sir Adam Beck                   | 6.35  | 7.42   | 13.77   |
| Metro Track And Field           | 6.53  | 9.00   | 15.53   |
| Cedar Brook C.C                 | 10.88   | 5.32   | 16.20   |
| Sunshine Center for Seniors     | 16.35   | 0.00   | 16.35   |
| Community Centre 55             | 7.91  | 8.57   | 16.47   |
| Amesbury Community Center       | 7.27  | 11.07  | 18.33   |
| Harbourfront Community Centre   | 10.25   | 8.50   | 18.76   |
| Tall Pines C.C                  | 11.15   | 8.55   | 19.70   |
| Northwood C.C                   | 8.70  | 12.73  | 21.44   |
| Banbury C.C.                    | 10.60   | 11.66  | 22.25   |
| Armour Height C.C               | 11.11   | 11.52  | 22.63   |
| Ellesmere C.C                   | 10.54   | 12.18  | 22.71   |
| Davenport C.C                   | 0.59  | 23.32  | 23.91   |
| Cedar Ridge C.C                 | 13.60   | 10.33  | 23.93   |
| Humber Sheppard Community Ctr   | 4.56  | 19.59  | 24.15   |
| West Rouge C.C                  | 9.17  | 15.47  | 24.65   |
| Mount Dennis Community Ctr      | 14.53   | 10.20  | 24.73   |
| Commander Park C.C              | 16.24   | 9.73   | 25.98   |
| Harwood Hall Community Ctr      | 5.08  | 21.27  | 26.36   |
| Eastview Neighbourhood Comm Ctr | 15.37   | 11.44  | 26.80   |
| Birkdale C.C                    | 21.70   | 5.21   | 26.90   |
| Franklin Horner                 | 5.94  | 22.31  | 28.25   |
| Oakridge C.C                    | 15.49   | 12.87  | 28.36   |
| Scarborough Village C.C         | 17.78   | 10.82  | 28.59   |
| North York Memorial Hall        | 18.94   | 10.70  | 29.64   |
| Leslie Grove Park               | 3.49  | 26.48  | 29.97   |
| Jenner Jean-Marie C.C.          | 10.00   | 20.15  | 30.15   |
| Lawrence Heights C.C.           | 10.64   | 20.07  | 30.70   |
| Earl Bales C.C & Senior         | 20.09   | 10.66  | 30.75   |
| Curran Hall C.C                 | 15.76   | 15.45  | 31.21   |
| Falstaff C.C                    | 11.43   | 19.82  | 31.25   |

|                                 |       |       |       |
|---------------------------------|-------|-------|-------|
| Masaryk-Cowan C.R.C             | 20.07 | 11.44 | 31.51 |
| Thistletown C.C                 | 7.86  | 23.87 | 31.73 |
| Sunnybrook Park                 | 16.52 | 15.37 | 31.89 |
| Driftwood C.C                   | 14.92 | 17.80 | 32.72 |
| Mid-Scarborough C.C             | 18.35 | 14.47 | 32.81 |
| Fairbanks Community Centre      | 16.34 | 16.61 | 32.96 |
| Lamp Senior Centre              | 17.95 | 15.47 | 33.43 |
| Flemingdon C.C                  | 11.13 | 22.49 | 33.62 |
| Ralph Thornton Community Ctr    | 11.52 | 22.33 | 33.85 |
| Forest Hill C.C                 | 20.16 | 13.77 | 33.92 |
| O'Connor C.C                    | 17.51 | 18.79 | 36.30 |
| Port Union C.C                  | 23.31 | 13.13 | 36.44 |
| Heron Park C.C                  | 22.16 | 15.32 | 37.48 |
| Stanley C.C                     | 16.00 | 23.35 | 39.35 |
| Oakdale Community Center        | 22.48 | 18.92 | 41.40 |
| Ourland Community Ctr           | 20.47 | 21.07 | 41.53 |
| Elmbank Community Centre        | 17.70 | 23.98 | 41.68 |
| Scadding Court Community Ctr    | 16.53 | 26.29 | 42.81 |
| Berner Trail C.C                | 19.86 | 23.28 | 43.14 |
| Main Square Comm Ctr            | 17.47 | 26.00 | 43.48 |
| McGregor Park C.C               | 26.54 | 17.14 | 43.68 |
| Edithvale C.C                   | 25.58 | 18.66 | 44.24 |
| David Appleton Community Centre | 25.23 | 20.03 | 45.27 |
| East Scar Boys/Girls Club       | 22.00 | 34.64 | 56.63 |
| Cecil Community Ctr             | 14.95 | 41.90 | 56.85 |
| East York Community Centre      | 15.79 | 42.89 | 58.68 |
| West Scarborough N.C            | 12.90 | 46.07 | 58.97 |
| Ledbury Community Center        | 35.93 | 23.98 | 59.91 |
| 519 Church St Comm Ctr          | 34.22 | 30.56 | 64.78 |
| Tam Heather C.C                 | 30.59 | 36.57 | 67.16 |
| St Lawrence C.C                 | 19.98 | 48.47 | 68.45 |
| Birchmount C.C                  | 30.55 | 38.61 | 69.16 |
| Chapley C.C / Wilmington Park   | 48.09 | 23.99 | 72.08 |
| L'Amoreaux Tennis Club          | 33.69 | 39.87 | 73.55 |
| Glenlong C.C & A.I.R            | 39.24 | 34.89 | 74.13 |
| St James Town C.C.              | 47.87 | 41.45 | 89.32 |
| Albion Comm Ctr & Pool (indoor) | 24.74 | 69.77 | 94.51 |

**Table 50: Community Centre 2012 Energy Intensity**

### 5.3 Target-setting Method and Metrics

5 community centres were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.


| Facility                   | Days in 2012 | Energy type |
|----------------------------|--------------|-------------|
| Cedar Brook C.C            | 457          | Electricity |
| Davenport C.C              | 396          | Electricity |
| Flemingdon C.C             | 389          | Electricity |
| Harwood Hall Community Ctr | 394          | Electricity |
| Community Centre 55        | 311          | Electricity |

**Table 51: Excluded Facilities**

After excluding these 5 facilities, 79 community centres and indoor recreational facilities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.


The red line on each chart indicates the top quartile for each component which is the target for that component. The red line on each chart indicates the top quartile for each component which is the target for that component.



**Figure 30: 2012 Electric Baseload Intensity Benchmark**


Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for community centres ranges from 3.3 to 43.0 kWh/ft<sup>2</sup> and the top-quartile is 9.21 kWh/ft<sup>2</sup>.





**Figure 31: 2012 Electric Cooling Intensity Benchmark**

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for community centres ranges from 0.5 to 14.3 ekWh/ft<sup>2</sup> and the top-quartile is 0.77 ekWh/ft<sup>2</sup>.



**Figure 32: 2012 Electric Heating Intensity Benchmark**

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for community centres ranges from 1.0 to 20.3 ekWh/ft<sup>2</sup> and the top-quartile is 1.76 ekWh/ft<sup>2</sup>.




Figure 33: 2012 Gas Baseload Intensity Benchmark

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for community centres ranges from 1.1 to 23.9 ekWh/ft<sup>2</sup> and the top-quartile is 1.83 ekWh/ft<sup>2</sup>.




Figure 34: 2012 Gas Heating Intensity Benchmark

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for community centres ranges from 3.4 to 44.6 ekWh/ft<sup>2</sup> and the top-quartile is 9.71 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of community centres, the factors are % of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps, % of the area served by electric air conditioning, % of area served by food services, presence and size of ice surface (including months of ice-in) and presence and size of indoor swimming pool.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 9 High Savings Potential Community Centres

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 9 community centres with over \$100,000 in annual savings potential.

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |            | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|------------|--------------------------------|------------------------|-----------|
|                                       | Average %                     |         |         |       | Average %             |           |         |       | Avg %                          | \$/yr | Electricity | Gas        |                                |                        |           |
|                                       | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating | Total |                                |       |             |            |                                |                        | \$/yr     |
| High potential savings facilities (9) | 64%                           | 100%    | 13%     | 65%   | \$1,025,079           | 77%       | 49%     | 58%   | \$156,725                      | 61%   | \$1,181,804 | \$ 585,759 | \$ 60,279                      | 420,191                | 1,938,059 |
| Birchmount C.C.                       | 69%                           | 100%    |         | 72%   | \$ 141,687            | 88%       | 59%     | 70%   | \$ 31,299                      | 71%   | \$ 172,986  | \$ 80,964  | \$ 12,038                      | 46,167                 | 337,518   |
| McGregor Park C.C.                    | 71%                           |         |         | 86%   | \$ 145,193            | 86%       |         | 67%   | \$ 13,057                      | 79%   | \$ 158,250  | \$ 82,968  | \$ 5,022                       | 45,262                 | 208,439   |
| St James Town C.C.                    | 79%                           | 100%    |         | 81%   | \$ 125,429            | 80%       | 70%     | 71%   | \$ 17,066                      | 77%   | \$ 142,495  | \$ 71,674  | \$ 6,564                       | 23,002                 | 221,887   |
| Tam Heather C.C.                      | 74%                           |         |         | 88%   | \$ 107,347            | 16%       | 72%     | 68%   | \$ 17,752                      | 77%   | \$ 125,099  | \$ 61,341  | \$ 6,828                       | 28,546                 | 212,638   |
| L'Amoreaux Tennis Club                | 60%                           | 100%    | 21%     | 67%   | \$ 99,399             |           | 75%     | 72%   | \$ 22,785                      | 70%   | \$ 122,185  | \$ 56,799  | \$ 8,764                       | 31,474                 | 242,768   |
| St Lawrence C.C.                      | 57%                           |         |         | 60%   | \$ 77,998             | 92%       | 61%     | 77%   | \$ 43,018                      | 72%   | \$ 121,016  | \$ 44,570  | \$ 16,545                      | 46,113                 | 372,173   |
| Heron Park C.C.                       | 63%                           |         |         | 70%   | \$ 113,084            | 64%       | 7%      | 25%   | \$ 5,133                       | 52%   | \$ 118,217  | \$ 64,619  | \$ 1,974                       | 52,377                 | 125,950   |
| Mid-Scarborough C.C.                  | 48%                           | 100%    |         | 48%   | \$ 110,831            | 23%       | 20%     | 20%   | \$ 6,615                       | 36%   | \$ 117,445  | \$ 63,332  | \$ 2,544                       | 89,125                 | 134,885   |
| Scarborough Village C.C.              | 58%                           |         |         | 72%   | \$ 104,111            |           |         | 0%    | \$ -                           | 45%   | \$ 104,111  | \$ 59,492  | \$ -                           | 58,125                 | 81,801    |

Table 52: Savings Potential for 9 High Savings Potential Community Centres

### Savings Potential by Energy Use Component for the 41 Mid Savings Potential Community Centres

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 41 community centres with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         | Total Energy Savings Potential |           | Incentives  |             | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |           |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|--------------------------------|-----------|-------------|-------------|--------------------------------|------------------------|-----------|-----------|
|                                       | Average %                     |         |         |       | Average %             |           |         | Avg %                          | \$/yr     | Electricity | Gas         |                                |                        |           |           |
|                                       | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating |                                |           |             |             |                                |                        | Total     | \$/yr     |
| Mid-potential savings facilities (41) | 37%                           | 77%     | 47%     | 40%   | \$ 914,751            | 69%       | 42%     | 49%                            | \$236,296 | 45%         | \$1,151,047 | \$ 522,715                     | \$ 90,883              | 1,166,121 | 2,426,424 |
| Commander Park C.C                    | 52%                           |         |         | 62%   | \$ 79,165             |           |         | 0%                             | \$ -      | 39%         | \$ 79,165   | \$ 45,237                      | \$ -                   | 56,317    | 62,201    |
| Edithvale C.C                         | 62%                           | 100%    |         | 66%   | \$ 58,032             |           | 45%     | 43%                            | \$ 4,929  | 56%         | \$ 62,962   | \$ 33,161                      | \$ 1,896               | 24,725    | 81,220    |
| 519 Church St Comm Ctr                | 70%                           | 100%    |         | 73%   | \$ 54,519             | 74%       | 59%     | 63%                            | \$ 7,509  | 68%         | \$ 62,028   | \$ 31,154                      | \$ 2,888               | 15,554    | 97,104    |
| Scadding Court Community Ctr          | 35%                           |         |         | 35%   | \$ 37,489             | 75%       | 51%     | 58%                            | \$ 17,730 | 49%         | \$ 55,220   | \$ 21,423                      | \$ 6,819               | 46,694    | 157,592   |
| Main Bales Comm Ctr                   | 43%                           | 100%    |         | 46%   | \$ 39,344             | 79%       | 44%     | 56%                            | \$ 12,765 | 52%         | \$ 52,109   | \$ 22,482                      | \$ 4,910               | 35,123    | 123,165   |
| East York Community Centre            | 35%                           | 100%    |         | 39%   | \$ 26,472             | 90%       | 61%     | 73%                            | \$ 24,436 | 64%         | \$ 50,908   | \$ 15,127                      | \$ 9,398               | 31,000    | 197,393   |
| Sunnybrook Park                       | 43%                           |         |         | 43%   | \$ 43,304             |           | 33%     | 32%                            | \$ 5,347  | 37%         | \$ 48,651   | \$ 24,745                      | \$ 2,057               | 43,702    | 72,689    |
| Masaryk-Cowan C.R.C                   | 52%                           | 100%    |         | 51%   | \$ 46,436             |           | 11%     | 11%                            | \$ 1,012  | 37%         | \$ 47,448   | \$ 26,535                      | \$ 389                 | 32,270    | 43,797    |
| Glenlong C.C & A.I.R                  | 55%                           |         | 88%     | 68%   | \$ 38,482             | 91%       | 40%     | 68%                            | \$ 6,113  | 68%         | \$ 44,594   | \$ 21,989                      | \$ 2,351               | 10,236    | 74,411    |
| Earl Bales C.C & Senior               | 45%                           |         | 36%     | 49%   | \$ 44,075             |           | 6%      | 5%                             | \$ 458    | 34%         | \$ 44,533   | \$ 25,186                      | \$ 176                 | 31,953    | 37,937    |
| Forest Hill C.C                       | 47%                           |         |         | 42%   | \$ 38,930             |           | 43%     | 43%                            | \$ 4,899  | 42%         | \$ 43,829   | \$ 22,246                      | \$ 1,884               | 32,841    | 65,990    |
| Chapley C.C / Wilmington Park         | 70%                           |         | 80%     | 79%   | \$ 37,249             | 91%       |         | 78%                            | \$ 3,304  | 79%         | \$ 40,553   | \$ 21,285                      | \$ 1,271               | 6,997     | 53,146    |
| Port Union C.C                        | 52%                           | 100%    |         | 61%   | \$ 39,529             | 1%        | 14%     | 12%                            | \$ 794    | 43%         | \$ 40,323   | \$ 22,588                      | \$ 305                 | 19,978    | 36,795    |
| Albion Comm Ctr & Pool (indoor)       | 13%                           | 69%     |         | 18%   | \$ 12,659             | 64%       | 71%     | 69%                            | \$ 25,195 | 56%         | \$ 37,854   | \$ 7,234                       | \$ 9,690               | 20,688    | 192,025   |
| East Scar Boys/Girls Club             | 57%                           | 100%    |         | 60%   | \$ 25,831             | 71%       | 66%     | 67%                            | \$ 8,200  | 65%         | \$ 34,032   | \$ 14,761                      | \$ 3,154               | 13,972    | 79,559    |
| West Scarborough N.C                  | 19%                           | 100%    |         | 25%   | \$ 11,363             | 92%       | 60%     | 76%                            | \$ 22,029 | 64%         | \$ 33,392   | \$ 6,493                       | \$ 8,473               | 25,199    | 168,132   |
| Lamp Senior Centre                    | 45%                           | 100%    |         | 44%   | \$ 29,145             |           | 28%     | 25%                            | \$ 2,554  | 35%         | \$ 31,699   | \$ 16,654                      | \$ 982                 | 26,318    | 41,357    |
| Ledbury Community Center              | 41%                           |         | 91%     | 70%   | \$ 20,304             | 91%       | 79%     | 79%                            | \$ 2,755  | 74%         | \$ 23,058   | \$ 11,602                      | \$ 1,059               | 5,780     | 35,861    |
| Eimbank Community Centre              | 49%                           |         |         | 50%   | \$ 18,227             | 53%       | 52%     | 52%                            | \$ 4,644  | 51%         | \$ 22,871   | \$ 10,415                      | \$ 1,786               | 14,725    | 47,886    |
| Birkdale C.C                          | 59%                           |         |         | 62%   | \$ 22,042             |           |         | 0%                             | \$ -      | 50%         | \$ 22,042   | \$ 12,596                      | \$ -                   | 11,733    | 17,319    |
| Oakridge C.C                          | 33%                           | 100%    |         | 44%   | \$ 17,576             | 55%       |         | 17%                            | \$ 1,026  | 32%         | \$ 18,603   | \$ 10,044                      | \$ 395                 | 18,600    | 21,227    |
| O'Connor C.C                          | 42%                           |         |         | 38%   | \$ 15,245             | 75%       | 17%     | 40%                            | \$ 3,033  | 39%         | \$ 18,278   | \$ 8,712                       | \$ 1,166               | 16,253    | 33,896    |
| Eastview Neighbourhood Comm Ctr       | 32%                           |         |         | 32%   | \$ 17,293             | 32%       |         | 8%                             | \$ 562    | 21%         | \$ 17,854   | \$ 9,882                       | \$ 216                 | 25,510    | 17,646    |
| Oakdale Community Center              | 44%                           |         | 53%     | 46%   | \$ 14,495             | 88%       |         | 69%                            | \$ 3,303  | 57%         | \$ 17,798   | \$ 8,283                       | \$ 1,270               | 10,000    | 35,259    |
| Berner Trail C.C                      | 45%                           | 100%    |         | 50%   | \$ 14,113             | 76%       | 38%     | 50%                            | \$ 2,993  | 50%         | \$ 17,106   | \$ 8,065                       | \$ 1,151               | 10,204    | 32,720    |
| Stanley C.C                           | 35%                           | 100%    |         | 38%   | \$ 10,987             | 91%       |         | 75%                            | \$ 5,681  | 60%         | \$ 16,668   | \$ 6,278                       | \$ 2,185               | 12,895    | 49,691    |
| Driftwood C.C                         | 26%                           |         |         | 23%   | \$ 12,046             | 73%       | 21%     | 40%                            | \$ 4,488  | 32%         | \$ 16,533   | \$ 6,883                       | \$ 1,726               | 25,015    | 41,897    |
| Fairbanks Community Centre            | 31%                           |         |         | 27%   | \$ 12,085             |           | 44%     | 44%                            | \$ 3,539  | 36%         | \$ 15,624   | \$ 6,906                       | \$ 1,361               | 19,364    | 35,068    |
| Thistletown C.C                       |                               |         |         | 0%    | \$ -                  | 62%       | 52%     | 54%                            | \$ 14,447 | 40%         | \$ 14,447   | \$ -                           | \$ 5,557               | 44,810    | 104,407   |
| Humber Sheppard Community Ctr         |                               | 100%    |         | 5%    | \$ 1,712              |           | 47%     | 44%                            | \$ 12,484 | 36%         | \$ 14,196   | \$ 978                         | \$ 4,802               | 57,867    | 91,567    |
| Ourland Community Ctr                 | 45%                           | 28%     |         | 41%   | \$ 11,145             |           | 53%     | 50%                            | \$ 2,509  | 46%         | \$ 13,655   | \$ 6,369                       | \$ 965                 | 9,451     | 26,892    |
| North York Memorial Hall              | 44%                           | 100%    |         | 48%   | \$ 13,340             |           |         | 0%                             | \$ -      | 31%         | \$ 13,340   | \$ 7,623                       | \$ -                   | 10,473    | 10,482    |
| Burrows Hall Community Complex        |                               | 100%    |         | 11%   | \$ 13,253             |           |         | 0%                             | \$ -      | 9%          | \$ 13,253   | \$ 7,573                       | \$ -                   | 252,952   | 10,413    |
| Franklin Horner                       |                               |         |         | 0%    | \$ -                  |           | 56%     | 56%                            | \$ 12,406 | 44%         | \$ 12,406   | \$ -                           | \$ 4,771               | 39,500    | 89,655    |
| Ralph Thornton Community Ctr          | 9%                            | 100%    |         | 15%   | \$ 4,014              |           | 55%     | 54%                            | \$ 5,123  | 40%         | \$ 9,137    | \$ 2,294                       | \$ 1,970               | 17,061    | 40,177    |
| Cecil Community Ctr                   | 36%                           | 100%    |         | 34%   | \$ 4,158              |           | 76%     | 73%                            | \$ 4,421  | 63%         | \$ 8,579    | \$ 2,376                       | \$ 1,700               | 5,769     | 35,216    |
| Illesmere C.C                         |                               | 100%    |         | 20%   | \$ 7,326              |           | 12%     | 11%                            | \$ 847    | 16%         | \$ 8,172    | \$ 4,186                       | \$ 326                 | 24,402    | 11,875    |
| Cedar Ridge C.C                       | 29%                           | 100%    |         | 30%   | \$ 7,571              |           |         | 0%                             | \$ -      | 17%         | \$ 7,571    | \$ 4,326                       | \$ -                   | 13,110    | 5,948     |
| West Rouge C.C                        |                               | 100%    |         | 11%   | \$ 3,577              |           | 37%     | 37%                            | \$ 3,510  | 27%         | \$ 7,087    | \$ 2,044                       | \$ 1,350               | 24,402    | 28,174    |
| David Appleton Community Centre       | 62%                           | 100%    |         | 62%   | \$ 6,344              | 57%       | 38%     | 42%                            | \$ 616    | 53%         | \$ 6,960    | \$ 3,625                       | \$ 237                 | 2,906     | 9,438     |
| Armour Height C.C                     | 19%                           |         |         | 19%   | \$ 5,873              | 41%       |         | 11%                            | \$ 637    | 15%         | \$ 6,510    | \$ 3,356                       | \$ 245                 | 19,773    | 9,218     |

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives   |            | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|--------------|------------|--------------------------------|------------------------|-----------|
|                                       | Average %                     |         |         |       | Average %             |           |         |       | Avg %                          | \$/yr | Electricity  | Gas        |                                |                        |           |
|                                       | Base-load                     | Cooling | Heating | Total | \$/yr                 | Base-load | Heating | Total |                                |       |              |            |                                |                        | \$/yr     |
| Mid-potential savings facilities (41) | 38%                           | 79%     | 47%     | 40%   | \$ 917,311            | 67%       | 40%     | 46%   | \$216,902                      | 43%   | \$ 1,134,213 | \$ 524,178 | \$ 83,424                      | 1,147,726              | 2,288,279 |
| Commander Park C.C                    | 52%                           |         |         | 62%   | \$ 79,165             |           |         | 0%    | \$ -                           | 39%   | \$ 79,165    | \$ 45,237  | \$ -                           | 56,317                 | 62,201    |
| Edithvale C.C                         | 62%                           | 100%    |         | 66%   | \$ 58,032             |           | 45%     | 43%   | \$ 4,929                       | 56%   | \$ 62,962    | \$ 33,161  | \$ 1,896                       | 24,725                 | 81,220    |
| 519 Church St Comm Ctr                | 70%                           | 100%    |         | 73%   | \$ 54,519             | 74%       | 59%     | 63%   | \$ 7,509                       | 68%   | \$ 62,028    | \$ 31,154  | \$ 2,888                       | 15,554                 | 97,104    |
| Scadding Court Community Ctr          | 35%                           |         |         | 35%   | \$ 37,489             | 75%       | 51%     | 58%   | \$ 17,730                      | 49%   | \$ 55,220    | \$ 21,423  | \$ 6,819                       | 46,694                 | 157,592   |
| Main Square Comm Ctr                  | 43%                           | 100%    |         | 46%   | \$ 39,344             | 79%       | 44%     | 56%   | \$ 12,765                      | 52%   | \$ 52,109    | \$ 22,482  | \$ 4,910                       | 35,123                 | 123,165   |
| East York Community Centre            | 35%                           | 100%    |         | 39%   | \$ 26,472             | 90%       | 61%     | 73%   | \$ 24,436                      | 64%   | \$ 50,908    | \$ 15,127  | \$ 9,398                       | 31,000                 | 197,393   |
| Sunnybrook Park                       | 43%                           |         |         | 43%   | \$ 43,304             |           | 33%     | 32%   | \$ 5,347                       | 37%   | \$ 48,651    | \$ 24,745  | \$ 2,057                       | 43,702                 | 72,669    |
| Masaryk-Cowan C.R.C                   | 52%                           | 100%    |         | 51%   | \$ 46,436             |           | 11%     | 11%   | \$ 1,012                       | 37%   | \$ 47,448    | \$ 26,535  | \$ 389                         | 32,270                 | 43,797    |
| Glenlong C.C & A.I.R                  | 55%                           |         | 88%     | 68%   | \$ 38,435             | 91%       | 40%     | 68%   | \$ 6,113                       | 68%   | \$ 44,548    | \$ 21,963  | \$ 2,351                       | 10,236                 | 74,375    |
| Earl Bales C.C & Senior               | 45%                           |         | 35%     | 49%   | \$ 43,930             |           | 6%      | 5%    | \$ 458                         | 34%   | \$ 44,387    | \$ 25,103  | \$ 176                         | 31,953                 | 37,823    |
| Forest Hill C.C                       | 47%                           |         |         | 42%   | \$ 38,930             |           | 43%     | 43%   | \$ 4,899                       | 42%   | \$ 43,829    | \$ 22,246  | \$ 1,884                       | 32,841                 | 65,990    |
| Chapley C.C / Wilmington Park         | 70%                           |         | 80%     | 79%   | \$ 37,217             | 91%       |         | 78%   | \$ 3,304                       | 79%   | \$ 40,522    | \$ 21,267  | \$ 1,271                       | 6,997                  | 53,121    |
| Port Union C.C                        | 52%                           | 100%    |         | 61%   | \$ 39,529             | 1%        | 14%     | 12%   | \$ 794                         | 43%   | \$ 40,323    | \$ 22,588  | \$ 305                         | 19,978                 | 36,795    |
| Albion Comm Ctr & Pool (indoor)       | 13%                           | 69%     |         | 18%   | \$ 12,669             | 34%       | 41%     | 40%   | \$ 14,520                      | 34%   | \$ 27,189    | \$ 7,239   | \$ 5,585                       | 20,688                 | 114,890   |
| East Scar Boys/Girls Club             | 57%                           | 100%    |         | 60%   | \$ 25,831             | 71%       | 66%     | 67%   | \$ 8,200                       | 65%   | \$ 34,032    | \$ 14,761  | \$ 3,154                       | 13,972                 | 79,559    |
| West Scarborough N.C                  | 19%                           | 100%    |         | 25%   | \$ 11,363             | 92%       | 60%     | 76%   | \$ 22,029                      | 64%   | \$ 33,392    | \$ 6,493   | \$ 8,473                       | 25,199                 | 168,132   |
| Lamp Senior Centre                    | 45%                           | 100%    |         | 44%   | \$ 29,145             |           | 28%     | 25%   | \$ 2,554                       | 35%   | \$ 31,699    | \$ 16,654  | \$ 982                         | 26,318                 | 41,357    |
| Ledbury Community Center              | 41%                           |         | 91%     | 70%   | \$ 20,277             | 91%       |         | 79%   | \$ 2,755                       | 73%   | \$ 23,032    | \$ 11,587  | \$ 1,059                       | 5,780                  | 35,840    |
| Eimbank Community Centre              | 49%                           |         |         | 50%   | \$ 18,227             | 53%       | 52%     | 52%   | \$ 4,644                       | 51%   | \$ 22,871    | \$ 10,415  | \$ 1,786                       | 14,725                 | 47,886    |
| Birkdale C.C                          | 59%                           |         |         | 62%   | \$ 22,042             |           |         | 0%    | \$ -                           | 50%   | \$ 22,042    | \$ 12,596  | \$ -                           | 11,733                 | 17,319    |
| Oakridge C.C                          | 33%                           | 100%    |         | 44%   | \$ 17,576             | 55%       |         | 17%   | \$ 1,026                       | 32%   | \$ 18,603    | \$ 10,044  | \$ 395                         | 18,600                 | 21,227    |
| O'Connor C.C                          | 42%                           |         |         | 38%   | \$ 15,245             | 75%       | 17%     | 40%   | \$ 3,033                       | 39%   | \$ 18,278    | \$ 8,712   | \$ 1,166                       | 16,253                 | 33,896    |
| Eastview Neighbourhood Comm Ctr       | 32%                           |         |         | 32%   | \$ 17,293             | 32%       |         | 8%    | \$ 562                         | 21%   | \$ 17,854    | \$ 9,882   | \$ 216                         | 25,510                 | 17,646    |
| Oakdale Community Center              | 44%                           |         | 52%     | 46%   | \$ 14,450             | 88%       |         | 69%   | \$ 3,303                       | 57%   | \$ 17,752    | \$ 8,257   | \$ 1,270                       | 10,000                 | 35,223    |
| Berner Trail C.C                      | 45%                           | 100%    |         | 50%   | \$ 14,113             | 76%       | 38%     | 50%   | \$ 2,993                       | 50%   | \$ 17,106    | \$ 8,065   | \$ 1,151                       | 10,204                 | 32,720    |
| Stanley C.C                           | 35%                           | 100%    |         | 38%   | \$ 10,987             | 91%       |         | 75%   | \$ 5,681                       | 60%   | \$ 16,668    | \$ 6,278   | \$ 2,185                       | 12,895                 | 49,691    |
| Driftwood C.C                         | 26%                           |         |         | 23%   | \$ 12,046             | 73%       | 21%     | 40%   | \$ 4,488                       | 32%   | \$ 16,533    | \$ 6,883   | \$ 1,726                       | 25,015                 | 41,897    |
| Fairbanks Community Centre            | 31%                           |         |         | 27%   | \$ 12,085             |           | 44%     | 44%   | \$ 3,539                       | 36%   | \$ 15,624    | \$ 6,906   | \$ 1,361                       | 19,364                 | 35,068    |
| Humber Sheppard Community Ctr         |                               | 100%    |         | 5%    | \$ 1,712              |           | 47%     | 44%   | \$ 12,484                      | 36%   | \$ 14,196    | \$ 978     | \$ 4,802                       | 57,867                 | 91,567    |
| Ourland Community Ctr                 | 45%                           | 29%     |         | 41%   | \$ 11,163             |           | 53%     | 50%   | \$ 2,509                       | 46%   | \$ 13,673    | \$ 6,379   | \$ 965                         | 9,451                  | 26,906    |
| North York Memorial Hall              | 44%                           | 100%    |         | 48%   | \$ 13,340             |           |         | 0%    | \$ -                           | 31%   | \$ 13,340    | \$ 7,623   | \$ -                           | 10,473                 | 10,482    |
| Burrows Hall Community Complex        |                               | 100%    |         | 11%   | \$ 13,253             |           |         | 0%    | \$ -                           | 9%    | \$ 13,253    | \$ 7,573   | \$ -                           | 252,952                | 10,413    |
| Franklin Horner                       |                               |         |         | 0%    | \$ -                  |           | 56%     | 56%   | \$ 12,406                      | 44%   | \$ 12,406    | \$ -       | \$ 4,771                       | 39,500                 | 89,655    |
| Ralph Thornton Community Ctr          | 9%                            | 100%    |         | 15%   | \$ 4,014              |           | 55%     | 54%   | \$ 5,123                       | 40%   | \$ 9,137     | \$ 2,294   | \$ 1,970                       | 17,061                 | 40,177    |
| Cecil Community Ctr                   | 36%                           | 100%    |         | 34%   | \$ 4,158              |           | 76%     | 73%   | \$ 4,421                       | 63%   | \$ 8,579     | \$ 2,376   | \$ 1,700                       | 5,769                  | 35,216    |
| Jenner Jean-Marie C.C.                | 8%                            |         |         | 8%    | \$ 2,827              | 18%       | 46%     | 43%   | \$ 5,728                       | 31%   | \$ 8,555     | \$ 1,616   | \$ 2,203                       | 26,415                 | 43,616    |
| Ellesmere C.C                         |                               | 100%    |         | 20%   | \$ 7,326              |           | 12%     | 11%   | \$ 847                         | 16%   | \$ 8,172     | \$ 4,186   | \$ 326                         | 24,402                 | 11,875    |
| Cedar Ridge C.C                       | 29%                           | 100%    |         | 30%   | \$ 7,571              |           |         | 0%    | \$ -                           | 17%   | \$ 7,571     | \$ 4,326   | \$ -                           | 13,110                 | 5,948     |
| West Rouge C.C                        |                               | 100%    |         | 11%   | \$ 3,577              |           | 37%     | 37%   | \$ 3,510                       | 27%   | \$ 7,087     | \$ 2,044   | \$ 1,350                       | 24,402                 | 28,174    |
| David Appleton Community Centre       | 62%                           | 100%    |         | 62%   | \$ 6,344              | 57%       | 38%     | 42%   | \$ 616                         | 53%   | \$ 6,960     | \$ 3,625   | \$ 237                         | 2,906                  | 9,438     |
| Armour Height C.C                     | 19%                           |         |         | 19%   | \$ 5,873              | 41%       |         | 11%   | \$ 637                         | 15%   | \$ 6,510     | \$ 3,356   | \$ 245                         | 19,773                 | 9,218     |

Table 53: Savings Potential for 41 Medium Savings Potential Community Centres

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

### Savings Potential by Energy Use Component for the 19 Low Savings Potential Community Centres

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 19 community centres with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | \$/yr     | Gas Savings Potential |         |       | \$/yr     | Total Energy Savings Potential |           | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|-----------|--------------------------------|-----------|-------------|----------|--------------------------------|------------------------|
|                                       | Average %                     |         |         |       |           | Average %             |         |       |           | Avg %                          | \$/yr     | Electricity | Gas      |                                |                        |
|                                       | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |           |                                |           |             |          |                                |                        |
| Low potential savings facilities (19) | 02%                           | 17%     | 06%     | 03%   | \$ 16,100 | 36%                   | 12%     | 18%   | \$ 20,441 | 11%                            | \$ 36,541 | \$ 9,200    | \$ 7,862 | 414,659                        | 160,374                |
| Lawrence Heights C.C.                 |                               |         |         | 0%    | \$ -      | 69%                   | 34%     | 45%   | \$ 4,981  | 29%                            | \$ 4,981  | \$ -        | \$ 1,916 | 22,152                         | 36,001                 |
| Amesbury Community Center             |                               | 100%    |         | 10%   | \$ 3,996  |                       | 6%      | 6%    | \$ 587    | 7%                             | \$ 4,583  | \$ 2,283    | \$ 226   | 37,975                         | 7,384                  |
| Jenner Jean-Marie C.C.                | 8%                            |         |         | 8%    | \$ 1,414  | 18%                   | 46%     | 43%   | \$ 2,864  | 31%                            | \$ 4,278  | \$ 808      | \$ 1,101 | 13,207                         | 21,808                 |
| Falstaff C.C.                         |                               | 8%      |         | 2%    | \$ 438    |                       | 53%     | 49%   | \$ 3,383  | 32%                            | \$ 3,822  | \$ 251      | \$ 1,301 | 13,853                         | 24,796                 |
| Northwood C.C.                        |                               |         |         | 0%    | \$ -      | 63%                   |         | 24%   | \$ 2,779  | 14%                            | \$ 2,779  | \$ -        | \$ 1,069 | 36,167                         | 20,082                 |
| Flemingdon C.C.                       |                               |         |         | 0%    | \$ -      |                       |         | 49%   | \$ 2,751  | 33%                            | \$ 2,751  | \$ -        | \$ 1,058 | 10,000                         | 19,879                 |
| Curran Hall C.C.                      | 41%                           |         |         | 40%   | \$ 2,208  |                       | 37%     | 37%   | \$ 362    | 39%                            | \$ 2,570  | \$ 1,262    | \$ 139   | 2,508                          | 4,352                  |
| Sunshine Center for Seniors           | 37%                           |         | 54%     | 45%   | \$ 2,324  |                       |         |       | \$ -      | 45%                            | \$ 2,324  | \$ 1,328    | \$ -     | 2,250                          | 1,826                  |
| Mount Dennis Community Ctr            | 29%                           |         | 15%     | 28%   | \$ 1,702  |                       | 4%      | 4%    | \$ 30     | 18%                            | \$ 1,732  | \$ 973      | \$ 12    | 3,003                          | 1,554                  |
| Metro Track And Field                 |                               | 100%    |         | 2%    | \$ 1,665  |                       |         | 0%    | \$ -      | 1%                             | \$ 1,665  | \$ 951      | \$ -     | 96,338                         | 1,308                  |
| Banbury C.C.                          | 7%                            |         |         | 7%    | \$ 993    |                       | 15%     | 15%   | \$ 421    | 11%                            | \$ 1,413  | \$ 567      | \$ 162   | 9,537                          | 3,820                  |
| Tall Pines C.C.                       | 11%                           | 100%    |         | 15%   | \$ 1,206  |                       |         | 0%    | \$ -      | 8%                             | \$ 1,206  | \$ 689      | \$ -     | 5,188                          | 947                    |
| Harwood Hall Community Ctr            |                               |         |         | 0%    | \$ -      |                       |         | 46%   | \$ 1,053  | 37%                            | \$ 1,053  | \$ -        | \$ 405   | 4,306                          | 7,611                  |
| Davenport C.C.                        |                               |         |         | 0%    | \$ -      |                       |         | 51%   | \$ 675    | 49%                            | \$ 675    | \$ -        | \$ 260   | 2,282                          | 4,881                  |
| Leslie Grove Park                     |                               |         |         | 0%    | \$ -      |                       | 62%     | 60%   | \$ 554    | 53%                            | \$ 554    | \$ -        | \$ 213   | 1,389                          | 4,003                  |
| Sir Adam Beck                         |                               | 100%    |         | 2%    | \$ 155    |                       |         | 0%    | \$ -      | 1%                             | \$ 155    | \$ 88       | \$ -     | 7,341                          | 122                    |
| Cedar Brook C.C.                      |                               |         |         | 0%    | \$ -      |                       |         | 0%    | \$ -      | 0%                             | \$ -      | \$ -        | \$ -     | 14,951                         | 0                      |
| Community Centre 55                   |                               |         |         | 0%    | \$ -      |                       |         | 0%    | \$ -      | 0%                             | \$ -      | \$ -        | \$ -     | 8,999                          | 0                      |
| Harbourfront Community Centre         |                               |         |         | 0%    | \$ -      |                       |         | 0%    | \$ -      | 0%                             | \$ -      | \$ -        | \$ -     | 123,214                        | 0                      |

Table 54: Savings Potential for 20 Low Savings Potential Community Centres

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as (Actual Energy Use – Target Energy Use)/Actual Energy Use and \$/year savings for each component are calculated as (Actual Energy Use - Target Energy Use) \* utility company rates \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Cultural Facilities

---

## Table of Contents

|          |   |            |
|----------|---|------------|
| <b>1</b> | <b>Benchmarking and Conservation Potential .....</b>                                      | <b>116</b> |
| 1.1      | Energy Use and Building Characteristics.....  | 116        |
| 1.1.1    | Building Characteristics.....   | 116        |
| 1.1.2    | Summary of Energy Use and Costs .....   | 116        |
| 1.2      | Energy Targets.....   | 118        |
| 1.3      | Savings Potential.....  | 119        |
| <b>2</b> | <b>Conservation Measures and Budget.....</b>  | <b>121</b> |
| 2.1      | Proposed Energy Efficiency Measures .....   | 121        |
| <b>3</b> | <b>Energy Management and Retrofit Plan .....</b>  | <b>127</b> |
| 3.1      | Implementation Costs and Modeled Savings .....  | 127        |
| 3.2      | Implementation Process and Tools – Determining the Specific Measures for Each Building .. | 127        |
| 3.2.1    | Building Performance Audit.....   | 128        |
| 3.2.2    | Energy Assessment .....   | 129        |
| 3.2.3    | Energy Savings Checklist .....  | 129        |
| 3.3      | Implementation Budget.....  | 130        |
| 3.4      | 10-Year Implementation Plan .....   | 130        |
| <b>4</b> | <b>Appendix A.....</b>  | <b>133</b> |
| 4.1      | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities .....    | 133        |
| 4.2      | Determining Energy Use Components.....  | 133        |
| 4.3      | Determining Targets .....   | 133        |
| 4.4      | Calculating Potential Savings .....   | 135        |
| 4.5      | Implementation Costs by Measure Type and Modeled Savings.....                             | 135        |
| 4.6      | Assessment Tools.....   | 136        |
| <b>5</b> | <b>Appendix B - Cultural Facilities .....</b>   | <b>138</b> |
| 5.1      | Buildings and Building Characteristics .....  | 138        |
| 5.2      | Energy Use Intensities.....   | 138        |
| 5.3      | Target-setting Method and Metrics.....  | 139        |
| 5.4      | Savings Potential by Energy Use Component .....   | 142        |



## List of Tables

|  |     |
|--|-----|
| Table 55: 2012 Energy Use and Costs for 20 City of Toronto Cultural Facilities.....        | 116 |
| Table 56: Top Quartile Targets.....  | 119 |
| Table 57: Savings Potential Summary.....   | 120 |
| Table 58: Savings Potential Based on Energy Use Component for 20 Cultural Facilities ..... | 120 |
| Table 55: Energy Saving Measures for Cultural Facilities .....                             | 126 |
| Table 60: Estimated Implementation Costs and Modeled Savings .....                         | 127 |
| Table 61: Assessment Tools Used to Determine Specific Energy-saving Measures .....         | 128 |
| Table 62: Total Budget - Energy Management and Retrofit Plan .....                         | 130 |
| Table 63: Cash Flow for 10-Year Implementation Plan .....                                  | 132 |
| Table 64: Implementation Costs by Measure Type .....                                       | 135 |
| Table 65: Cultural Facility Building Information .....                                     | 138 |
| Table 66: Cultural Facility 2012 Energy Intensity.....                                     | 139 |
| Table 67: Excluded Facilities .....  | 139 |
| Table 68: Savings Potential for 1 High Savings Potential Cultural Facility .....           | 143 |
| Table 69: Savings Potential for 9 Medium Savings Potential Cultural Facilities .....       | 143 |

## List of Figures

|   |     |
|---|-----|
| Figure 35: 2012 Energy Use and Cost Breakdown for 20 City of Toronto Cultural Facilities..... | 117 |
| Figure 36: 2012 Total Energy Intensity Benchmark .....  | 117 |
| Figure 37: 2012 Total Electricity Intensity Benchmark .....                                   | 118 |
| Figure 38: 2012 Total Gas Intensity Benchmark .....   | 118 |
| Figure 39: Cash Flow for 10-Year Implementation Plan .....                                    | 132 |
| Figure 40: 2012 Electric Baseload Intensity Benchmark.....                                    | 140 |
| Figure 41: 2012 Electric Cooling Intensity Benchmark .....                                    | 140 |
| Figure 42: 2012 Electric Heating Intensity Benchmark.....                                     | 141 |
| Figure 43: 2012 Gas Baseload Intensity Benchmark.....   | 141 |
| Figure 44: 2012 Gas Heating Intensity Benchmark.....  | 142 |

## 1 Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 20 cultural facilities in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas of these facilities are provided in Appendix B.

The total area for all of the buildings is 596,553 ft<sup>2</sup>. The cultural facilities range in size from less than 1,000 ft<sup>2</sup> to over 185,000 ft<sup>2</sup>.

None of the facilities are equipped with a renewable energy system.

The facilities range from 0% to 100% air-conditioned. Two facilities (Historic Fort York and Gibson House Museum) are fully served by electric heat. Four other cultural facilities are using approximately 25% electric heat. No cultural facilities are served by ground or water source heat pumps.

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 20 buildings are summarized below.

|                                    | 2012 Energy Use |                    |
|------------------------------------|-----------------|--------------------|
|                                    | Unit            | \$                 |
| <b>Electricity (kWh)</b>           | 9,015,694       | \$1,262,197        |
| <b>Natural Gas (m<sup>3</sup>)</b> | 747,997         | \$194,479          |
| <b>Total</b>                       |                 | <b>\$1,456,676</b> |

Table 55: 2012 Energy Use and Costs for 20 City of Toronto Cultural Facilities




Figure 35: 2012 Energy Use and Cost Breakdown for 20 City of Toronto Cultural Facilities

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 20 buildings. Total energy use ranges from approximately 1.5 to over 96 ekWh/ft<sup>2</sup>. There are also wide ranges for electricity and gas use per ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 36: 2012 Total Energy Intensity Benchmark




Figure 37: 2012 Total Electricity Intensity Benchmark




Figure 38: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for cultural facilities are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each cultural facility to achieve its target over the duration of the ECDM Plan.

| Energy type         | Component    | Value       | Unit                            |
|---------------------|--------------|-------------|---------------------------------|
| Electricity         | Base         | 8.1         | kWh/ft <sup>2</sup> /year       |
|                     | Cooling      | 0.7         | kWh/ft <sup>2</sup> /year       |
|                     | Heating      | 0.4         | kWh/ft <sup>2</sup> /year       |
|                     | <b>Total</b> | <b>9.2</b>  | <b>kWh/ft<sup>2</sup>/year</b>  |
| Gas                 | Base         | 2.2         | ekWh/ft <sup>2</sup> /year      |
|                     | Heating      | 12.0        | ekWh/ft <sup>2</sup> /year      |
|                     | <b>Total</b> | <b>14.2</b> | <b>ekWh/ft<sup>2</sup>/year</b> |
| <b>Total energy</b> | <b>Total</b> | <b>23.4</b> | <b>ekWh/ft<sup>2</sup>/year</b> |

**Table 56: Top Quartile Targets**

The data set for target-setting is made up of 17 cultural facilities with complete and reliable data, all of which are City of Toronto buildings. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)) and % of the area which is air conditioned. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each cultural facility. The total savings potential for each cultural facility is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 20 cultural facilities are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There is 1 cultural facility with annual savings potential greater than \$100,000. 9 cultural facilities have annual savings potential between \$5,000 and \$100,000 and 10 cultural facilities have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 20 buildings is \$448,008 (\$358,867 for electricity and \$89,141 for gas) with an average total energy savings of 36%.

For the 1 high-potential savings facility, the total annual savings potential is \$273,738 (\$251,868 for electricity and \$21,870 for gas) with an average total energy savings of 35%.

For the 9 mid-potential savings facilities, the total annual savings potential is \$157,310 (\$95,352 for electricity and \$61,958 for gas) with an average total energy savings of 42%.

For the 10 low-potential savings facilities, the total annual savings potential is \$16,960 (\$11,647 for electricity and \$5,313 for gas) with an average total energy savings of 19%.


|                                       | Electricity Savings Potential |            |            |            | \$/yr            | Gas Savings Potential |            |            | \$/yr            | Total Energy Savings Potential |                  | Incentives       |                 | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|------------|------------|------------|------------------|-----------------------|------------|------------|------------------|--------------------------------|------------------|------------------|-----------------|--------------------------------|------------------------|
|                                       | Average %                     |            |            |            |                  | Base-load             | Average %  |            |                  | Avg %                          | \$/yr            | Electricity      | Gas             |                                |                        |
|                                       | Base-load                     | Cooling    | Heating    | Total      |                  |                       | Base-load  | Heating    |                  |                                |                  |                  |                 |                                |                        |
| <b>TOTAL: 20 facilities</b>           | <b>30%</b>                    | <b>55%</b> | <b>31%</b> | <b>28%</b> | <b>\$358,867</b> | <b>86%</b>            | <b>40%</b> | <b>46%</b> | <b>\$ 89,141</b> | <b>36%</b>                     | <b>\$448,008</b> | <b>\$205,067</b> | <b>\$34,285</b> | <b>596,553</b>                 | <b>926,181</b>         |
| High potential savings facilities (1) | 30%                           | 56%        | 00%        | 31%        | \$251,868        | 100%                  | 00%        | 45%        | \$ 21,870        | 35%                            | \$273,738        | \$143,925        | \$ 8,412        | 99,115                         | 355,950                |
| Mid-potential savings facilities (9)  | 35%                           | 60%        | 46%        | 26%        | \$ 95,352        | 41%                   | 58%        | 50%        | \$ 61,958        | 42%                            | \$157,310        | \$ 54,487        | \$23,830        | 237,280                        | 522,684                |
| Low potential savings facilities (10) | 13%                           | 22%        | 01%        | 13%        | \$ 11,647        | 41%                   | 14%        | 23%        | \$ 5,313         | 19%                            | \$ 16,960        | \$ 6,656         | \$ 2,043        | 260,157                        | 47,548                 |

**Table 57: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 20 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 15.1        | 10.6        | 30%                 | \$ 318,199           |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 1.0         | 0.5         | 55%                 | \$ 33,117            |
| Electric Heating (kWh/ft <sup>2</sup> )   | 0.5         | 0.3         | 31%                 | \$ 7,284             |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 8.7         | 8.7         | 0%                  | \$ 267               |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 2.5         | 0.4         | 86%                 | \$ 24,728            |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 10.6        | 6.3         | 40%                 | \$ 50,351            |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 17.5        | 11.3        | 35%                 | \$ 14,062            |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>28.1</b> | <b>17.8</b> | <b>36%</b>          | <b>\$ 448,008</b>    |



**Table 58: Savings Potential Based on Energy Use Component for 20 Cultural Facilities**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Proposed Energy Efficiency Measures

Table 5 below shows the full range of possible energy efficiency measures for the entire portfolio of cultural facilities. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 20 facilities indicate that the largest percentage reductions will come from measures associated with electric cooling and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).



| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off machines, office and kitchen equipment when not needed                                  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B2   | Unplug machines, office and kitchen equipment if not actively used                               | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off computer monitors when not in use   | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B4   | Enable ENERGY STAR power settings on your computer   | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B5   | Unplug chargers when not in use  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B6   | Turn off lights when areas not in use  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B7   | Make use of natural light instead of turning on lights where possible                            | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 3                        | 6           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 3                        | 6           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 3                        | 6           | Year 3   | 15+                   |                    |
| L1   | Conduct audit of exhibit and display lighting to identify possible improvements                  | 3                      | 3                        | 6           | Year 3   | 4 to 6                |                    |
| L2   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L3   | Install motion sensors in washrooms/occasional use spaces to shut off lights when unoccupied     | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L4   | Install photo-sensors and/or a timer on outdoor and daylit interior area lighting                | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L5   | Replace HID lighting with high efficiency fluorescent  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L6   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L7   | Replace festive lighting with LED  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L8   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 3                        | 4           | Year 4   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 3                        | 4           | Year 4   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 3                        | 4           | Year 4   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| M3   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 3                        | 4           | Year 4   | 10 to 20              |                    |
| M4   | Convert electric hot water heaters to natural gas  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

| Electric Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes</b> |  |                        |                          |             |          |                       |                    |
| B8   | Adjust blinds (to retain heat in winter)   | 4                      | 3                        | 7           | Year 1   | annual review         | Building Occupants |
| B9   | Avoid use of electric heaters  | 4                      | 3                        | 7           | Year 1   |                       | Building Occupants |
| B10  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 3                        | 7           | Year 1   |                       | Building Occupants |
| M8   | Control fan coil and entrance heaters to optimize run-times                                | 3                      | 3                        | 6           | Year 2   | seasonal review       |                    |
| M9   | Evaluate conversion from electric heating to natural gas                                   | 2                      | 3                        | 5           | Year 2   | n/a                   |                    |
| M5   | Install snow sensors to control the snow-melting system                                    | 1                      | 3                        | 4           | Year 4   | seasonal review       |                    |
| M6   | Upgrade base building heating system to avoid use of electric heaters                      | 1                      | 3                        | 4           | Year 4   | seasonal review       |                    |
| M7   | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1                      | 3                        | 4           | Year 4   | seasonal review       |                    |
|  | Other:   |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Electric Cooling Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes</b> |  |                        |                          |             |          |                       |                    |
| B11  | Winterize room air-conditioners  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B12  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B13  | Only cool rooms that are being used  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B14  | Install and use energy efficient ceiling fans  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B15  | Close blinds (to shade space from direct sunlight)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B16  | Install window film, solar screens or awnings on south and west facing windows               | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M10  | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M12  | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M13  | Test and tune the air conditioning units   | 3                      | 4                        | 7           | Year 2   | 3                     |                    |
| M11  | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
|  | Other:   |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Gas Baseload Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round</b> |  |                        |                          |             |          |                       |                    |
| B17  | Optimize dishwasher operation (only run when full) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| P1   | Optimize DHW temperature control                   | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| P3   | Test and tune DHW boiler efficiency                | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M16  | Investigate and repair possible gas leaks          | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P2   | Implement DHW circulation pump control             | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P4   | Install low flow showerheads and faucet aerators   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| M14  | Insulate DHW tanks and distribution piping         | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M15  | Replace DHW boilers with more efficient models     | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
|  | Other: _____                                       |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Heating Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS HEATING - refers to the additional energy used in winter for heating and humidification</b> |  |                        |                          |             |          |                       |                    |
| B18  | Check and clear baseboard heaters of obstructions  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B19  | Adjust blinds (to retain heat in winter)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B20  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M17  | Optimize operating periods of ventilation systems supplying heated spaces                  | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M18  | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M20  | Test and tune boiler efficiency  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M22  | Check heating system for flow balancing and air venting                                    | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| EN1  | Check and seal exterior walls and openings   | 3                      | 4                        | 7           | Year 2   | 10 to 15              |                    |
| EN5  | Seal window and door frames  | 3                      | 4                        | 7           | Year 2   | 5                     |                    |
| M23  | Optimize fan-coil unit and entrance heater controls  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M24  | Consider heating system zoning   | 2                      | 4                        | 6           | Year 2   | n/a                   |                    |
| M19  | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M21  | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| EN2  | Insulate the attic adequately  | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| EN3  | Reclad the building's exterior   | 1                      | 4                        | 5           | Year 3   | 20 to 24              |                    |
| EN4  | Replace single-pane windows with double-pane windows                                       | 1                      | 4                        | 5           | Year 3   | 20 to 24              |                    |
| EN6  | If replacing the roof, ensure R-value at least 22  | 1                      | 4                        | 5           | Year 3   | n/a                   |                    |
| M25  | Install high efficiency burners  | 1                      | 4                        | 5           | Year 3   | 15 to 20              |                    |
| M26  | Replace boilers with more efficient models   | 1                      | 4                        | 5           | Year 3   | 15 to 20              |                    |
| M27  | Replace old rooftop units with energy efficient units                                      | 1                      | 4                        | 5           | Year 3   | 15 to 20              |                    |
| M28  | Install heat recovery or solar heating units   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other: _____   |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

**Table 59: Energy Saving Measures for Cultural Facilities**

The specific measures and implementation timeline for each individual cultural facility will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities is \$4.65/ft<sup>2</sup> (see Appendix A). The budget allows for lighting audits, lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high-potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low-potential buildings is set at 40 percent of the basic amount to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium, and low potential cultural facilities are summarized in Table 6 below.

| Annual Savings Potential | # of facilities | Average Area (ft2) | Estimated Implementation Cost \$/sqft | Estimated Implementation Cost \$ | Estimated Savings potential \$ | Estimated Savings potential % | Payback |
|--------------------------|-----------------|--------------------|---------------------------------------|----------------------------------|--------------------------------|-------------------------------|---------|
| >\$100,000               | 1               | 99,115             | 5.58                                  | \$ 553,061                       | \$ 273,738                     | 61.1%                         | 2.02    |
| \$5,000-\$100,000        | 9               | 26,364             | 4.65                                  | \$ 1,103,353                     | \$ 157,310                     | 35.1%                         | 7.01    |
| <\$5,000                 | 10              | 26,016             | 1.86                                  | \$ 483,893                       | \$ 16,960                      | 3.8%                          | 28.53   |
|                          | 20              |                    |                                       | \$ 2,140,307                     | \$ 448,008                     |                               | 4.78    |

**Table 60: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.
- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 7 below.

|                |                                  | #         | Cost     | Savings Potential                     | Description  | Resources                   |
|----------------|----------------------------------|-----------|----------|---------------------------------------|--|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 1         | \$ 7,500 | savings potential > \$100,000         | includes interval meter analysis and water consumption | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 9         | \$ 750   | savings potential \$5,000 - \$100,000 | includes interval meter analysis                       | energy analyst              |
| Low Potential  | Checklists                       | 10        | \$ 150   | savings potential < \$5,000           |  | Division Champion and staff |
|                |                                  | <b>20</b> |          |                                       |  |                             |

**Table 61: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Building Performance Audit

There is 1 cultural facility (St Lawrence Market South) with over \$100,000 in annual energy saving potential. Over 60% of the total energy savings for all cultural facilities can be found at this facility.

St Lawrence Market South can save an average of 35% of its total energy use. The total annual energy savings are estimated to be over \$273,700 and the annual GHG savings are approximately 356,000 kg.

St Lawrence Market South can save an average of 31% of its total electricity use (30% Electric Baseload, 56% Electric Cooling and 0% Electric Heating). The total annual electricity savings are estimated to be approximately \$250,000.

St Lawrence Market South can save an average of 45% of its total gas use, and all of the savings are in Gas Baseload. The total annual gas savings are estimated to be approximately \$22,000.

St Lawrence Market South will undergo a Building Performance Audit (see the Implementation Plan for further details). For a complete description of the Building Performance Audit, refer to Appendix A.

See Appendix B for the associated energy savings potential by energy use component.

The largest percentage reductions for this facility can be found in Gas Baseload and Electric Cooling. After the implementation of the proposed measures, this facility is eligible to receive over \$150,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Assessment

There are 9 cultural facilities with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 37% of the total energy savings for all 20 cultural facilities can be found in these 9 facilities.

These 9 cultural facilities can save an average of 42% of their total energy use. The total annual energy savings are estimated to be over \$157,000 and individual building annual savings range from approximately \$5,100 to almost \$34,000. The annual GHG savings are approximately 522,600 kg.

These 9 cultural facilities can save an average of 26% of their total electricity use (35% Electric Baseload, 60% Electric Cooling and 46% Electric Heating). The total annual electricity savings are estimated to be approximately \$95,000 and individual building annual savings range from just under \$10,000 to over \$30,000.

These 9 cultural facilities can save an average of 50% of their total gas use (41% Gas Baseload and 58% Gas Heating). The total annual gas savings are estimated to be approximately \$62,000 and individual building annual savings range from under \$1,000 to over \$30,000.

These 9 facilities will undergo an Energy Assessment with highest potential cultural facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 9 cultural facilities and their associated energy savings potential by energy use component.

The largest percentage reductions for this group of 9 cultural facilities can be found in Electric Cooling and Gas Heating. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these cultural facilities are eligible to receive over \$78,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.3 Energy Savings Checklist

There are 10 cultural facilities with less than \$5,000 in savings potential. Less than 4% of the total energy savings for all 20 cultural facilities can be found in these 10 facilities.

These 10 cultural facilities can save an average of 19% of their total energy use. The total annual energy savings are estimated to be approximately \$17,000 and individual building annual savings range from approximately \$300 to almost \$5,000. The annual GHG savings are approximately 47,500 kg.

These 10 cultural facilities can save an average of 13% of their total electricity use (13% Electric Baseload, 22% Electric Cooling and 1% Electric Heating). The total annual electricity savings are estimated to be approximately \$11,600 and individual building annual savings range from under \$300 to over \$4,800.

These 10 cultural facilities can save an average of 23% of their total gas use (41% Gas Baseload and 14% Gas Heating). The total annual gas savings are estimated to be approximately \$5,300 and individual building annual savings range from under \$100 to over \$1,500.

These 10 facilities will undergo a checklist approach with highest potential cultural facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 10 cultural facilities and their associated energy savings potential by energy use component.

The largest percentage reductions for this group of 10 cultural facilities can be found in Gas Baseload and Electric Cooling.

The energy savings checklist will be used by the Division Champion for the cultural facilities in conjunction with the building operator and/or service contractor for each cultural facility. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### 3.3 Implementation Budget

Table 8 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 20 facilities. The total costs to implement the energy management and retrofit plan for cultural facilities is estimated to be \$2,156,057. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                     |
|----------------------------------|---------------------|
| Building Performance Audit (BPA) | \$ 7,500            |
| Energy Assessment                | \$ 6,750            |
| Checklist                        | \$ 1,500            |
| Implementation                   | \$ 2,140,307        |
| <b>Total</b>                     | <b>\$ 2,156,057</b> |

Table 62: Total Budget - Energy Management and Retrofit Plan

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 9 and Figure 5 below.



The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from the Building Performance Audit will occur in Year 1 and the implementation of these measures will occur in Year 2. Identification of measures from Energy Assessments will begin in Year 1, with all 9 Energy Assessments completed by the end of Year 5. The implementation of these measures will begin in Year 2, and will be completed by the end of Year 6. Identification of measures from the Checklists will begin in Year 2, with all 10 Checklists completed by the end of Year 6. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$1,577,884. The cumulative net cash flow becomes positive in Year 8.

The implementation plan includes the following assumptions:

- Approximately 77% of the project budget will be spent in the first 5 years, and the other 23% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 77% of facilities will be retrofitted in the first 5 years and 23% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.
- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1    | Year 2      | Year 3      | Year 4      | Year 5      | Year 6      | Year 7      | Year 8     | Year 9     | Year 10       | Totals       |
|---|-----------|-------------|-------------|-------------|-------------|-------------|-------------|------------|------------|---------------|--------------|
| High Potential - Building Performance Audit                           | 1         | 0           | 0           | 0           | 0           | 0           | 0           | 0          | 0          | 0             | 1            |
| Mid Potential - Energy Assessment                                     | 2         | 2           | 2           | 2           | 1           | 0           | 0           | 0          | 0          | 0             | 9            |
| Low Potential - Checklist   | 0         | 3           | 3           | 3           | 1           | 0           | 0           | 0          | 0          | 0             | 10           |
| Assessment Costs  | \$ 9,000  | \$ 1,968    | \$ 1,978    | \$ 1,987    | \$ 916      | \$ -        | \$ -        | \$ -       | \$ -       | \$ -          | \$ 15,848    |
| Implementation Costs  | \$ -      | \$ 830,500  | \$ 414,250  | \$ 422,535  | \$ 430,986  | \$ 192,556  | \$ -        | \$ -       | \$ -       | \$ -          | \$ 2,290,828 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 900    | \$ 83,247   | \$ 41,623   | \$ 42,452   | \$ 43,190   | \$ 19,256   | \$ -        | \$ -       | \$ -       | \$ -          | \$ 230,668   |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -      | \$ 41,525   | \$ 62,238   | \$ 83,364   | \$ 104,914  | \$ 114,541  | \$ 114,541  | \$ 114,541 | \$ 114,541 | \$ 114,541.39 |              |
| Annual Costs  | \$ 9,900  | \$ 957,240  | \$ 520,088  | \$ 550,339  | \$ 580,005  | \$ 326,353  | \$ 114,541  | \$ 114,541 | \$ 114,541 | \$ 114,541    | \$ 3,402,091 |
| Estimated Achieved Annual Savings                                     |           | \$ 94,968   | \$ 302,553  | \$ 482,577  | \$ 548,299  | \$ 595,158  | \$ 630,392  | \$ 661,912 | \$ 695,008 | \$ 729,758    | \$ 4,740,624 |
| Estimated Incentives  | \$ -      | \$ 185,248  | \$ 33,944   | \$ 12,681   | \$ 7,479    | \$ -        | \$ -        | \$ -       | \$ -       | \$ -          | \$ 239,352   |
| Annual Savings and Incentives   | \$ -      | \$ 280,216  | \$ 336,496  | \$ 495,258  | \$ 555,778  | \$ 595,158  | \$ 630,392  | \$ 661,912 | \$ 695,008 | \$ 729,758    | \$ 4,979,975 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       |           | -\$ 396     | -\$ 27,477  | -\$ 34,821  | -\$ 37,024  | -\$ 37,993  | -\$ 27,241  | -\$ 6,607  | \$ -       | \$ -          | -\$ 171,558  |
| Net Cash Flow incl borrowing costs                                    | -\$ 9,900 | -\$ 677,420 | -\$ 211,069 | -\$ 89,902  | -\$ 61,252  | \$ 230,812  | \$ 488,610  | \$ 540,764 | \$ 580,466 | \$ 615,216    | \$ 1,406,326 |
| Cumulative Net Cash Flow  | -\$ 9,900 | -\$ 686,924 | -\$ 870,516 | -\$ 925,597 | -\$ 949,825 | -\$ 681,020 | -\$ 165,169 | \$ 382,202 | \$ 962,668 | \$ 1,577,884  |              |

Table 63: Cash Flow for 10-Year Implementation Plan




Figure 39: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above) and facilities of the same type from other municipalities. Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment.

Electric Baseload for cultural facilities is determined as the average kWh/day for March, April, October and November multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from May to September, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-

standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

### Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

### Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>))+ Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Cultural facilities
- Performing arts facilities

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 2.25                    | 100%       | 6.5           | 2.9                     |                                     |
| Mechanical   | 1.50                    | 30%        | 6             | 0.6                     | 0.7                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 0%         | 10            |                         | 0.2                                 |
| Process      | 0.15                    | 0%         | 5             |                         | 0.1                                 |
| <b>Total</b> | <b>4.65</b>             |            | <b>6.7</b>    | <b>3.77</b>             | <b>1.02</b>                         |

**Table 64: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls. They also include lighting audits.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process (domestic hot water) measures include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building's existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building
- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### Initial Energy Targets

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and

low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.

## 5 Appendix B - Cultural Facilities

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 20 cultural facility buildings included in this report and Plan.

| Building                         | Address             | Building Area (ft <sup>2</sup> ) |
|----------------------------------|---------------------|----------------------------------|
| Allan Gardens                    | 160 Gerrard St E.   | 25,177                           |
| Casa Loma Building               | 1 Austin Terrace    | 83,938                           |
| Casa Loma Hunt Lodge             | 328 Walmer Rd       | 4,381                            |
| Civic Garden Centre              | 755 Lawrence Ave E  | 36,952                           |
| Colborne Lodge (inc. Coachhouse) | 1 Colborne Lodge Dr | 8,547                            |
| Don Valley Brickwork             | 550 Bayview Ave     | 186,239                          |
| Edwards Gardens                  | 755 Lawrence Ave E  | 10,021                           |
| Gibson House Museum              | 5172 Yonge St       | 8,364                            |
| Historic Fort York               | 100 Garrison Rd     | 22,819                           |
| Lakeshore Assembly Hall          | 1 Colonel Samuel Dr | 14,596                           |
| Mackenzie House Museum           | 82 Bond St          | 2,573                            |
| Martin Grove House / Bungalow    | 410 Martin Grove Rd | 18,140                           |
| Montgomery's Inn                 | 4709 Dundas St W    | 7,642                            |
| Neilson Pk Creative Arts         | 56 Neilson Dr       | 12,346                           |
| Riverdale Farm                   | 201 Winchester St   | 23,713                           |
| Spadina House Museum             | 285 Spadina Rd      | 27,588                           |
| St Lawrence Market South         | 95 Front St E       | 99,115                           |
| William Goodwin House            | 355 Lesmill Rd      | 818                              |
| Zion Methodist Church            | 1650 Finch Ave E    | 2,002                            |
| Zion School House                | 1091 Finch Ave E    | 1,582                            |

Table 65: Cultural Facility Building Information

### 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 20 cultural facility buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| Building                      | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|-------------------------------|---|--|---|
| Martin Grove House / Bungalow | 0.52  | 0.91   | 1.43  |
| Don Valley Brickwork          | 0.96  | 1.21   | 2.18  |
| Riverdale Farm                | 3.60  | 5.05   | 8.65  |



|                                  |       |       |       |
|----------------------------------|-------|-------|-------|
| Historic Fort York               | 11.47 | 0.00  | 11.47 |
| Gibson House Museum              | 11.89 | 0.00  | 11.89 |
| Spandina House Museum            | 3.48  | 18.73 | 22.21 |
| Casa Loma Building               | 9.07  | 16.67 | 25.74 |
| Neilson Pk Creative Arts         | 14.17 | 12.12 | 26.29 |
| Casa Loma Hunt Lodge             | 0.42  | 26.46 | 26.88 |
| Civic Garden Centre              | 12.18 | 15.46 | 27.65 |
| Colborne Lodge (inc. Coachhouse) | 14.62 | 15.92 | 30.53 |
| Zion School House                | 15.73 | 20.60 | 36.33 |
| Montgomery's Inn                 | 33.06 | 5.76  | 38.83 |
| Edwards Gardens                  | 5.73  | 34.48 | 40.22 |
| Zion Methodist Church            | 10.82 | 32.72 | 43.54 |
| Lakeshore Assembly Hall          | 24.03 | 23.90 | 47.93 |
| Mackenzie House Museum           | 13.22 | 37.13 | 50.35 |
| Allan Gardens                    | 7.93  | 61.02 | 68.95 |
| St Lawrence Market South         | 54.63 | 19.54 | 74.16 |
| William Goodwin House            | 38.84 | 58.02 | 96.85 |

Table 66: Cultural Facility 2012 Energy Intensity

### 5.3 Target-setting Method and Metrics

3 cultural facilities were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.

| Facility              | Days in 2012                          | Energy type     |
|-----------------------|---------------------------------------|-----------------|
| Zion Methodist Church | Huge negative consumption in February | Electricity     |
| Casa Loma Hunt Lodge  |                                       | 396 Electricity |
| Casa Loma Building    |                                       | 396 Electricity |

Table 67: Excluded Facilities

After excluding these 3 facilities, 17 City of Toronto facilities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.

The red line on each chart indicates the top quartile for each component which is the target for that component.




Figure 40: 2012 Electric Baseload Intensity Benchmark

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for cultural facilities ranges from 0.5 to 54.7 ekWh/ft<sup>2</sup> and the top-quartile is 8.1 ekWh/ft<sup>2</sup>.




Figure 41: 2012 Electric Cooling Intensity Benchmark

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for cultural facilities ranges from 0.4 to 3.1 ekWh/ft<sup>2</sup> and the top-quartile is 0.7 ekWh/ft<sup>2</sup>.




Figure 42: 2012 Electric Heating Intensity Benchmark

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for cultural facilities ranges from 0.3 to 7.9 ekWh/ft<sup>2</sup> and the top-quartile is 0.4 ekWh/ft<sup>2</sup>.





Figure 43: 2012 Gas Baseload Intensity Benchmark

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for cultural facilities ranges from 0.9 to 8.8 ekWh/ft<sup>2</sup> and the top-quartile is 2.2 ekWh/ft<sup>2</sup>.



**Figure 44: 2012 Gas Heating Intensity Benchmark**

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for cultural facilities ranges from 4.8 to 57.9 ekWh/ft<sup>2</sup> and the top-quartile is 11.96 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of cultural facilities, the factors are % of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps and % of the area served by electric air conditioning.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 1 High-Savings Potential Cultural Facility

Buildings are sorted by total annual savings potential, starting with the highest saving potential buildings.

There is one cultural facility with over \$100,000 in annual savings potential.

High savings
Moderate savings
Low savings

| Operation name                        | Electricity Savings Potential |         |         |       |           | Gas Savings Potential |         |       |           | Total Energy Savings Potential |           | Incentives  |          | Indoor Area | GHG Emissions |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|-----------|--------------------------------|-----------|-------------|----------|-------------|---------------|
|                                       | Average %                     |         |         |       | \$/yr     | Average %             |         |       | \$/yr     | Avg %                          | \$/yr     | Electricity | Gas      |             |               |
|                                       | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |           |                                |           |             |          |             |               |
| High potential savings facilities (1) | 30%                           | 56%     | 00%     | 31%   | \$251,868 | 100%                  | 00%     | 45%   | \$ 21,870 | 35%                            | \$273,738 | \$143,925   | \$ 8,412 | 99,115      | 355,950       |
| St Lawrence Market South              | 30%                           | 56%     |         | 31%   | \$251,868 | 100%                  |         | 45%   | \$ 21,870 | 35%                            | \$273,738 | \$143,925   | \$ 8,412 | 99,115      | 355,950       |

**Table 68: Savings Potential for 1 High Savings Potential Cultural Facility**

### Savings Potential by Energy Use Component for the 9 Mid-Savings Potential Cultural Facilities

Buildings are sorted by total annual savings potential, starting with the highest saving potential buildings.

There are 9 cultural facilities with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

High savings
Moderate savings
Low savings

| Operation name                       | Electricity Savings Potential |         |         |       |           | Gas Savings Potential |         |       |           | Total Energy Savings Potential |           | Incentives  |          | Indoor Area | GHG Emissions |
|--------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|-----------|--------------------------------|-----------|-------------|----------|-------------|---------------|
|                                      | Average %                     |         |         |       | \$/yr     | Average %             |         |       | \$/yr     | Avg %                          | \$/yr     | Electricity | Gas      |             |               |
|                                      | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |           |                                |           |             |          |             |               |
| Mid-potential savings facilities (9) | 35%                           | 60%     | 46%     | 26%   | \$ 95,352 | 41%                   | 58%     | 50%   | \$ 61,958 | 42%                            | \$157,310 | \$ 54,487   | \$23,830 | 237,280     | 522,684       |
| Lakeshore Assembly Hall              | 63%                           | 43%     | 63%     | 62%   | \$ 30,379 | 0%                    | 44%     | 40%   | \$ 3,510  | 51%                            | \$ 33,889 | \$ 17,359   | \$ 1,350 | 14,596      | 49,237        |
| Allan Gardens                        |                               |         |         | 0%    | \$ -      | 38%                   | 85%     | 82%   | \$ 31,811 | 72%                            | \$ 31,811 | \$ -        | \$12,235 | 25,177      | 229,896       |
| Montgomery's Inn                     | 70%                           |         | 66%     | 69%   | \$ 25,470 |                       |         | 0%    | \$ -      | 59%                            | \$ 25,470 | \$ 14,554   | \$ -     | 7,642       | 20,012        |
| Civic Garden Centre                  | 27%                           | 75%     |         | 33%   | \$ 21,117 |                       | 18%     | 17%   | \$ 2,400  | 24%                            | \$ 23,517 | \$ 12,067   | \$ 923   | 36,952      | 33,935        |
| Casa Loma Building                   |                               |         |         | 0%    | \$ -      |                       |         | 33%   | \$ 11,534 | 33%                            | \$ 11,534 | \$ -        | \$ 4,436 | 83,938      | 83,354        |
| Historic Fort York                   | 30%                           |         |         | 28%   | \$ 11,134 |                       |         |       | \$ -      | 28%                            | \$ 11,134 | \$ 6,362    | \$ -     | 22,819      | 8,748         |
| Colborne Lodge (inc. Coachhouse)     | 36%                           | 100%    | 35%     | 42%   | \$ 7,252  |                       | 25%     | 25%   | \$ 865    | 33%                            | \$ 8,117  | \$ 4,144    | \$ 333   | 8,547       | 11,949        |
| Spandina House Museum                |                               |         |         | 0%    | \$ -      | 100%                  | 45%     | 52%   | \$ 6,722  | 44%                            | \$ 6,722  | \$ -        | \$ 2,585 | 27,588      | 48,577        |
| Edwards Gardens                      |                               |         |         | 0%    | \$ -      | 6%                    | 63%     | 59%   | \$ 5,116  | 50%                            | \$ 5,116  | \$ -        | \$ 1,968 | 10,021      | 36,976        |

**Table 69: Savings Potential for 9 Medium Savings Potential Cultural Facilities**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

### Savings Potential by Energy Use Component for the 10 Low-Savings Potential Cultural Facilities

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 10 cultural facilities with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

High savings
Moderate savings
Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |        |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|----------|--------------------------------|------------------------|--------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           |         | \$/yr | Avg %                          | \$/yr | Electricity | Gas      |                                |                        |        |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load | Heating |       |                                |       |             |          | Total                          |                        |        |
| Low potential savings facilities (10) | 13%                           | 22%     | 01%     | 13%   | \$ 11,647             | 41%       | 14%     | 23%   | \$ 5,313                       | 19%   | \$ 16,960   | \$ 6,656 | \$ 2,043                       | 260,157                | 47,548 |
| Neilson Pk Creative Arts              | 22%                           |         |         | 20%   | \$ 4,861              | 100%      |         | 2%    | \$ 73                          | 12%   | \$ 4,934    | \$ 2,778 | \$ 28                          | 12,346                 | 4,345  |
| William Goodwin House                 | 77%                           | 40%     | 56%     | 75%   | \$ 3,318              |           | 78%     | 75%   | \$ 892                         | 75%   | \$ 4,209    | \$ 1,896 | \$ 343                         | 818                    | 9,050  |
| Mackenzie House Museum                | 32%                           |         |         | 30%   | \$ 1,377              | 64%       | 61%     | 62%   | \$ 1,477                       | 53%   | \$ 2,854    | \$ 787   | \$ 568                         | 2,573                  | 11,757 |
| Casa Loma Hunt Lodge                  |                               |         |         | 0%    | \$ -                  |           |         | 55%   | \$ 1,596                       | 55%   | \$ 1,596    | \$ -     | \$ 614                         | 4,381                  | 11,533 |
| Zion School House                     | 33%                           |         | 14%     | 32%   | \$ 1,094              | 100%      | 42%     | 42%   | \$ 344                         | 37%   | \$ 1,438    | \$ 625   | \$ 132                         | 1,582                  | 3,345  |
| Zion Methodist Church                 |                               |         |         | 9%    | \$ 267                |           |         | 57%   | \$ 932                         | 57%   | \$ 1,199    | \$ 152   | \$ 358                         | 2,002                  | 6,945  |
| Gibson House Museum                   |                               | 100%    |         | 3%    | \$ 423                |           |         |       | \$ -                           | 3%    | \$ 423      | \$ 242   | \$ -                           | 8,364                  | 333    |
| Don Valley Brickwork                  |                               | 100%    |         | 1%    | \$ 307                |           |         | 0%    | \$ -                           | 1%    | \$ 307      | \$ 175   | \$ -                           | 186,239                | 241    |
| Riverdale Farm                        |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -     | \$ -                           | 23,713                 | 0      |
| Martin Grove House / Bungalow         |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -     | \$ -                           | 18,140                 | 0      |

**Table 70: Savings Potential for 10 Low-Savings Potential Cultural Facilities**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as (Actual Energy Use – Target Energy Use)/Actual Energy Use and \$/year savings for each component are calculated as (Actual Energy Use - Target Energy Use) \* utility company rates \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Ambulance Stations and Associated Offices/Facilities

---

## Table of Contents

|       |   |     |
|-------|---|-----|
| 1.    | Benchmarking and Conservation Potential .....   | 148 |
| 1.1   | Energy Use and Building Characteristics.....  | 148 |
| 1.1.1 | Building Characteristics.....   | 148 |
| 1.1.2 | Summary of Energy Use and Costs .....   | 148 |
| 1.2   | Energy Targets.....   | 150 |
| 1.3   | Savings Potential.....  | 151 |
| 2     | Conservation Measures and Budget.....   | 153 |
| 2.1   | Previous Energy Efficiency Initiatives.....   | 153 |
| 2.2   | Proposed Energy Efficiency Measures .....   | 153 |
| 3     | Energy Management and Retrofit Plan .....   | 160 |
| 3.1   | Implementation Costs and Modeled Savings .....  | 160 |
| 3.2   | Implementation Process and Tools – Determining the Specific Measures for Each Building .. | 160 |
| 3.2.1 | Building Performance Audit.....   | 161 |
| 3.2.2 | Energy Assessment .....   | 162 |
| 3.2.3 | Energy Savings Checklist .....  | 162 |
| 3.3   | Implementation Budget.....  | 163 |
| 3.4   | 10-Year Implementation Plan .....   | 163 |
| 4     | Appendix A.....   | 166 |
| 4.1   | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....     | 166 |
| 4.2   | Determining Energy Use Components.....  | 166 |
| 4.3   | Determining Targets .....   | 166 |
| 4.4   | Calculating Potential Savings .....   | 168 |
| 4.5   | Implementation Costs by Measure Type and Modeled Savings.....                             | 168 |
| 4.6   | Assessment Tools.....   | 169 |
| 5     | Appendix B - Ambulance stations .....   | 171 |
| 5.1   | Buildings and Building Characteristics .....  | 171 |
| 5.2   | Energy Use Intensities.....   | 171 |
| 5.3   | Target-setting Method and Metrics.....  | 172 |



## List of Tables

|  |     |
|--|-----|
| Table 71: Energy Use and Costs for 24 City of Toronto Ambulance Stations .....           | 148 |
| Table 72: Top Quartile Targets.....  | 151 |
| Table 73: Savings Potential Summary .....  | 152 |
| Table 74: Savings Potential based on Energy Use Component for 24 Ambulance Stations..... | 152 |
| Table 75: 2008 Ambulance Headquarters Project Estimated Project Costs and Savings .....  | 153 |
| Table 72: Energy Saving Measures for Ambulance Stations.....                             | 158 |
| Table 77: Proposed Renewable Energy Systems for EMS Facilities.....                      | 159 |
| Table 78: Estimated Implementation Costs and Modeled Savings .....                       | 160 |
| Table 79: Assessment Tools Used to Determine Specific Energy-saving Measures .....       | 161 |
| Table 80: Total Budget - Energy Management and Retrofit Plan .....                       | 163 |
| Table 81: Cash Flow for 10-Year Implementation Plan .....                                | 165 |
| Table 82: Implementation Costs by Measure Type .....                                     | 169 |
| Table 83: Ambulance Station Building Information.....                                    | 171 |
| Table 84: Ambulance Station 2012 Energy Intensity .....                                  | 172 |
| Table 85: Excluded Facilities .....  | 172 |
| Table 86: Savings Potential for 1 High Savings Potential Ambulance Station .....         | 176 |
| Table 87: Savings Potential for 5 Medium Savings Potential Ambulance Stations .....      | 176 |

## List of Figures

|   |     |
|---|-----|
| Figure 45: 2012 Energy Use and Cost Breakdown for 24 City of Toronto Ambulance Stations ..... | 149 |
| Figure 46: 2012 Total Energy Intensity Benchmark .....  | 149 |
| Figure 47: 2012 Total Electricity Intensity Benchmark .....                                   | 150 |
| Figure 48: 2012 Total Gas Intensity Benchmark .....   | 150 |
| Figure 49: Cash Flow for 10-Year Implementation Plan .....                                    | 165 |
| Figure 50: 2012 Electric Baseload Intensity Benchmark.....                                    | 173 |
| Figure 51: 2012 Electric Cooling Intensity Benchmark .....                                    | 173 |
| Figure 52: 2012 Electric Heating Intensity Benchmark.....                                     | 174 |
| Figure 53: 2012 Gas Baseload Intensity Benchmark.....   | 174 |
| Figure 54: 2012 Gas Heating Intensity Benchmark.....  | 175 |

## 1. Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 24 ambulance stations in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B. The majority of the buildings are ambulance stations, but also included are the Ambulance Headquarters and associated office type facilities.

The total area for all of the buildings is 216,311 ft<sup>2</sup>. The ambulance stations range in size from just over 1,500 ft<sup>2</sup> to over 100,000 ft<sup>2</sup> (Ambulance Headquarters).

None of the ambulance stations (or associated offices/facilities) are equipped with renewable energy systems.

The majority of the ambulance stations have air conditioning serving approximately 50% of the building. Only the Ambulance Headquarters has air-conditioning serving 100% of the building. Only one facility (EMS station 47) is fully served by electric heat. Even though they are not reported to be using electric heat, the electricity profiles show that the majority of the other ambulance stations have significant additional use of electricity in winter months. While some of this usage may be due to longer hours of lighting or electric motors, use of electric heaters is indicated and should be further explored. Identifying and limiting electricity use associated with space heating will be one of the first measures recommended in the plan (see section on proposed energy efficiency measures). None of the ambulance stations are served by ground or water source heat pumps.

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use from monthly utility bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities. Total energy use and costs are summarized below.

|                                    | 2012 Energy Use |                  |
|------------------------------------|-----------------|------------------|
|                                    | Unit            | \$               |
| <b>Electricity (kWh)</b>           | 5,149,579       | \$720,941        |
| <b>Natural Gas (m<sup>3</sup>)</b> | 404,139         | \$105,076        |
| <b>Total</b>                       |                 | <b>\$826,017</b> |

**Table 71: Energy Use and Costs for 24 City of Toronto Ambulance Stations**




Figure 45: 2012 Energy Use and Cost Breakdown for 24 City of Toronto Ambulance Stations

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the buildings. Total energy use intensity ranges from less than 20 to over 80 ekWh/ft<sup>2</sup>. The ranges for electricity and gas use per ft<sup>2</sup> are even greater. Note that no 2012 data was available for EMS Station 54 and therefore it was not analyzed and reported on.

The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 46: 2012 Total Energy Intensity Benchmark




Figure 47: 2012 Total Electricity Intensity Benchmark




Figure 48: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for ambulance stations are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each ambulance station to achieve its target over the duration of the ECDM Plan.

| Energy type  | Component | Value | Unit                       |
|--------------|-----------|-------|----------------------------|
| Electricity  | Base      | 7.7   | kWh/ft <sup>2</sup> /year  |
|              | Cooling   | 0.3   | kWh/ft <sup>2</sup> /year  |
|              | Heating   | 2.3   | kWh/ft <sup>2</sup> /year  |
|              | Total     | 10.3  | kWh/ft <sup>2</sup> /year  |
| Gas          | Base      | 0.9   | ekWh/ft <sup>2</sup> /year |
|              | Heating   | 15.3  | ekWh/ft <sup>2</sup> /year |
|              | Total     | 16.2  | ekWh/ft <sup>2</sup> /year |
| Total energy | Total     | 26.5  | ekWh/ft <sup>2</sup> /year |

**Table 72: Top Quartile Targets**

The data set for target-setting is made up of the 20 ambulance stations with complete and reliable data, all of which are City of Toronto buildings, from the larger group included in this Plan. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), and % of the area which is air conditioned. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each ambulance station. The total savings potential for each ambulance station is determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 24 ambulance stations are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

The Ambulance Headquarters is the only building with annual savings potential greater than \$100,000. 5 ambulance stations have annual savings potential between \$5,000 and \$100,000 and 18 ambulance stations have annual savings potential less than \$5,000 (see Table 873).

The total annual savings potential for the 24 buildings is \$347,515 (\$324,524 for electricity and \$22,991 for gas) with an average total energy savings of 35%.

For the 1 high-potential savings facility (Ambulance Headquarters), the total annual savings potential is \$270,876 (\$262,619 for electricity and \$8,258 for gas) with an average total energy savings of 38%.

For the 5 mid-potential savings facilities, the total annual savings potential is \$50,181 (\$44,246 for electricity and \$5,935 for gas) with an average total energy savings of 41%.

For the 18 low-potential savings facilities, the total annual savings potential is \$26,457 (\$17,659 for electricity and \$8,798 for gas) with an average total energy savings of 21%.


| Operation name                        | Electricity Savings Potential |            |            |            | \$/yr            | Gas Savings Potential |            |            | \$/yr            | Total Energy Savings Potential |                  | Incentives       |                 | Indoor Area<br>ft² | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|------------|------------|------------|------------------|-----------------------|------------|------------|------------------|--------------------------------|------------------|------------------|-----------------|--------------------|------------------------|
|                                       | Average %                     |            |            |            |                  | Base-load             | Average %  |            |                  | Avg %                          | \$/yr            | Electricity      | Gas             |                    |                        |
|                                       | Base-load                     | Cooling    | Heating    | Total      |                  |                       | Base-load  | Heating    |                  |                                |                  |                  |                 |                    |                        |
| <b>TOTAL: 24 facilities</b>           | <b>46%</b>                    | <b>54%</b> | <b>21%</b> | <b>45%</b> | <b>\$324,524</b> | <b>52%</b>            | <b>19%</b> | <b>22%</b> | <b>\$ 22,991</b> | <b>35%</b>                     | <b>\$347,515</b> | <b>\$185,442</b> | <b>\$ 8,843</b> | <b>216,311</b>     | <b>421,137</b>         |
| High potential savings facilities (1) | 50%                           | 54%        | 00%        | 50%        | \$262,619        | 51%                   | 13%        | 17%        | \$ 8,258         | 38%                            | \$270,876        | \$150,068        | \$ 3,176        | 101,719            | 266,020                |
| Mid-potential savings facilities (5)  | 53%                           | 68%        | 16%        | 50%        | \$ 44,246        | 58%                   | 31%        | 33%        | \$ 5,935         | 41%                            | \$ 50,181        | \$ 25,283        | \$ 2,283        | 34,584             | 77,659                 |
| Low potential savings facilities (18) | 16%                           | 37%        | 22%        | 16%        | \$ 17,659        | 50%                   | 23%        | 23%        | \$ 8,798         | 21%                            | \$ 26,457        | \$ 10,091        | \$ 3,384        | 80,008             | 77,459                 |

**Table 73: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 884 below shows the total potential savings for all 24 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components  | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|--|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft²)  | 22.5        | 12.1        | 46%                 | \$ 303,514           |
| Electric Cooling (kWh/ft²)   | 1.1         | 0.5         | 54%                 | \$ 14,370            |
| Electric Heating (kWh/ft²)   | 2.1         | 1.6         | 21%                 | \$ 6,092             |
| Total Electricity (kWh/ft²) for facilities w/o component intensities | 8.4         | 7.9         | 6%                  | \$ 548               |
| Gas Baseload (ekWh/ft²)  | 1.6         | 0.8         | 52%                 | \$ 4,269             |
| Gas Heating (ekWh/ft²)   | 17.9        | 14.4        | 19%                 | \$ 18,230            |
| Total Gas (ekWh/ft²) for facilities w/o component intensities        | 16.5        | 14.1        | 15%                 | \$ 492               |
| <b>Total Energy (ekWh/ft²)</b>                                       | <b>43.1</b> | <b>28.2</b> | <b>35%</b>          | <b>\$ 347,515</b>    |



**Table 74: Savings Potential based on Energy Use Component for 24 Ambulance Stations**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electrical Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and some of them will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2008, the City of Toronto undertook a study to identify building improvement measures that would improve energy and water efficiency and reduce the operating cost and environmental impact of the Ambulance Headquarters building.

Table 85 below summarizes the estimated overall project costs, savings and estimated energy reduction as a result of the 2008 project.

| Project Name & Year | Num. of Bldgs | Total Floor Area (m2) | Project Cost & Savings (estimated) |                 |                    |                            | Estimated Energy Reduction |                         |                        |                        |
|---------------------|---------------|-----------------------|------------------------------------|-----------------|--------------------|----------------------------|----------------------------|-------------------------|------------------------|------------------------|
|                     |               |                       | Retrofit Cost                      | Total \$Savings | Total ekWh Savings | Total CO2 Savings (tonnes) | Payback                    | Electricity Savings kWh | Electricity Savings kW | Natural Gas Savings m3 |
| EMS Station 2008    | 1             | 9,450                 | \$1,195,732                        | \$187,744       | 2,301,783          | 531                        | 6.4                        | 1,689,234               | 192                    | 59,231                 |

**Table 75: 2008 Ambulance Headquarters Project Estimated Project Costs and Savings**

The types of measures implemented at the Ambulance Headquarters building included the following:

- Lighting Retrofits
- Minor Mechanical Modifications
- Automated Building Controls
- Power Factor Corrections
- Variable Speed Drives

### 2.2 Proposed Energy Efficiency Measures

Table 6 shows the full range of possible energy efficiency measures for the entire portfolio of ambulance stations. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the facilities indicate that the largest percentage reductions will come from measures associated with electric cooling and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).



| Electric Baseload Measures | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility |
|----------------------------|------------------------|--------------------------|-------------|----------|-----------------------|----------------|
|----------------------------|------------------------|--------------------------|-------------|----------|-----------------------|----------------|

**ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent**

|     |  |   |   |   |        |                 |                    |
|-----|--|---|---|---|--------|-----------------|--------------------|
| B1  | Turn off machines, office and kitchen equipment when not needed                                  | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B2  | Unplug machines, office and kitchen equipment if not actively used                               | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B3  | Turn off computer monitors when not in use   | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B4  | Enable ENERGY STAR power settings on your computer   | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B5  | Unplug chargers when not in use  | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B6  | Turn off lights when areas not in use  | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| B7  | Make use of natural light instead of turning on lights where possible                            | 4 | 4 | 8 | Year 1 | Annual Review   | Building Occupants |
| M1  | Optimize operating schedules for fans and pumps  | 3 | 4 | 7 | Year 2 | Seasonal Review |                    |
| M2  | Test and adjust ventilation systems to reduce fan power  | 3 | 4 | 7 | Year 2 | Seasonal Review |                    |
| EL4 | Install power factor correction  | 3 | 4 | 7 | Year 2 | 15+             |                    |
| L1  | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L2  | Install motion sensors in washrooms/occasional use spaces to shut off lights when unoccupied     | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L3  | Install photo-sensors and/or a timer on outdoor and daylight interior area lighting              | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L4  | Replace HID lighting with high efficiency fluorescent  | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L5  | Replace outdoor lights and signage with high efficiency fixtures                                 | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L6  | Replace festive lighting with LED  | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| L7  | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1 | 4 | 5 | Year 3 | 15+             |                    |
| EL1 | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1 | 4 | 5 | Year 3 | 8 to 12         |                    |
| EL2 | Replace computers with ENERGY STAR rated units   | 1 | 4 | 5 | Year 3 | 4 to 6          |                    |
| EL3 | Install controls on vending machines   | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |
| EL5 | Submeter data and call centres   | 1 | 4 | 5 | Year 3 | Seasonal Review |                    |
| M3  | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1 | 4 | 5 | Year 3 | 10 to 20        |                    |
| M4  | Convert electric hot water heaters to natural gas  | 1 | 4 | 5 | Year 3 | 10 to 15        |                    |

Other: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Electric Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes</b> |  |                        |                          |             |          |                       |                    |
| B8   | Adjust blinds (to retain heat in winter)   | 4                      | 2                        | 6           | Year 1   | annual review         | Building Occupants |
| B9   | Avoid use of electric heaters  | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B10  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| M8   | Control fan coil and entrance heaters to optimize run-times                                | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M9   | Evaluate conversion from electric heating to natural gas                                   | 2                      | 2                        | 4           | Year 2   | n/a                   |                    |
| M5   | Install snow sensors to control the snow-melting system                                    | 1                      | 2                        | 3           | Year 4   | seasonal review       |                    |
| M6   | Upgrade base building heating system to avoid use of electric heaters                      | 1                      | 2                        | 3           | Year 4   | seasonal review       |                    |
| M7   | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1                      | 2                        | 3           | Year 4   | seasonal review       |                    |
| M10  | Install controls on vehicle plug-in heaters  | 1                      | 2                        | 3           | Year 4   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Electric Cooling Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes</b> |  |                        |                          |             |          |                       |                    |
| B11  | Winterize room air-conditioners  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B12  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B13  | Only cool rooms that are being used  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B14  | Install and use energy efficient ceiling fans  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B15  | Close blinds (to shade space from direct sunlight)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B16  | Install window film, solar screens or awnings on south and west facing windows               | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M11  | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M13  | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M14  | Test and tune the air conditioning units   | 3                      | 4                        | 7           | Year 2   | 3                     |                    |
| M12  | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other:   |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round |  |                        |                          |             |          |                       |                    |
| B17   | Optimize dishwasher operation (only run when full) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| P1  | Optimize DHW temperature control                   | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| P3  | Test and tune DHW boiler efficiency                | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M17   | Investigate and repair possible gas leaks          | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P2  | Implement DHW circulation pump control             | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P4  | Install low flow showerheads and faucet aerators   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| M15   | Insulate DHW tanks and distribution piping         | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M16   | Replace DHW boilers with more efficient models     | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other: _____  |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS HEATING - refers to the additional energy used in winter for heating and humidification |  |                        |                          |             |          |                       |                    |
| B18   | Check and clear baseboard heaters of obstructions  | 4                      | 1                        | 5           | Year 1   |                       | Building Occupants |
| B19   | Adjust blinds (to retain heat in winter)   | 4                      | 1                        | 5           | Year 1   |                       | Building Occupants |
| B20   | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 1                        | 5           | Year 1   |                       | Building Occupants |
| M19   | Optimize operating periods of ventilation systems supplying heated spaces                  | 2                      | 1                        | 3           | Year 2   | seasonal review       |                    |
| M20   | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 1                        | 4           | Year 2   | seasonal review       |                    |
| M23   | Test and tune boiler efficiency  | 3                      | 1                        | 4           | Year 2   | seasonal review       |                    |
| M25   | Check heating system for flow balancing and air venting                                    | 3                      | 1                        | 4           | Year 2   | seasonal review       |                    |
| EN1   | Check and seal exterior walls and openings   | 3                      | 1                        | 4           | Year 2   | 10 to 15              |                    |
| EN5   | Seal window and door frames  | 3                      | 1                        | 4           | Year 2   | 5                     |                    |
| M26   | Optimize fan-coil unit and entrance heater controls  | 3                      | 1                        | 4           | Year 2   | seasonal review       |                    |
| M27   | Consider heating system zoning   | 2                      | 1                        | 3           | Year 2   | n/a                   |                    |
| M22   | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 1                        | 3           | Year 5   | 10 to 15              |                    |
| M18   | Use controls to prevent heaters from running when overhead doors are open                  | 1                      | 1                        | 2           | Year 2   | seasonal review       |                    |
| M21   | Apply CO control to vehicle area exhaust fans  | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| M24   | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| EN2   | Insulate the attic adequately  | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| EN3   | Reclad the building's exterior   | 1                      | 1                        | 2           | Year 5   | 20 to 24              |                    |
| EN4   | Replace single-pane windows with double-pane windows                                       | 1                      | 1                        | 2           | Year 5   | 20 to 24              |                    |
| EN6   | If replacing the roof, ensure R-value at least 22  | 1                      | 1                        | 2           | Year 5   | n/a                   |                    |
| M28   | Install high efficiency burners  | 1                      | 1                        | 2           | Year 5   | 15 to 20              |                    |
| M29   | Replace boilers with more efficient models   | 1                      | 1                        | 2           | Year 5   | 15 to 20              |                    |
| M30   | Replace old rooftop units with energy efficient units                                      | 1                      | 1                        | 2           | Year 5   | 15 to 20              |                    |
| M31   | Install heat recovery or solar heating units   | 1                      | 1                        | 2           | Year 5   | 10 to 15              |                    |
| Other: _____  |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |

|                           |
|---------------------------|
| Behavioural Measures      |
| Operational Measures      |
| Retrofit/Capital Measures |

**Table 76: Energy Saving Measures for Ambulance Stations**

The specific measures and implementation timeline for each individual ambulance station will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

**Proposed / Future Renewable Energy Installations**

| <b>Building Name</b> | <b>Building Address</b> | <b>Renewable Installation</b> | <b>System Size</b> | <b>Unit</b> |
|----------------------|-------------------------|-------------------------------|--------------------|-------------|
| EMS Station 46       | 105 Cedarvale Ave       | Solar PV                      | 10                 | kW          |
| EMS Station 29       | 4560 Sheppard Ave E     | Solar PV                      | 10                 | kW          |
| EMS Station 16       | 4330 Dufferin St        | Solar PV                      | 40                 | kW          |
| EMS Station 55       | 5700 Bathurst St        | Geothermal                    | 70                 | kW          |
| EMS Station 35       | 265 Manitoba Drive      | Geothermal                    | 10                 | kW          |

**Table 77: Proposed Renewable Energy Systems for EMS Facilities**

### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities is \$4.20/ft<sup>2</sup> (see Appendix A). The budget allows for lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high-potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low-potential buildings is set at 40 percent of the basic amount to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium and low-potential ambulance stations are summarized in Table 78 below.

| Annual Savings Potential | Number of facilities | Average area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | Estimated Savings potential % | Payback     |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|-------------------------------|-------------|
| > \$100,000              | 1                    | 101,719                         | 5.04   | \$ 512,663                       | \$ 270,876                     | 77.9%                         | 1.89        |
| \$5,000 - \$100,000      | 5                    | 6,917                           | 4.20   | \$ 145,255                       | \$ 50,181                      | 14.4%                         | 2.89        |
| < \$5,000                | 18                   | 4,445                           | 1.68   | \$ 134,414                       | \$ 26,457                      | 7.6%                          | 5.08        |
|                          | <b>24</b>            |                                 |  | <b>\$ 792,331</b>                | <b>\$ 347,515</b>              |                               | <b>2.28</b> |

**Table 78: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.
- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 79 below.

|                |                                  | #         | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|-----------|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 1         | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 5         | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 18        | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | <b>24</b> |          |                     |                             |

**Table 79: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Building Performance Audit

There is one high-potential savings facility with over \$100,000 in annual energy saving potential (Ambulance Headquarters). The total annual energy savings are estimated to be over \$270,000 and the annual GHG savings are approximately 266,000 kg.

The Ambulance Headquarters can save an average of 50% of its total electricity use (50% Electric Baseload and 54% Electric Cooling). The total annual electricity savings are estimated to be approximately \$260,000.

The Ambulance Headquarters can save an average of 17% of its total gas use (51% Gas Baseload and 13% Gas Heating). The total annual gas savings are estimated to be approximately \$8,300.

The Ambulance Headquarters will undergo a Building Performance Audit (see the Implementation Plan for further details). For a complete description of the Building Performance Audit, refer to Appendix A.

Approximately 75% of the total energy savings for all ambulance stations and associated offices/facilities can be found at the Ambulance Headquarters.

See Appendix B for the associated energy savings potential by energy use component for the Ambulance Headquarters.

The highest percentage reductions for the Ambulance Headquarters can be found in Electric Baseload, Electric Cooling and Gas Baseload. After the implementation of the proposed measures, the Ambulance Headquarters is eligible to receive over \$150,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Assessment

There are 5 ambulance stations with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 14% of the total energy savings for all 24 ambulance stations and associated offices/facilities can be found in these 5 facilities.

These 5 ambulance stations can save an average of 41% of their total energy use. The total annual energy savings are estimated to be over \$50,000 and individual building annual savings range from approximately \$5,000 to over \$23,000. The annual GHG savings are approximately 77,700 kg.

These 5 ambulance stations can save an average of 50% of their total electricity use (53% Electric Baseload, 68% Electric Cooling and 16% Electric Heating). The total annual electricity savings are estimated to be approximately \$44,000 and individual building annual savings range from just over \$3,500 to approximately \$22,000.

These 5 ambulance stations can save an average of 33% of their total gas use (58% Gas Baseload and 31% Gas Heating). The total annual gas savings are estimated to be approximately \$5,900 and individual building annual savings range from no savings to over \$2,000.

These 5 facilities will undergo an Energy Assessment with highest potential ambulance stations focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 5 ambulance stations and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 5 ambulance stations can be found in Electric Baseload, Electric Cooling and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these ambulance stations are eligible to receive almost \$27,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.3 Energy Savings Checklist

There are 18 ambulance stations with less than \$5,000 in savings potential. Approximately 7% of the total energy savings for all 24 ambulance stations can be found in these 18 facilities.

These 18 ambulance stations can save an average of 21% of their total energy use. The total annual energy savings are estimated to be approximately \$26,000 and individual building annual savings range from \$0 to approximately \$4,000. The annual GHG savings are approximately 77,000 kg.



These 18 ambulance stations can save an average of 16% of their total electricity use (16% Electric Baseload, 37% Electric Cooling and 22% Electric Heating). The total annual electricity savings are estimated to be approximately \$18,000 and individual building annual savings range from \$0 to over \$4,000.

These 18 ambulance stations can save an average of 23% of their total gas use (50% Gas Baseload and 23% Gas Heating). The total annual gas savings are estimated to be approximately \$8,800 and individual building annual savings range from \$0 to almost \$2,400.

These 18 facilities will undergo a checklist approach with highest potential ambulance stations focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 18 ambulance stations and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 18 ambulance stations can be found in Electric Cooling and Gas Baseload.

The energy savings checklist will be used by the Division Champion for the ambulance stations in conjunction with the building operator and/or service contractor for each ambulance station. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### 3.3 Implementation Budget

Table 80 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 24 facilities. The total costs to implement the energy management and retrofit plan for ambulance stations is estimated to be \$806,281. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                   |
|----------------------------------|-------------------|
| Building Performance Audit (BPA) | \$ 7,500          |
| Energy Assessment                | \$ 3,750          |
| Checklist                        | \$ 2,700          |
| Implementation                   | \$ 792,331        |
| <b>Total</b>                     | <b>\$ 806,281</b> |

**Table 80: Total Budget - Energy Management and Retrofit Plan**

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 81 and Figure 49 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from the Building Performance Audit of Ambulance Headquarters will occur in Year 1 and the implementation of the measures will occur in Year 2. Identification of measures from Energy Assessments will begin in Year 1, with all 5 Energy Assessments completed by the end of Year 5. The implementation of these measures will begin in Year 2, and be completed by the end of Year 6. Identification of measures from the Checklists will begin in Year 2, with all 18 Checklists completed by the end of Year 6. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$2,608,934. The cumulative net cash flow becomes positive in Year 5.

The implementation plan includes the following assumptions:

- Approximately 76% of the project budget will be spent in the first 5 years, and the other 24% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 76% of facilities will be retrofitted in the first 5 years and 24% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.
- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1    | Year 2       | Year 3        | Year 4        | Year 5        | Year 6        | Year 7        | Year 8        | Year 9        | Year 10       | Totals       |
|---|-----------|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--------------|
| High Potential - Building Performance Audit                           | 1         | 0            | 0             | 0             | 0             | 0             | 0             | 0             | 0             | 0             | 1            |
| Mid Potential - Energy Assessment                                     | 1         | 1            | 1             | 1             | 1             | 0             | 0             | 0             | 0             | 0             | 5            |
| Low Potential - Checklist   | 0         | 4            | 4             | 4             | 4             | 2             | 0             | 0             | 0             | 0             | 18           |
| Assessment Costs  | \$ 8,250  | \$ 1,374     | \$ 1,387      | \$ 1,399      | \$ 1,412      | \$ 338        | \$ -          | \$ -          | \$ -          | \$ -          | \$ 14,161    |
| Implementation Costs  | \$ -      | \$ 563,599   | \$ 62,527     | \$ 63,778     | \$ 65,053     | \$ 66,354     | \$ 17,155     | \$ -          | \$ -          | \$ -          | \$ 838,466   |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 825    | \$ 56,497    | \$ 6,391      | \$ 6,518      | \$ 6,647      | \$ 6,669      | \$ 1,716      | \$ -          | \$ -          | \$ -          | \$ 85,263    |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -      | \$ 28,180    | \$ 31,306     | \$ 34,495     | \$ 37,748     | \$ 41,066     | \$ 41,923     | \$ 41,923     | \$ 41,923     | \$ 41,923.32  |              |
| Annual Costs  | \$ 9,075  | \$ 649,651   | \$ 101,611    | \$ 106,190    | \$ 110,860    | \$ 114,427    | \$ 60,794     | \$ 41,923     | \$ 41,923     | \$ 41,923     | \$ 1,278,378 |
| Estimated Achieved Annual Savings                                     |           | \$ 81,056.16 | \$ 249,395.26 | \$ 381,586.63 | \$ 420,301.00 | \$ 455,463.06 | \$ 486,613.03 | \$ 513,437.61 | \$ 539,109.49 | \$ 566,064.97 | \$ 3,693,027 |
| Estimated Incentives  | \$ -      | \$ 166,282   | \$ 11,690     | \$ 7,556      | \$ 5,420      | \$ 3,337      | \$ -          | \$ -          | \$ -          | \$ -          | \$ 194,285   |
| Annual Savings and Incentives   | \$ -      | \$ 247,338   | \$ 261,085    | \$ 389,143    | \$ 425,721    | \$ 458,800    | \$ 486,613    | \$ 513,438    | \$ 539,109    | \$ 566,065    | \$ 3,887,312 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       |           | -\$ 363      | -\$ 16,456    | -\$ 10,077    | \$ -          | \$ -          | \$ -          | \$ -          | \$ -          | \$ -          | -\$ 26,895   |
| Net Cash Flow incl borrowing costs                                    | -\$ 9,075 | -\$ 402,676  | \$ 143,018    | \$ 272,876    | \$ 314,861    | \$ 344,373    | \$ 425,819    | \$ 471,514    | \$ 497,186    | \$ 524,142    | \$ 2,582,039 |
| Cumulative Net Cash Flow  | -\$ 9,075 | -\$ 411,388  | -\$ 251,914   | \$ 31,039     | \$ 345,900    | \$ 690,273    | \$ 1,116,092  | \$ 1,587,606  | \$ 2,084,792  | \$ 2,608,934  |              |

Table 81: Cash Flow for 10-Year Implementation Plan




Figure 49: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above) and facilities of the same type from other municipalities. Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for ambulance stations is determined as the average kWh/day for April, May, September and October multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from June to August, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February, March, November and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-

standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

### Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>).

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>).

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

### Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>))+ Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup> ) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Fire stations
- Shelter, Support and Housing Administration
- Ambulance stations and associated offices and facilities
- Storage facilities where equipment or vehicles are maintained, repaired or stored
- Public libraries
- Long-Term Care Homes and Services
- Police stations and associated offices and facilities
- Children's Services
- Administrative offices and related facilities, including municipal council chambers

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 1.80                    | 100%       | 6.5           | 2.3                     |                                     |
| Mechanical   | 1.50                    | 30%        | 6             | 0.6                     | 0.7                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 0%         | 10            |                         | 0.2                                 |
| Process      | 0.15                    | 0%         | 5             |                         | 0.1                                 |
| <b>Total</b> | <b>4.20</b>             |            | <b>6.8</b>    | <b>3.19</b>             | <b>1.02</b>                         |

**Table 82: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process (domestic hot water) measures include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building’s existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved, and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building

- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### **Initial Energy Targets**

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.



## 5 Appendix B - Ambulance stations

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 24 ambulance station buildings included in this report and Plan.

| Building                     | Address             | Building Area (ft <sup>2</sup> ) |
|------------------------------|---------------------|----------------------------------|
| 2430 Lawrence Ave E          | 2430 Lawrence Ave E | 7,782                            |
| 50 Toryork                   | 50 Toryork          | 13,153                           |
| Ambulance Headquarters       | 4330 Dufferin St    | 101,719                          |
| EMS Workshop West            | 866 Richmond St W   | 1,658                            |
| EMS Station 10               | 2015 Lawrence Ave W | 5,005                            |
| EMS Station 11               | 1135 Caledonia Rd   | 3,574                            |
| EMS Station 14               | 321 Rexdale Blvd    | 4,252                            |
| EMS Station 24               | 3061 Birchmount Rd  | 2,659                            |
| EMS Station 28               | 2900 Lawrence Ave E | 1,905                            |
| EMS Station 31               | 4219 Dundas St W    | 2,831                            |
| EMS Station 32               | 9 Clendenan Ave     | 3,218                            |
| EMS Station 33               | 760 Dovercourt Rd   | 3,132                            |
| EMS Station 34 (save-a-life) | 674 Markham St      | 13,939                           |
| EMS Station 37               | 1288 Queen St W     | 4,413                            |
| EMS Station 38               | 259 Horner Ave      | 5,102                            |
| EMS Station 40               | 58 Richmond St E    | 12,798                           |
| EMS Station 42               | 1535 Kingston Rd    | 6,997                            |
| EMS Station 44               | 887 Pharmacy Ave    | 2,799                            |
| EMS Station 45               | 135 Davenport Rd    | 11,496                           |
| EMS Station 46               | 105 Cedarvale Ave   | 1,572                            |
| EMS Station 47               | 3600 St Clair Ave E | 1,787                            |
| EMS Station 49               | 3100 Eglinton Ave E | 2,583                            |
| EMS Station 12               | 1535 Albion Rd.     | 1,938                            |
| EMS Station 54               |                     | no data                          |

Table 83: Ambulance Station Building Information

### 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 24 ambulance station buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| Building                     | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|------------------------------|---|--|---|
| EMS Station 32               | 6.18  | 13.00  | 19.18   |
| EMS Station 45               | 6.02  | 13.41  | 19.44   |
| EMS Station 40               | 12.12   | 9.26   | 21.38   |
| EMS Station 33               | 8.49  | 14.07  | 22.56   |
| EMS Station 37               | 9.76  | 13.03  | 22.79   |
| EMS Station 34 (save-a-life) | 3.80  | 22.24  | 26.05   |
| EMS Station 47               | 16.53   | 10.26  | 26.80   |
| 50 Toryork                   | 12.00   | 15.39  | 27.39   |
| EMS Station 49               | 15.35   | 15.76  | 31.11   |
| EMS Station 24               | 9.07  | 23.25  | 32.32   |
| EMS Station 14               | 12.10   | 20.54  | 32.64   |
| EMS Station 11               | 9.86  | 24.04  | 33.89   |
| EMS Station 10               | 13.70   | 21.07  | 34.77   |
| EMS Station 44               | 10.08   | 26.35  | 36.43   |
| EMS Station 31               | 14.13   | 22.63  | 36.77   |
| EMS Station 42               | 17.49   | 21.70  | 39.19   |
| EMS Workshop West            | 7.06  | 33.45  | 40.51   |
| EMS Station 46               | 12.90   | 28.66  | 41.55   |
| EMS Station 12               | 17.29   | 25.26  | 42.54   |
| EMS Station 38               | 14.82   | 29.33  | 44.16   |
| 2430 Lawrence Ave E          | 30.67   | 22.03  | 52.71   |
| Ambulance Headquarters       | 36.31   | 19.46  | 55.77   |
| EMS Station 28               | 23.42   | 61.07  | 84.49   |
| EMS Station 54               | no data   | no data  | no data   |

**Table 84: Ambulance Station 2012 Energy Intensity**

### 5.3 Target-setting Method and Metrics

4 EMS stations were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.

| Facility       | Days in 2012         | Energy type |
|----------------|----------------------|-------------|
| EMS Station 32 | 333                  | Electricity |
| EMS Station 33 | 329                  | Electricity |
| EMS Station 46 | 333                  | Electricity |
| EMS Station 13 | Negative consumption | Electricity |

**Table 85: Excluded Facilities**

After excluding these facilities, 20 City of Toronto facilities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.

The red line on each chart indicates the top quartile for each component which is the target for that component.




Figure 50: 2012 Electric Baseload Intensity Benchmark

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for ambulance stations ranges from 2.5 to 35.3 ekWh/ft<sup>2</sup> and the top-quartile is 7.7 ekWh/ft<sup>2</sup>.




Figure 51: 2012 Electric Cooling Intensity Benchmark

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for ambulance stations ranges from 0 to 1.6 ekWh/ft<sup>2</sup> and the top-quartile is 0.3 ekWh/ft<sup>2</sup>.




Figure 52: 2012 Electric Heating Intensity Benchmark

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for ambulance stations ranges from 0 to 6.4 ekWh/ft<sup>2</sup> and the top-quartile is 2.3 ekWh/ft<sup>2</sup>.





Figure 53: 2012 Gas Baseload Intensity Benchmark

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for ambulance stations ranges from 0.03 to 16.4 ekWh/ft<sup>2</sup> and the top-quartile is 0.9 ekWh/ft<sup>2</sup>.



**Figure 54: 2012 Gas Heating Intensity Benchmark**

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for ambulance stations ranges from 8.6 to 44.7 ekWh/ft<sup>2</sup> and the top-quartile is 15.3 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of ambulance stations, the factors are % of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps, and % of the area served by electric air conditioning.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from total electricity use (or total gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 1 High Savings Potential Ambulance Station

Ambulance Headquarters is the only facility with more than \$100,000 in annual savings potential.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | \$/yr     | Gas Savings Potential |         |       | \$/yr    | Total Energy Savings Potential |           | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|----------|--------------------------------|-----------|-------------|----------|--------------------------------|------------------------|
|                                       | Average %                     |         |         |       |           | Average %             |         |       |          | Avg %                          | \$/yr     | Electricity | Gas      |                                |                        |
|                                       | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |          |                                |           |             |          |                                |                        |
| High potential savings facilities (1) | 50%                           | 54%     | 00%     | 50%   | \$262,619 | 51%                   | 13%     | 17%   | \$ 8,258 | 38%                            | \$270,876 | \$150,068   | \$ 3,176 | 101,719                        | 266,020                |
| Ambulance Headquarters                | 50%                           | 54%     | 00%     | 50%   | \$262,619 | 51%                   | 13%     | 17%   | \$ 8,258 | 38%                            | \$270,876 | \$150,068   | \$ 3,176 | 101,719                        | 266,020                |

**Table 86: Savings Potential for 1 High Savings Potential Ambulance Station**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

**Savings Potential by Energy Use Component for the 5 Mid Savings Potential Ambulance Stations**

Buildings are sorted by total annual savings potential, starting with the highest saving potential buildings.

There are 5 ambulance stations with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                       | Electricity Savings Potential |         |         |       | \$/yr     | Gas Savings Potential |         |       | \$/yr    | Total Energy Savings Potential |           | Incentives  |          | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|--------------------------------------|-------------------------------|---------|---------|-------|-----------|-----------------------|---------|-------|----------|--------------------------------|-----------|-------------|----------|--------------------------------|------------------------|
|                                      | Average %                     |         |         |       |           | Average %             |         |       |          | Avg %                          | \$/yr     | Electricity | Gas      |                                |                        |
|                                      | Base-load                     | Cooling | Heating | Total |           | Base-load             | Heating | Total |          |                                |           |             |          |                                |                        |
| Mid-potential savings facilities (5) | 53%                           | 68%     | 16%     | 50%   | \$ 44,246 | 58%                   | 31%     | 33%   | \$ 5,935 | 41%                            | \$ 50,181 | \$ 25,283   | \$ 2,283 | 34,584                         | 77,659                 |
| 2430 Lawrence Ave E                  | 72%                           | 54%     | 16%     | 66%   | \$ 22,016 | 38%                   | 27%     | 27%   | \$ 1,189 | 50%                            | \$ 23,205 | \$ 12,581   | \$ 457   | 7,782                          | 25,889                 |
| Station #42                          | 46%                           | 82%     |         | 43%   | \$ 7,360  | 17%                   | 25%     | 25%   | \$ 944   | 33%                            | \$ 8,304  | \$ 4,206    | \$ 363   | 6,997                          | 12,606                 |
| Station #38                          | 47%                           |         |         | 47%   | \$ 4,916  | 41%                   | 44%     | 44%   | \$ 1,651 | 45%                            | \$ 6,568  | \$ 2,809    | \$ 635   | 5,102                          | 15,795                 |
| Station #40                          | 32%                           |         |         | 30%   | \$ 6,409  |                       |         | 0%    | \$ -     | 17%                            | \$ 6,409  | \$ 3,662    | \$ -     | 12,798                         | 5,036                  |
| Station #28                          | 57%                           | 63%     | 53%     | 56%   | \$ 3,544  | 94%                   | 66%     | 74%   | \$ 2,151 | 69%                            | \$ 5,695  | \$ 2,025    | \$ 827   | 1,905                          | 18,332                 |

**Table 87: Savings Potential for 5 Medium Savings Potential Ambulance Stations**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

**Savings Potential by Energy Use Component for the 18 Low Savings Potential Ambulance Stations**

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 18 ambulance stations with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

High savings Moderate savings Low savings

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |           | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |        |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|-----------|--------------------------------|------------------------|--------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           |         | \$/yr | Avg %                          | \$/yr | Electricity | Gas       |                                |                        |        |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load | Heating |       |                                |       |             |           | Total                          |                        |        |
| Low potential savings facilities (18) | 16%                           | 37%     | 22%     | 16%   | \$ 17,659             | 50%       | 23%     | 23%   | \$ 8,798                       | 21%   | \$ 26,457   | \$ 10,091 | \$ 3,384                       | 80,008                 | 77,459 |
| 50 Toryork                            | 22%                           |         | 2%      | 18%   | \$ 4,011              |           | 1%      | 1%    | \$ 37                          | 8%    | \$ 4,048    | \$ 2,292  | \$ 14                          | 13,153                 | 3,418  |
| Station #11                           |                               | 76%     | 63%     | 50%   | \$ 2,805              |           | 35%     | 34%   | \$ 740                         | 39%   | \$ 3,345    | \$ 1,488  | \$ 285                         | 3,574                  | 7,394  |
| Station #10                           | 18%                           |         | 43%     | 26%   | \$ 2,427              |           | 27%     | 27%   | \$ 698                         | 26%   | \$ 3,124    | \$ 1,387  | \$ 268                         | 5,005                  | 6,948  |
| Station #12                           | 47%                           |         |         | 36%   | \$ 1,877              | 70%       | 66%     | 66%   | \$ 818                         | 53%   | \$ 2,694    | \$ 1,072  | \$ 314                         | 1,938                  | 7,383  |
| Station #34 (save-a-life)             |                               |         |         | 0%    | \$ -                  |           | 31%     | 31%   | \$ 2,394                       | 26%   | \$ 2,394    | \$ -      | \$ 921                         | 13,939                 | 17,301 |
| Station #49                           | 34%                           |         | 45%     | 37%   | \$ 2,112              |           |         | 0%    | \$ -                           | 18%   | \$ 2,112    | \$ 1,207  | \$ -                           | 2,583                  | 1,659  |
| Station #14                           | 20%                           |         | 19%     | 20%   | \$ 1,448              |           | 24%     | 23%   | \$ 510                         | 22%   | \$ 1,958    | \$ 828    | \$ 196                         | 4,252                  | 4,824  |
| Station #31                           | 25%                           |         | 27%     | 26%   | \$ 1,383              |           | 29%     | 28%   | \$ 442                         | 27%   | \$ 1,825    | \$ 790    | \$ 170                         | 2,831                  | 4,282  |
| Station #47                           | 27%                           |         |         | 17%   | \$ 762                | 100%      | 100%    | 100%  | \$ 464                         | 48%   | \$ 1,226    | \$ 436    | \$ 178                         | 1,787                  | 3,949  |
| Station #46                           |                               |         |         | 19%   | \$ 548                |           |         | 43%   | \$ 492                         | 43%   | \$ 1,040    | \$ 313    | \$ 189                         | 1,572                  | 3,984  |
| Station #44                           | 2%                            | 100%    |         | 2%    | \$ 69                 | 74%       | 36%     | 41%   | \$ 782                         | 30%   | \$ 851      | \$ 39     | \$ 301                         | 2,799                  | 5,704  |
| EMS Workshop West                     |                               |         |         | 0%    | \$ -                  | 46%       | 57%     | 56%   | \$ 783                         | 46%   | \$ 783      | \$ -      | \$ 301                         | 1,658                  | 5,661  |
| Station #24                           | 5%                            | 39%     |         | 7%    | \$ 223                | 84%       | 12%     | 30%   | \$ 473                         | 24%   | \$ 696      | \$ 127    | \$ 182                         | 2,659                  | 3,594  |
| Station #37                           |                               |         | 12%     | 3%    | \$ 194                | 19%       |         | 2%    | \$ 23                          | 2%    | \$ 218      | \$ 111    | \$ 9                           | 4,413                  | 321    |
| Station #45                           |                               |         |         | 0%    | \$ -                  | 35%       |         | 4%    | \$ 143                         | 3%    | \$ 143      | \$ -      | \$ 55                          | 11,496                 | 1,036  |
| Station #32                           |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -      | \$ -                           | 3,218                  | 0      |
| Station #33                           |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -      | \$ -                           | 3,132                  | 0      |
| Station #54                           |                               |         |         | 0%    | \$ -                  |           |         | 0%    | \$ -                           | 0%    | \$ -        | \$ -      | \$ -                           | 0                      | 0      |

Table 88: Savings Potential for 18 Low Savings Potential Ambulance Stations

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as (Actual Energy Use – Target Energy Use)/Actual Energy Use and \$/year savings for each component are calculated as (Actual Energy Use – Target Energy Use) \* utility company rates \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Fire Stations and Associated Offices/Facilities

---



## Table of Contents

|          |   |            |
|----------|---|------------|
| <b>1</b> | <b>Benchmarking and Conservation Potential .....</b>                                      | <b>181</b> |
| 1.1      | Energy Use and Building Characteristics.....  | 181        |
| 1.1.1    | Building Characteristics.....   | 181        |
| 1.1.2    | Summary of Energy Use and Costs .....   | 181        |
| 1.2      | Energy Targets.....   | 184        |
| 1.3      | Savings Potential.....  | 185        |
| <b>2</b> | <b>Conservation Measures and Budget.....</b>  | <b>187</b> |
| 2.1      | Previous Energy Efficiency Initiatives.....   | 187        |
| 2.2      | Proposed Energy Efficiency Measures .....   | 188        |
| <b>3</b> | <b>Energy Management and Retrofit Plan .....</b>  | <b>195</b> |
| 3.1      | Implementation Costs and Modeled Savings .....  | 195        |
| 3.2      | Implementation Process and Tools – Determining the Specific Measures for Each Building .. | 195        |
| 3.2.1    | Energy Assessment .....   | 196        |
| 3.2.2    | Energy Savings Checklist .....  | 197        |
| 3.3      | Implementation Budget.....  | 198        |
| 3.4      | 10-Year Implementation Plan .....   | 198        |
| <b>4</b> | <b>Appendix A.....</b>  | <b>200</b> |
| 4.1      | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities .....    | 200        |
| 4.2      | Determining Energy Use Components.....  | 200        |
| 4.3      | Determining Targets .....   | 201        |
| 4.4      | Calculating Potential Savings .....   | 202        |
| 4.5      | Implementation Costs by Measure Type and Modeled Savings.....                             | 202        |
| 4.6      | Assessment Tools.....   | 203        |
| <b>5</b> | <b>Appendix B - Fire Stations.....</b>  | <b>205</b> |
| 5.1      | Buildings and Building Characteristics .....  | 205        |
| 5.2      | Energy Use Intensities.....   | 207        |
| 5.3      | Target-setting Method and Metrics.....  | 210        |

## List of Tables

|  |     |
|--|-----|
| Table 89: Current Renewable Energy Systems at City of Toronto Fire Stations .....            | 181 |
| Table 90: 2012 Energy Use and Costs for 88 City of Toronto Fire Stations .....               | 182 |
| Table 91: Top Quartile Targets.....  | 185 |
| Table 92: Savings Potential Summary .....  | 186 |
| Table 93: Savings Potential Based on Energy Use Component for 88 Fire Stations .....         | 186 |
| Table 94: 2003 Fire HProject Estimated Project Costs and Savings.....                        | 187 |
| Table 90: Energy Saving Measures for Fire Stations.....                                      | 193 |
| Table 96: Proposed Renewable Energy Systems on Fire Stations and Associated Facilities ..... | 194 |
| Table 97: Estimated Implementation Costs and Modeled Savings .....                           | 195 |
| Table 98: Assessment Tools Used to Determine Specific Energy-saving Measures .....           | 196 |
| Table 99: Total Budget - Energy Management and Retrofit Plan .....                           | 198 |
| Table 100: Cash Flow for 10-Year Implementation Plan .....                                   | 199 |
| Table 101: Implementation Costs by Measure Type .....  | 203 |
| Table 102: Fire Station Building Information .....   | 207 |
| Table 103: Fire Station 2012 Energy Intensity .....  | 210 |
| Table 104: Excluded Facilities .....   | 210 |
| Table 105: Savings Potential for 34 Medium Savings Potential Fire Stations.....              | 213 |
| Table 106: Savings Potential for 54 Low Savings Potential Fire Stations.....                 | 214 |

## List of Figures

|  |     |
|--|-----|
| Figure 55: 2012 Energy Use and Cost Breakdown for 88 City of Toronto Fire Stations ..... | 182 |
| Figure 56: 2012 Total Energy Intensity Benchmark .....                                   | 183 |
| Figure 57: 2012 Total Electricity Intensity Benchmark .....                              | 183 |
| Figure 58: 2012 Total Gas Intensity Benchmark .....                                      | 184 |
| Figure 59: Cash Flow for 10-Year Implementation Plan .....                               | 200 |
| Figure 60: 2012 Electric Baseload Intensity Benchmark.....                               | 211 |
| Figure 61: 2012 Electric Cooling Intensity Benchmark .....                               | 211 |
| Figure 62: 2012 Electric Heating Intensity Benchmark.....                                | 211 |
| Figure 63: 2012 Gas Baseload Intensity Benchmark.....                                    | 212 |
| Figure 64: 2012 Gas Heating Intensity Benchmark.....                                     | 212 |

# 1 Benchmarking and Conservation Potential

## 1.1 Energy Use and Building Characteristics

### 1.1.1 Building Characteristics

The City of Toronto is reporting on 88 fire station buildings in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B. The majority of the 88 buildings are fire stations, but also included are 3 training centres (including the Fire Academy), a museum, and an office type facility.

The total area for all of the buildings is 836,816 ft<sup>2</sup>. The fire stations range in size from less than 2,500 ft<sup>2</sup> to almost 25,000 ft<sup>2</sup>. The Toryork Office and Fire Academy are both over 40,000 ft<sup>2</sup>.

Five of the fire stations are equipped with renewable energy systems, as summarized below.

| Building Name | Building Address       | Renewable Installation | System Size | Unit |
|---------------|------------------------|------------------------|-------------|------|
| Fire Hall 212 | 8500 Sheppard Ave East | Solar Hot Water        | 11          | kW   |
| Fire Hall 231 | 740 Markham Rd         | Solar Hot Water        | 11          | kW   |
| Fire Hall 334 | 339 Queens Quay West   | Solar Photovoltaic     | 3.2         | kW   |
| Fire Hall 424 | 462 Runnymede Rd       | Solar Photovoltaic     | 1.2         | kW   |
| Fire Hall 426 | 140 Lansdowne Ave      | Solar Hot Water        | 11          | kW   |

**Table 89: Current Renewable Energy Systems at City of Toronto Fire Stations**

The majority of the fire stations have air conditioning serving approximately 50% of the building. Only the Fire Training Centre and Toryork Office have air-conditioning serving over 50% of the building. Only one facility (Fire Station former TO #35) is reported to be served by electric heat. Even though they are not reported to be using electric heat, the electricity profiles show that the majority of the other fire stations have significant additional use of electricity in winter months. While some of this usage may be due to longer hours of lighting or electric motors, use of electric heaters is indicated and should be further explored. Identifying and limiting electricity use associated with space heating will be one of the first measures recommended in the plan (see section on proposed energy efficiency measures). None of the fire stations are served by ground or water source heat pumps.

### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for

calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 88 buildings are summarized below.

|                               | 2012 Energy Use |                    |
|-------------------------------|-----------------|--------------------|
|                               | Unit            | \$                 |
| Electricity (kWh)             | 9,693,353       | \$1,357,069        |
| Natural Gas (m <sup>3</sup> ) | 1,716,046       | \$446,172          |
| <b>Total</b>                  |                 | <b>\$1,803,241</b> |

Table 90: 2012 Energy Use and Costs for 88 City of Toronto Fire Stations




Figure 55: 2012 Energy Use and Cost Breakdown for 88 City of Toronto Fire Stations

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 88 buildings. Total energy use ranges from less than 20 to over 80 ekWh/ft<sup>2</sup>. The ranges for electricity and gas use per ft<sup>2</sup> are even greater. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in

Appendix B.




Figure 56: 2012 Total Energy Intensity Benchmark




Figure 57: 2012 Total Electricity Intensity Benchmark




Figure 58: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for fire stations are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each fire station to achieve its target over the duration of the ECDM Plan.

| Energy type         | Component    | Value       | Unit                            |
|---------------------|--------------|-------------|---------------------------------|
| Electricity         | Baseload     | 7.4         | kWh/ft <sup>2</sup> /year       |
|                     | Cooling      | 0.5         | kWh/ft <sup>2</sup> /year       |
|                     | Heating      | 0.6         | kWh/ft <sup>2</sup> /year       |
|                     | <b>Total</b> | <b>8.5</b>  | <b>kWh/ft<sup>2</sup>/year</b>  |
| Gas                 | Baseload     | 1.7         | ekWh/ft <sup>2</sup> /year      |
|                     | Heating      | 14.7        | ekWh/ft <sup>2</sup> /year      |
|                     | <b>Total</b> | <b>16.5</b> | <b>ekWh/ft<sup>2</sup>/year</b> |
| <b>Total energy</b> | <b>Total</b> | <b>24.9</b> | <b>ekWh/ft<sup>2</sup>/year</b> |

**Table 91: Top Quartile Targets**

76 fire stations made up the data set for target-setting, 68 of which are City of Toronto buildings with complete and reliable data from the 88 which are part of this Plan, with 8 additional buildings from other municipalities. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), and % of the area which is air conditioned. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each fire station. The total savings potential for each fire station is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 88 fire stations are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are no fire stations with annual savings potential greater than \$100,000. 34 fire stations have annual savings potential between \$5,000 and \$100,000 and 54 fire stations have annual savings potential less than \$5,000 (see Table 92).

The total annual savings potential for the 88 buildings is \$581,115 (\$457,980 for electricity and \$123,134 for gas) with an average total energy savings of 30%.

For the 34 mid-potential savings facilities, the total annual savings potential is \$459,713 (\$387,007 for electricity and \$72,706 for gas) with an average total energy savings of 38%.

For the 54 low-potential savings facilities, the total annual savings potential is \$121,402 (\$70,973 for electricity and \$50,429 for gas) with an average total energy savings of 20%.


|                                       | Electricity Savings Potential |                   | Gas Savings Potential |                   | Total Energy Savings Potential |                   | Incentives        |                  | Indoor Area     | GHG Emissions    |
|---------------------------------------|-------------------------------|-------------------|-----------------------|-------------------|--------------------------------|-------------------|-------------------|------------------|-----------------|------------------|
|                                       | Average %                     | \$/yr             | Average %             | \$/yr             | Average %                      | \$/yr             | Electricity       | Gas              | ft <sup>2</sup> | kg/yr            |
| <b>TOTAL: 88 facilities</b>           | <b>34%</b>                    | <b>\$ 457,980</b> | <b>28%</b>            | <b>\$ 123,134</b> | <b>30%</b>                     | <b>\$ 581,115</b> | <b>\$ 261,703</b> | <b>\$ 47,359</b> | <b>836,816</b>  | <b>1,249,723</b> |
| Mid-potential savings facilities (34) | 46%                           | \$ 387,007        | 33%                   | \$ 72,706         | 38%                            | \$ 459,713        | \$ 221,147        | \$ 27,964        | 383,732         | 829,515          |
| Low potential savings facilities (54) | 14%                           | \$ 70,973         | 22%                   | \$ 50,429         | 20%                            | \$ 121,402        | \$ 40,556         | \$ 19,396        | 453,085         | 420,208          |

**Table 92: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures), and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 93 below shows the total potential savings for all 88 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 10.5        | 6.9         | 34%                 | \$ 330,068           |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 0.8         | 0.5         | 41%                 | \$ 27,387            |
| Electric Heating (kWh/ft <sup>2</sup> )   | 1.0         | 0.5         | 48%                 | \$ 32,716            |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 10.1        | 7.4         | 27%                 | \$ 67,809            |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 2.6         | 1.5         | 43%                 | \$ 18,753            |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 18.8        | 14.0        | 26%                 | \$ 79,926            |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 20.7        | 15.3        | 26%                 | \$ 24,455            |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>32.8</b> | <b>23.0</b> | <b>30%</b>          | <b>\$ 581,115</b>    |



**Table 93: Savings Potential Based on Energy Use Component for 88 Fire Stations**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling, Electric Heating (i.e. higher electricity use in winter months as described above under Building Characteristics) and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electrical Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.



## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2003, the City of Toronto undertook a study to identify building improvement measures that would improve energy and water efficiency and reduce the operating cost and environmental impact of fire hall facilities located throughout the City of Toronto. Measures were categorized into one of three programs, namely, Energy Savings Program, Capital Program and Renewable Program.

Table 94 below summarizes the estimated overall project costs, savings and estimated energy reduction for the 88 fire hall facilities as a result of the 2003 project.

| Project Name & Year | # of Bldgs | Total Floor Area (m2) | Estimated Project Cost & Savings |                 |                    |                            |                 | Estimated Energy Reduction |                        |                        |                  |
|---------------------|------------|-----------------------|----------------------------------|-----------------|--------------------|----------------------------|-----------------|----------------------------|------------------------|------------------------|------------------|
|                     |            |                       | Retrofit Cost                    | Total \$Savings | Total ekWh Savings | Total CO2 Savings (tonnes) | Payback (years) | Electricity Savings kWh    | Electricity Savings kW | Natural Gas Savings m3 | Water Savings m3 |
| Fire Hall 2003      | 88         | 66,722                | \$2,611,319                      | \$334,594       | 5,473,597          | 1,115                      | 7.8             | 1,048,843                  | 2,897                  | 427,856                | 12,702           |

**Table 94: 2003 Fire HProject Estimated Project Costs and Savings**

The types of measures implemented included the following (may not apply to all buildings):

- Lighting Retrofits
  - retrofitted all fixtures that contained T12 lamps with electromagnetic ballasts to fixtures with T8 lamps and electronic ballasts
- Major Mechanical Modifications
  - solar air heating (Fire Stations 326, 334)
  - solar water heating (Fire Stations 212, 231)
  - boiler replacement
  - replaced electric DHW tanks with gas-fired DHW tanks (Fire Stations 424, 425, 444)
  - installed thermostatic mixing valves
- Minor Mechanical Modifications
  - replaced refrigerators and freezers with energy efficient models
  - optimized vending machines (installed motion sensor controllers to reduce compressor cycling during periods of low to no occupancy)
  - installed apparatus door heater interlock so that heaters automatically shut off when bay doors are open
  - insulation of uninsulated or poorly insulated DHW tanks
- Automated Building Controls
  - commissioned and expanded the building automation controls at the South Command Training Centre
  - boiler controls added to hot water boilers

- programmable thermostats and over-ride buttons installed to provide temperature setback in the apparatus bays
  - installed programmable thermostats to allow for space temperature setback during unoccupied hours
- Required Capital Upgrades
    - boiler, furnace and condenser replacement
    - AHU, RTU replacement, HVAC modifications
    - DHW heater, unit heater replacement
    - CO/NOx monitoring system
  - Building Envelope Upgrades
    - sealed doors, windows and envelope cracks to reduce air leakage
    - added or repaired existing attic insulation
    - upgraded single glazed overhead doors, replaced old leaky windows with new double-glazed low 'E' windows (Fire Stations 424, 425)
  - Water Conservation
    - upgraded or replaced selected domestic water fixtures with new low-flow technology
  - Training, re-commissioning and green roof installation (Fire Stations 332, 334)

## 2.2 Proposed Energy Efficiency Measures

**Table 24: Energy Saving Measures for Children's Services Buildings**

below shows the full range of possible energy efficiency measures for the entire portfolio of fire stations. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 88 facilities indicate that the largest percentage reductions will come from measures associated with electric cooling, electric heating and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).

| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off machines, office and kitchen equipment when not needed                                  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B2   | Unplug machines, office and kitchen equipment if not actively used                               | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off computer monitors when not in use   | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B4   | Enable ENERGY STAR power settings on your computer   | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B5   | Unplug chargers when not in use  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B6   | Turn off lights when areas not in use  | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| B7   | Make use of natural light instead of turning on lights where possible                            | 4                      | 3                        | 7           | Year 1   | Annual Review         | Building Occupants |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 3                        | 6           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 3                        | 6           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 3                        | 6           | Year 3   | 15+                   |                    |
| L1   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L2   | Install motion sensors in washrooms/occasional use spaces to shut off lights when unoccupied     | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L3   | Install photo-sensors and/or a timer on outdoor and daylight interior area lighting              | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L4   | Replace HID lighting with high efficiency fluorescent  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L5   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L6   | Replace festive lighting with LED  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| L7   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 3                        | 4           | Year 4   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 3                        | 4           | Year 4   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 3                        | 4           | Year 4   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
| EL5  | Submeter data and call centres   | 1                      | 3                        | 4           | Year 4   | Seasonal Review       |                    |
| M3   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 3                        | 4           | Year 4   | 10 to 20              |                    |
| M4   | Convert electric hot water heaters to natural gas  | 1                      | 3                        | 4           | Year 4   | 10 to 15              |                    |
|  | Other: _____   |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Electric Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes</b> |  |                        |                          |             |          |                       |                    |
| B8   | Adjust blinds (to retain heat in winter)   | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B9   | Avoid use of electric heaters  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B10  | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M8   | Control fan coil and entrance heaters to optimize run-times                                | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M9   | Evaluate conversion from electric heating to natural gas                                   | 2                      | 4                        | 6           | Year 2   | n/a                   |                    |
| M5   | Install snow sensors to control the snow-melting system                                    | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| M6   | Upgrade base building heating system to avoid use of electric heaters                      | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| M7   | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1                      | 4                        | 5           | Year 3   | seasonal review       |                    |
| M10  | Install controls on vehicle plug-in heaters  | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
|  | Other: _____   |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Electric Cooling Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes</b> |  |                        |                          |             |          |                       |                    |
| B11  | Winterize room air-conditioners  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B12  | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B13  | Only cool rooms that are being used  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B14  | Install and use energy efficient ceiling fans  | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B15  | Close blinds (to shade space from direct sunlight)   | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| B16  | Install window film, solar screens or awnings on south and west facing windows               | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| M11  | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M13  | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M14  | Test and tune the air conditioning units   | 3                      | 4                        | 7           | Year 2   | 3                     |                    |
| M12  | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
|  | Other: _____   |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |
|  | _____  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round |  |                        |                          |             |          |                       |                    |
| B17   | Optimize dishwasher operation (only run when full) | 4                      | 4                        | 8           | Year 1   |                       | Building Occupants |
| P1  | Optimize DHW temperature control                   | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| P3  | Test and tune DHW boiler efficiency                | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M17   | Investigate and repair possible gas leaks          | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P2  | Implement DHW circulation pump control             | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P4  | Install low flow showerheads and faucet aerators   | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| M15   | Insulate DHW tanks and distribution piping         | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M16   | Replace DHW boilers with more efficient models     | 1                      | 4                        | 5           | Year 3   | 10 to 15              |                    |
| Other: _____  |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |
| _____   |  |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Heating Measures  |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS HEATING - refers to the additional energy used in winter for heating and humidification |  |                        |                          |             |          |                       |                    |
| B18   | Check and clear baseboard heaters of obstructions  | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B19   | Adjust blinds (to retain heat in winter)   | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| B20   | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 2                        | 6           | Year 1   |                       | Building Occupants |
| M19   | Optimize operating periods of ventilation systems supplying heated spaces                  | 2                      | 2                        | 4           | Year 2   | seasonal review       |                    |
| M20   | Test and adjust ventilation systems to optimize outside air volumes                        | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M23   | Test and tune boiler efficiency  | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M25   | Check heating system for flow balancing and air venting                                    | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| EN1   | Check and seal exterior walls and openings   | 3                      | 2                        | 5           | Year 2   | 10 to 15              |                    |
| EN5   | Seal window and door frames  | 3                      | 2                        | 5           | Year 2   | 5                     |                    |
| M26   | Optimize fan-coil unit and entrance heater controls  | 3                      | 2                        | 5           | Year 2   | seasonal review       |                    |
| M27   | Consider heating system zoning   | 2                      | 2                        | 4           | Year 2   | n/a                   |                    |
| M22   | Test, repair, replace and right-size heating control valves and outside air dampers        | 2                      | 2                        | 4           | Year 4   | 10 to 15              |                    |
| M18   | Use controls to prevent heaters from running when overhead doors are open                  | 1                      | 2                        | 3           | Year 2   | seasonal review       |                    |
| M21   | Apply CO control to vehicle area exhaust fans  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| M24   | Upgrade heating system control to optimize space temperatures and operating periods        | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| EN2   | Insulate the attic adequately  | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| EN3   | Reclad the building's exterior   | 1                      | 2                        | 3           | Year 5   | 20 to 24              |                    |
| EN4   | Replace single-pane windows with double-pane windows                                       | 1                      | 2                        | 3           | Year 5   | 20 to 24              |                    |
| EN6   | If replacing the roof, ensure R-value at least 22  | 1                      | 2                        | 3           | Year 5   | n/a                   |                    |
| M28   | Install high efficiency burners  | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M29   | Replace boilers with more efficient models   | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M30   | Replace old rooftop units with energy efficient units                                      | 1                      | 2                        | 3           | Year 5   | 15 to 20              |                    |
| M31   | Install heat recovery or solar heating units   | 1                      | 2                        | 3           | Year 5   | 10 to 15              |                    |
| Other: __   |  |                        |                          |             |          |                       |                    |

Behavioural Measures

Operational Measures

Retrofit/Capital Measures

**Table 95: Energy Saving Measures for Fire Stations**

The specific measures and implementation timeline for each individual fire station will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

**Proposed / Future Renewable Energy Installations**

| <b>Building Name</b>                              | <b>Building Address</b> | <b>Renewable Installation</b> | <b>System Size</b> | <b>Unit</b> |
|---|-------------------------|-------------------------------|--------------------|-------------|
| Fire Hall 341                                     | 555 Oakwood Ave         | Geothermal                    | 31                 | kW          |
| Fire Hall 112                                     | 5700 Bathurst St        | Geothermal                    | 70                 | kW          |
| Fire Hall 123                                     | 143 Bond Ave            | Geothermal                    | 25                 | kW          |
| Fire Hall 245                                     | 1600 Birchmount Rd      | Geothermal                    | 53                 | kW          |
| Fire Hall 145                                     | 20 Beffort Rd           | Solar PV                      | 10                 | kW          |
| Fire Hall 213                                     | 37 Lapsley              | Solar PV                      | 10                 | kW          |
| Fire Hall 231                                     | 740 Markham Rd          | Solar PV                      | 10                 | kW          |
| Fire Hall 234                                     | 40 Coronation Dr        | Solar PV                      | 10                 | kW          |
| Fire Hall 235 & Special Operation Training Centre | 220 Bermondsey Rd       | Solar PV                      | 10                 | kW          |
| Fire Hall 243                                     | 4560 Sheppard Ave E     | Solar PV                      | 10                 | kW          |
| Fire Hall 311                                     | 20 Balmoral             | Solar PV                      | 10                 | kW          |
| Fire Hall 325                                     | 475 Dundas St E         | Solar PV                      | 10                 | kW          |
| Fire Hall 441 and West Fire Training              | 947 Martin Grove Rd     | Solar PV                      | 10                 | kW          |
| Fire Headquarters                                 | 4330 Dufferin St        | Solar PV                      | 40                 | kW          |

**Table 96: Proposed Renewable Energy Systems on Fire Stations and Associated Facilities**



### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities, is \$4.20/ft<sup>2</sup> (see Appendix A). The budget allows for lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high-potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low potential buildings is set at 40 percent of the basic amount to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium and low potential fire stations are summarized in Table 97 below.

| Annual Savings Potential | Number of facilities | Average Area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | Estimated Savings potential % | Payback     |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|-------------------------------|-------------|
| >\$100,000               | 0                    | -                               | 5.04   | \$ -                             | \$ -                           | 0.0%                          |             |
| \$5,000-\$100,000        | 34                   | 11,286                          | 4.20   | \$ 1,611,673                     | \$ 459,713                     | 79.1%                         | 3.51        |
| <\$5,000                 | 54                   | 8,390                           | 1.68   | \$ 761,183                       | \$ 121,402                     | 20.9%                         | 6.27        |
|                          | <b>88</b>            |                                 |  | <b>\$ 2,372,855</b>              | <b>\$ 581,115</b>              |                               | <b>4.08</b> |

**Table 97: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.

- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 98 below.

|                |                                  | #         | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|-----------|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 0         | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 34        | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 54        | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | <b>88</b> |          |                     |                             |

**Table 98: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Energy Assessment

There are 34 fire stations with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 80% of the total energy savings for all 88 fire stations can be found in these 34 facilities.

These 34 fire stations can save an average of 38% of their total energy use. The total annual energy savings are estimated to be over \$450,000 and individual building annual savings range from approximately \$5,000 to over \$55,000. The annual GHG savings are approximately 830,000 kg.

These 34 fire stations can save an average of 46% of their total electricity use (46% Electric Baseload, 41% Electric Cooling and 53% Electric Heating). The total annual electricity savings are estimated to be approximately \$387,000 and individual building annual savings range from just over \$1,200 to almost \$48,000.

These 34 fire stations can save an average of 33% of their total gas use (49% Gas Baseload and 29% Gas Heating). The total annual gas savings are estimated to be approximately \$72,700 and individual building annual savings range from \$0 to approximately \$7,000.

These 34 facilities will undergo an Energy Assessment with highest potential fire stations focused on first (see the Implementation Plan for further details).

Approximately 30% of the total energy savings can be found at the top 5 buildings with the highest savings potential (Toryork Office, Fire Station 334, the Fire Academy, Fire Station 112 and Fire Station 114).

Over 50% of the total energy savings can be found at the top 15 buildings with the highest savings potential.

See Appendix B for a list of these 34 fire stations and their associated energy savings potential by energy use component.

Highest percentage reductions for this group of 34 fire stations can be found in Electric Heating, Electric Baseload and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these fire stations are eligible to receive almost \$250,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Savings Checklist

There are 54 fire stations with less than \$5,000 in savings potential. Approximately 20% of the total energy savings for all 88 fire stations can be found in these 54 facilities.

These 54 fire stations can save an average of 20% of their total energy use. The total annual energy savings are estimated to be approximately \$121,000 and individual building annual savings range from \$0 to just under \$5,000. The annual GHG savings are approximately 420,000 kg.

These 54 fire stations can save an average of 14% of their total electricity use (11% Electric Baseload, 41% Electric Cooling and 36% Electric Heating). The total annual electricity savings are estimated to be approximately \$71,000 and individual building annual savings range from \$0 to over \$4,300.

These 54 fire stations can save an average of 22% of their total gas use (35% Gas Baseload and 22% Gas Heating). The total annual gas savings are estimated to be approximately \$50,000 and individual building annual savings range from \$0 to over \$2,500.

These 54 facilities will undergo a checklist approach with highest potential fire stations focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 54 fire stations and their associated energy savings potential by energy use component.

The majority of the savings for this group of 54 fire stations can be found in Electric Heating, Electric Cooling and Gas Baseload.

The energy savings checklist will be used by the Division Champion for the fire stations in conjunction with the building operator and/or service contractor for each fire station. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### 3.3 Implementation Budget

Table 99 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 88 facilities. The total costs to implement the energy management and retrofit plan for Fire Halls is estimated to be \$2,406,455. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                     |
|----------------------------------|---------------------|
| Building Performance Audit (BPA) | \$ -                |
| Energy Assessment                | \$ 25,500           |
| Checklist                        | \$ 8,100            |
| Implementation                   | \$ 2,372,855        |
| <b>Total</b>                     | <b>\$ 2,406,455</b> |

**Table 99: Total Budget - Energy Management and Retrofit Plan**

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 100 and Figure 49 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from Energy Assessments will begin in Year 1, with all 34 Energy Assessments completed by the end of Year 5. The implementation of these measures will begin in Year 2, and be completed by the end of Year 6. Identification of measures from the Checklists will begin in Year 2, with all 54 Checklists completed by the end of Year 10. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$2,168,318. The cumulative net cash flow becomes positive in Year 8.

The implementation plan includes the following assumptions:

- Approximately 75% of the project budget will be spent in the first 5 years, and the other 25% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 75% of medium and low potential savings facilities will be retrofitted in the first 5 years and 25% in the following 5 years.

- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.
- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1       | Year 2        | Year 3        | Year 4        | Year 5        | Year 6        | Year 7        | Year 8        | Year 9        | Year 10      | Totals       |
|---|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--------------|--------------|
| Mid Potential - Energy Assessment                                     | 8            | 8             | 8             | 8             | 2             | 0             | 0             | 0             | 0             | 0            | 34           |
| Low Potential - Checklist   | 0            | 14            | 14            | 13            | 13            | 0             | 0             | 0             | 0             | 0            | 54           |
| Assessment Costs  | \$ 6,000     | \$ 8,185      | \$ 8,229      | \$ 8,111      | \$ 3,653      | \$ -          | \$ -          | \$ -          | \$ -          | \$ -         | \$ 34,177    |
| Implementation Costs  | \$ -         | \$ 394,538    | \$ 611,851    | \$ 624,088    | \$ 621,007    | \$ 313,132    | \$ -          | \$ -          | \$ -          | \$ -         | \$ 2,564,614 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 600       | \$ 40,272     | \$ 62,008     | \$ 63,220     | \$ 62,466     | \$ 31,313     | \$ -          | \$ -          | \$ -          | \$ -         | \$ 259,879   |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -         | \$ 19,727     | \$ 50,319     | \$ 81,524     | \$ 112,574    | \$ 128,231    | \$ 128,231    | \$ 128,231    | \$ 128,231    | \$ 128,231   |              |
| Annual Costs  | \$ 6,600     | \$ 462,721    | \$ 732,407    | \$ 776,942    | \$ 799,700    | \$ 472,676    | \$ 128,231    | \$ 128,231    | \$ 128,231    | \$ 128,231   | \$ 3,763,969 |
| Estimated Achieved Annual Savings                                     | \$ 62,108.19 | \$ 233,166.09 | \$ 453,854.91 | \$ 618,421.13 | \$ 737,596.42 | \$ 811,432.80 | \$ 858,570.92 | \$ 901,499.47 | \$ 946,574.44 | \$ 5,623,224 |              |
| Estimated Incentives  | \$ -         | \$ 124,301    | \$ 86,760     | \$ 54,837     | \$ 34,424     | \$ 8,741      | \$ -          | \$ -          | \$ -          | \$ -         | \$ 309,062   |
| Annual Savings and Incentives   | \$ -         | \$ 186,409    | \$ 319,926    | \$ 508,692    | \$ 652,845    | \$ 746,337    | \$ 811,433    | \$ 858,571    | \$ 901,499    | \$ 946,574   | \$ 5,932,287 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       |              | \$ 264        | \$ 11,316     | \$ 27,816     | \$ 38,546     | \$ 44,420     | \$ 33,473     | \$ 6,145      | \$ -          | \$ -         | \$ 161,981   |
| Net Cash Flow incl borrowing costs                                    | -\$ 6,600    | -\$ 276,576   | -\$ 423,797   | -\$ 296,066   | -\$ 185,400   | \$ 229,242    | \$ 649,729    | \$ 724,195    | \$ 773,269    | \$ 818,344   | \$ 2,006,337 |
| Cumulative Net Cash Flow  | -\$ 6,600    | -\$ 282,912   | -\$ 695,393   | -\$ 963,644   | -\$ 1,110,498 | -\$ 836,837   | -\$ 153,635   | \$ 576,706    | \$ 1,349,974  | \$ 2,168,318 |              |

Table 100: Cash Flow for 10-Year Implementation Plan




Figure 59: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

### 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above) and facilities of the same type from other municipalities. Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for fire stations is determined as the average kWh/day for April, May, September and October multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from June to August, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February, March, November and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average  $\text{m}^3/\text{day}$  for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

### 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

#### Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by  $(100\% - \% \text{ of area served})$

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by  $(100\% - \% \text{ of area served})$

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add  $50 \text{ kWh}/\text{ft}^2 * \% \text{ of building occupied by Data Centre}$  to Electric Baseload

**Food Services:** Add  $30 \text{ kWh}/\text{ft}^2 * \% \text{ of facility area occupied by Food Services (including seating area)}$  to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add  $(1.04 \text{ kWh}/\text{ft}^2 \text{ of ice}/\text{week} * \text{ft}^2 \text{ of ice surface area} * 16 \text{ weeks}/\text{year})$  divided by  $\text{ft}^2$  of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

**Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:**

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52 weeks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from ekWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:



- Fire stations and associated offices and facilities
- Shelter, Support and Housing Administration
- Ambulance stations and associated offices and facilities
- Storage facilities where equipment or vehicles are maintained, repaired or stored
- Public libraries
- Long-Term Care Homes and Services
- Police stations and associated offices and facilities
- Children’s Services
- Administrative offices and related facilities, including municipal council chambers

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 1.80                    | 100%       | 6.5           | 2.3                     |                                     |
| Mechanical   | 1.50                    | 30%        | 6             | 0.6                     | 0.7                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 0%         | 10            |                         | 0.2                                 |
| Process      | 0.15                    | 0%         | 5             |                         | 0.1                                 |
| <b>Total</b> | <b>4.20</b>             |            | <b>6.8</b>    | <b>3.19</b>             | <b>1.02</b>                         |

**Table 101: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process (domestic hot water) measures include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building’s existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver

the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved, and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building
- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### **Initial Energy Targets**

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### **Energy Assessment**

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.

## 5 Appendix B - Fire Stations

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 88 fire station buildings included in this report and Plan.

| <b>Building</b>  | <b>Address</b>         | <b>Building Area (ft<sup>2</sup>)</b> |
|------------------|------------------------|---------------------------------------|
| Fire Station 111 | 3300 Bayview Ave       | 5,662                                 |
| Fire Station 112 | 5700 Bathurst St       | 7,018                                 |
| Fire Station 113 | 700 Seneca Hill Dr     | 4,833                                 |
| Fire Station 114 | 12 Canterbury Place    | 8,633                                 |
| Fire Station 115 | 115 Parkway Forest Dr  | 5,985                                 |
| Fire Station 116 | 2755A Old Leslie St    | 11,776                                |
| Fire Station 121 | 10 William Carson Cres | 4,219                                 |
| Fire Station 122 | 2545 Bayview Ave       | 3,046                                 |
| Fire Station 123 | 145 Bond Ave           | 2,497                                 |
| Fire Station 125 | 1109 Leslie Street     | 5,813                                 |
| Fire Station 131 | 3135 Yonge St          | 5,845                                 |
| Fire Station 132 | 476 Lawrence Ave W     | 7,664                                 |
| Fire Station 133 | 1505 Lawrence Ave W    | 8,062                                 |
| Fire Station 134 | 16 Montgomery Ave      | 7,126                                 |
| Fire Station 135 | 641 Eglinton Ave W     | 10,592                                |
| Fire Station 141 | 4100 Keele St          | 12,000                                |
| Fire Station 142 | 2753 Jane Street       | 5,586                                 |
| Fire Station 143 | 1009 Sheppard Ave W    | 2,895                                 |
| Fire Station 145 | 20 Beffort Rd          | 11,001                                |
| Fire Station 146 | 2220 Jane St           | 7,535                                 |
| Fire Station 211 | 900 Tapscott Rd        | 5,005                                 |
| Fire Station 212 | 8500 Sheppard Ave East | 16,501                                |
| Fire Station 213 | 7 Lapsley Rd           | 5,048                                 |
| Fire Station 214 | 745 Meadowvale Rd      | 4,887                                 |
| Fire Station 215 | 5318 Lawrence Ave E    | 5,737                                 |
| Fire Station 222 | 755 Warden Ave         | 6,910                                 |
| Fire Station 223 | 116 Dorset Rd          | 7,459                                 |
| Fire Station 224 | 1313 Woodbine Ave      | 3,767                                 |
| Fire Station 225 | 3600 Danforth Ave      | 9,085                                 |
| Fire Station 226 | 85 Main St             | 11,808                                |
| Fire Station 227 | 1904 Queen St E        | 10,484                                |
| Fire Station 231 | 740 Markham Rd         | 14,241                                |

| <b>Building</b>  | <b>Address</b>       | <b>Building Area (ft<sup>2</sup>)</b> |
|------------------|----------------------|---------------------------------------|
| Fire Station 232 | 1550 Midland Ave     | 5,350                                 |
| Fire Station 233 | 59 Curlew Dr         | 11,001                                |
| Fire Station 234 | 40 Coronation Dr     | 5,350                                 |
| Fire Station 235 | 200 Bermondsey Rd    | 8,902                                 |
| Fire Station 241 | 3325 Warden Ave      | 5,500                                 |
| Fire Station 242 | 2733 Brimley Rd      | 5,500                                 |
| Fire Station 243 | 4560 Sheppard Ave E  | 5,350                                 |
| Fire Station 244 | 2340 Birchmount Rd   | 5,350                                 |
| Fire Station 245 | 1600 Birchmount Rd   | 5,608                                 |
| Fire Station 311 | 20 Balmoral Ave      | 12,755                                |
| Fire Station 312 | 34 Yorkville Ave     | 9,806                                 |
| Fire Station 313 | 441 Bloor St E       | 12,099                                |
| Fire Station 314 | 12 Grosvenor St      | 11,937                                |
| Fire Station 315 | 132 Bellevue Ave     | 7,244                                 |
| Fire Station 321 | 231 McCrae Ave       | 7,535                                 |
| Fire Station 322 | 256 Cosburn Ave      | 7,535                                 |
| Fire Station 323 | 153 Chatham Ave      | 10,236                                |
| Fire Station 324 | 840 Gerrard St E     | 13,153                                |
| Fire Station 325 | 475 Dundas St E      | 10,129                                |
| Fire Station 331 | 31 Claremont St      | 10,979                                |
| Fire Station 332 | 260 Adelaide St W    | 24,865                                |
| Fire Station 333 | 201 Front St E       | 12,723                                |
| Fire Station 334 | 339 Queens Quay West | 13,003                                |
| Fire Station 335 | 235 Cibola Ave       | 4,402                                 |
| Fire Station 341 | 555 Oakwood Ave      | 9,268                                 |
| Fire Station 342 | 106 Ascot Ave        | 3,057                                 |
| Fire Station 343 | 65 Hendrick Ave      | 9,827                                 |
| Fire Station 344 | 240 Howland Ave      | 11,238                                |
| Fire Station 345 | 1287 Dufferin St     | 12,809                                |
| Fire Station 411 | 75 Toryork Dr        | 8,762                                 |
| Fire Station 412 | 267 Humberline Dr    | 7,029                                 |
| Fire Station 413 | 1549 Albion Rd       | 3,929                                 |
| Fire Station 415 | 2120 Kipling Ave     | 7,804                                 |
| Fire Station 421 | 6 Lambton Ave        | 9,461                                 |
| Fire Station 422 | 590 Jane St          | 7,944                                 |
| Fire Station 423 | 358 Keele St         | 12,335                                |
| Fire Station 424 | 462 Runnymede Rd     | 5,866                                 |

| <b>Building</b>         | <b>Address</b>       | <b>Building Area (ft<sup>2</sup>)</b> |
|-------------------------|----------------------|---------------------------------------|
| Fire Station 425        | 83 Deforest Rd       | 7,955                                 |
| Fire Station 426        | 140 Lansdowne Ave    | 12,486                                |
| Fire Station 431        | 308 Prince Edward Dr | 3,907                                 |
| Fire Station 432        | 155 The East Mall    | 13,692                                |
| Fire Station 433        | 615 Royal York Rd    | 5,038                                 |
| Fire Station 434        | 3 Lunness Rd         | 5,188                                 |
| Fire Station 435        | 130 Eighth St        | 6,889                                 |
| Fire Station 441        | 947 Martin Grove Rd  | 19,472                                |
| Fire Station 442        | 2015 Lawrence Ave W  | 15,478                                |
| Fire Station 443        | 1724 Islington Ave   | 3,929                                 |
| Fire Station 444        | 666 Renforth Dr      | 3,929                                 |
| Fire Station 445        | 280 Burnhamthorpe Rd | 11,765                                |
| Fire Stn former TO #35  | 11 Queens Quay W     | 3,143                                 |
| Fire Academy            | 895 Eastern Ave      | 61,214                                |
| Fire Museum And Storage | 351 Birchmount Rd    | 3,272                                 |
| Fire Training Centre    | 4562 Sheppard Ave E  | 7,998                                 |
| Husar Training Bldg     | N/A                  | 11,474                                |
| Rotherham Ave 15        | 15 Rotherham Ave     | 23,002                                |
| Toryork Office          | 40 Toryork           | 42,625                                |

**Table 102: Fire Station Building Information**

## 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 88 fire station buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| <b>Building</b>      | <b>2012 Total Electricity Intensity (kWh/ft<sup>2</sup>)</b> | <b>2012 Total Gas Intensity (ekWh/ft<sup>2</sup>)</b> | <b>2012 Total Energy Intensity (ekWh/ft<sup>2</sup>)</b> |
|----------------------|--|---|--|
| Fire Station 425     | 6.40   | 9.04  | 15.44  |
| Fire Station 441     | 6.31   | 10.56   | 16.87  |
| Fire Station 411     | 8.94   | 9.78  | 18.72  |
| Rotherham Ave 15     | 7.21   | 12.56   | 19.76  |
| Fire Training Centre | 8.04   | 12.05   | 20.09  |
| Fire Station 223     | 6.12   | 16.02   | 22.14  |
| Fire Station 432     | 2.56   | 20.45   | 23.01  |
| Fire Station 445     | 10.58  | 12.83   | 23.41  |
| Fire Station 332     | 12.05  | 12.19   | 24.24  |

| <b>Building</b>  | <b>2012 Total Electricity Intensity (kWh/ft<sup>2</sup>)</b> | <b>2012 Total Gas Intensity (ekWh/ft<sup>2</sup>)</b> | <b>2012 Total Energy Intensity (ekWh/ft<sup>2</sup>)</b> |
|------------------|--|---|--|
| Fire Station 314 | 4.45   | 19.87   | 24.31  |
| Fire Station 324 | 6.10   | 18.67   | 24.76  |
| Fire Station 243 | 9.42   | 15.57   | 24.98  |
| Fire Station 311 | 4.69   | 20.41   | 25.10  |
| Fire Station 415 | 9.14   | 16.35   | 25.50  |
| Fire Station 331 | 7.89   | 17.84   | 25.73  |
| Fire Station 435 | 12.14  | 14.16   | 26.30  |
| Fire Station 231 | 9.78   | 16.53   | 26.32  |
| Fire Station 434 | 5.68   | 21.15   | 26.83  |
| Fire Station 322 | 5.36   | 21.57   | 26.93  |
| Fire Station 343 | 5.01   | 21.95   | 26.96  |
| Fire Station 233 | 7.95   | 19.27   | 27.22  |
| Fire Station 146 | 7.56   | 19.68   | 27.24  |
| Fire Station 442 | 14.21  | 13.29   | 27.49  |
| Fire Station 125 | 11.07  | 16.61   | 27.68  |
| Fire Station 245 | 7.80   | 19.93   | 27.73  |
| Fire Station 421 | 10.65  | 17.09   | 27.74  |
| Fire Station 227 | 7.10   | 21.10   | 28.20  |
| Fire Station 133 | 11.93  | 17.03   | 28.96  |
| Fire Academy     | 11.82  | 17.41   | 29.23  |
| Fire Station 431 | 10.03  | 19.26   | 29.29  |
| Fire Station 226 | 5.88   | 24.24   | 30.11  |
| Fire Station 134 | 5.88   | 24.41   | 30.28  |
| Fire Station 423 | 8.52   | 21.94   | 30.46  |
| Fire Station 413 | 9.87   | 20.71   | 30.58  |
| Fire Station 422 | 7.94   | 22.68   | 30.62  |
| Fire Station 222 | 8.55   | 22.66   | 31.21  |
| Fire Station 241 | 8.25   | 23.06   | 31.31  |
| Fire Station 344 | 6.76   | 24.62   | 31.38  |
| Fire Station 444 | 7.29   | 24.30   | 31.59  |
| Fire Station 145 | 9.28   | 22.33   | 31.61  |
| Fire Station 215 | 10.98  | 20.91   | 31.90  |
| Fire Station 312 | 9.85   | 22.30   | 32.15  |
| Fire Station 325 | 8.92   | 23.46   | 32.39  |
| Fire Station 116 | 16.21  | 16.47   | 32.68  |
| Fire Station 234 | 9.02   | 23.68   | 32.70  |
| Fire Station 333 | 9.98   | 22.75   | 32.73  |

| <b>Building</b>         | <b>2012 Total Electricity Intensity (kWh/ft<sup>2</sup>)</b> | <b>2012 Total Gas Intensity (ekWh/ft<sup>2</sup>)</b> | <b>2012 Total Energy Intensity (ekWh/ft<sup>2</sup>)</b> |
|-------------------------|--|---|--|
| Fire Station 242        | 10.33  | 22.40   | 32.73  |
| Fire Station 132        | 12.07  | 21.16   | 33.24  |
| Fire Station 244        | 9.68   | 23.98   | 33.66  |
| Fire Station 443        | 8.85   | 24.93   | 33.78  |
| Fire Station 211        | 18.44  | 15.58   | 34.02  |
| Fire Station 225        | 10.54  | 23.75   | 34.29  |
| Fire Station 135        | 12.94  | 21.60   | 34.54  |
| Fire Station 232        | 13.54  | 21.11   | 34.65  |
| Fire Station 321        | 11.87  | 22.85   | 34.73  |
| Fire Station 235        | 12.02  | 23.97   | 36.00  |
| Fire Station 115        | 17.08  | 19.47   | 36.56  |
| Fire Station 433        | 19.63  | 17.60   | 37.23  |
| Fire Station 341        | 8.68   | 28.76   | 37.44  |
| Fire Station 214        | 11.95  | 25.51   | 37.46  |
| Husar Training Bldg     | 20.66  | 17.00   | 37.66  |
| Fire Station 424        | 9.78   | 27.98   | 37.77  |
| Fire Station 412        | 10.71  | 27.09   | 37.80  |
| Fire Station 426        | 14.10  | 23.95   | 38.05  |
| Fire Station 213        | 11.86  | 26.64   | 38.50  |
| Toryork Office          | 16.50  | 22.14   | 38.65  |
| Fire Station 212        | 13.29  | 25.95   | 39.24  |
| Fire Station 224        | 16.45  | 22.86   | 39.32  |
| Fire Station 345        | 9.68   | 30.55   | 40.23  |
| Fire Station 313        | 13.02  | 28.69   | 41.71  |
| Fire Station 342        | 9.26   | 32.97   | 42.23  |
| Fire Station 334        | 27.34  | 15.23   | 42.58  |
| Fire Station 323        | 10.99  | 31.60   | 42.59  |
| Fire Station 121        | 25.38  | 17.47   | 42.85  |
| Fire Station 335        | 25.73  | 17.67   | 43.39  |
| Fire Stn former TO #35  | 43.83  | 0.00  | 43.83  |
| Fire Station 141        | 13.24  | 30.98   | 44.22  |
| Fire Station 131        | 13.87  | 30.79   | 44.66  |
| Fire Station 315        | 14.32  | 34.20   | 48.51  |
| Fire Station 111        | 16.04  | 33.33   | 49.37  |
| Fire Station 113        | 16.51  | 33.25   | 49.76  |
| Fire Museum And Storage | 6.78   | 43.50   | 50.28  |
| Fire Station 122        | 17.07  | 41.71   | 58.78  |

| Building         | 2012 Total Electricity Intensity (kWh/ft <sup>2</sup> ) | 2012 Total Gas Intensity (ekWh/ft <sup>2</sup> ) | 2012 Total Energy Intensity (ekWh/ft <sup>2</sup> ) |
|------------------|---|--|---|
| Fire Station 142 | 21.43   | 38.17  | 59.59   |
| Fire Station 114 | 23.72   | 39.04  | 62.76   |
| Fire Station 112 | 31.48   | 34.03  | 65.51   |
| Fire Station 123 | 19.29   | 63.23  | 82.52   |
| Fire Station 143 | 24.59   | 66.94  | 91.53   |

Table 103: Fire Station 2012 Energy Intensity

### 5.3 Target-setting Method and Metrics

20 fire stations were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.

| Facility         | Days in 2012 | Energy type |
|------------------|--------------|-------------|
| Fire Station 116 | 335          | Gas         |
| Fire Station 122 | 333          | Electricity |
| Fire Station 123 | 394          | Electricity |
| Fire Station 132 | 398          | Electricity |
| Fire Station 134 | 396          | Electricity |
| Fire Station 141 | 336          | Gas         |
| Fire Station 143 | 399          | Electricity |
| Fire Station 146 | 399          | Electricity |
| Fire Station 211 | 454          | Electricity |
| Fire Station 223 | 334          | Gas         |
| Fire Station 227 | 334          | Electricity |
| Fire Station 311 | 452          | Electricity |
| Fire Station 314 | 399          | Electricity |
| Fire Station 321 | 460          | Electricity |
| Fire Station 412 | 327          | Electricity |
| Fire Station 423 | 333          | Electricity |
| Fire Station 431 | 397          | Electricity |
| Fire Station 441 | 728          | Gas         |
| Fire Station 442 | 395          | Electricity |
| Fire Station 445 | 394          | Electricity |


Table 104: Excluded Facilities

After excluding these 20 facilities, 68 City of Toronto facilities and 8 from other municipalities were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.


The red line on each chart indicates the top quartile for each component which is the target for that component.






**Figure 60: 2012 Electric Baseload Intensity Benchmark**

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for fire stations ranges from 1.9 to 32.4 ekWh/ft<sup>2</sup> and the top-quartile is 7.4 ekWh/ft<sup>2</sup>.




**Figure 61: 2012 Electric Cooling Intensity Benchmark**

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for fire stations ranges from 0 to 2.5 ekWh/ft<sup>2</sup> and the top-quartile is 0.5 ekWh/ft<sup>2</sup>.




**Figure 62: 2012 Electric Heating Intensity Benchmark**

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for fire stations ranges from 0 to 12.9 ekWh/ft<sup>2</sup> and the top-quartile is 0.6 ekWh/ft<sup>2</sup>.



**Figure 63: 2012 Gas Baseload Intensity Benchmark**

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for fire stations ranges from 0 to 9.3 ekWh/ft<sup>2</sup> and the top-quartile is 1.7 ekWh/ft<sup>2</sup>.



**Figure 64: 2012 Gas Heating Intensity Benchmark**

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for fire stations ranges from 7.0 to 41.2 ekWh/ft<sup>2</sup> and the top-quartile is 14.7 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of fire stations, the factors are

% of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps, and % of the area served by electric air conditioning.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 34 Mid Savings Potential Fire Stations

Buildings are sorted by total annual savings potential, starting with the highest saving potential buildings.

There are 34 fire stations with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |           | Indoor Area<br>ft² | GHG Emissions<br>kg/yr |         |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|-----------|--------------------|------------------------|---------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           |         | \$/yr | Avg %                          | \$/yr | Electricity | Gas       |                    |                        |         |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load | Heating |       |                                |       |             |           |                    |                        | Total   |
| Mid-potential savings facilities (34) | 46%                           | 41%     | 53%     | 46%   | \$387,007             | 49%       | 29%     | 33%   | \$ 72,706                      | 38%   | \$459,713   | \$221,147 | \$27,964           | 383,732                | 829,515 |
| Torvork Office                        | 52%                           |         |         | 49%   | \$ 47,797             |           | 31%     | 30%   | \$ 7,228                       | 38%   | \$ 55,026   | \$ 27,313 | \$ 2,780           | 42,625                 | 89,792  |
| Fire Station 334                      | 69%                           |         | 90%     | 76%   | \$ 37,903             | 28%       |         | 4%    | \$ 220                         | 50%   | \$ 38,123   | \$ 21,659 | \$ 85              | 13,003                 | 31,371  |
| Fire Academy                          | 27%                           | 44%     | 24%     | 28%   | \$ 28,709             | 49%       |         | 9%    | \$ 2,511                       | 17%   | \$ 31,220   | \$ 16,405 | \$ 966             | 61,214                 | 40,705  |
| Fire Station 112                      | 73%                           | 64%     | 77%     | 73%   | \$ 22,648             | 59%       | 50%     | 51%   | \$ 3,075                       | 62%   | \$ 25,723   | \$ 12,942 | \$ 1,183           | 7,018                  | 40,016  |
| Fire Station 114                      | 64%                           | 67%     | 68%     | 64%   | \$ 18,483             | 56%       | 58%     | 57%   | \$ 4,865                       | 60%   | \$ 23,348   | \$ 10,562 | \$ 1,871           | 8,633                  | 49,682  |
| Husar Training Bldg                   | 57%                           |         | 79%     | 58%   | \$ 19,382             |           | 10%     | 10%   | \$ 478                         | 36%   | \$ 19,860   | \$ 11,076 | \$ 184             | 11,474                 | 18,682  |
| Fire Station 332                      | 34%                           | 42%     |         | 35%   | \$ 14,723             | 56%       |         | 18%   | \$ 1,378                       | 27%   | \$ 16,101   | \$ 8,413  | \$ 530             | 24,865                 | 21,530  |
| Fire Station 212                      | 40%                           | 22%     |         | 38%   | \$ 11,803             | 47%       | 37%     | 38%   | \$ 4,131                       | 38%   | \$ 15,934   | \$ 6,745  | \$ 1,589           | 16,501                 | 39,128  |
| Fire Station 426                      | 47%                           | 56%     |         | 51%   | \$ 12,633             | 10%       | 33%     | 31%   | \$ 2,335                       | 39%   | \$ 14,968   | \$ 7,219  | \$ 898             | 12,486                 | 26,801  |
| Fire Station 142                      | 63%                           | 44%     |         | 62%   | \$ 10,326             | 71%       | 54%     | 57%   | \$ 3,035                       | 58%   | \$ 13,361   | \$ 5,900  | \$ 1,167           | 5,586                  | 30,048  |
| Fire Station 116                      |                               |         |         | 48%   | \$ 12,803             |           |         | 0%    | \$ 7                           | 24%   | \$ 12,810   | \$ 7,316  | \$ 3               | 11,776                 | 10,107  |
| Fire Station 335                      | 73%                           |         |         | 78%   | \$ 12,368             | 49%       |         | 10%   | \$ 186                         | 50%   | \$ 12,554   | \$ 7,067  | \$ 72              | 4,402                  | 11,062  |
| Fire Station 141                      |                               |         |         | 36%   | \$ 8,067              |           |         | 47%   | \$ 4,380                       | 44%   | \$ 12,447   | \$ 4,610  | \$ 1,684           | 12,000                 | 37,989  |
| Fire Station 442                      |                               |         |         | 39%   | \$ 11,988             |           |         | 0%    | \$ -                           | 20%   | \$ 11,988   | \$ 6,851  | \$ -               | 15,478                 | 9,419   |
| Fire Station 313                      | 37%                           | 36%     |         | 35%   | \$ 7,821              | 69%       | 36%     | 42%   | \$ 3,700                       | 40%   | \$ 11,521   | \$ 4,469  | \$ 1,423           | 12,099                 | 32,882  |
| Fire Stn former TO #35                | 73%                           |         | 10%     | 57%   | \$ 10,982             |           |         |       | \$ -                           | 57%   | \$ 10,982   | \$ 6,275  | \$ -               | 3,143                  | 8,629   |
| Fire Station 143                      |                               |         |         | 66%   | \$ 6,545              |           |         | 75%   | \$ 3,673                       | 73%   | \$ 10,218   | \$ 3,740  | \$ 1,413           | 2,895                  | 31,685  |
| Fire Station 121                      | 65%                           | 71%     | 77%     | 66%   | \$ 9,953              | 35%       | 0%      | 5%    | \$ 101                         | 42%   | \$ 10,054   | \$ 5,687  | \$ 39              | 4,219                  | 8,552   |
| Fire Station 135                      | 41%                           |         | 41%     | 43%   | \$ 8,267              | 5%        | 25%     | 23%   | \$ 1,338                       | 31%   | \$ 9,605    | \$ 4,724  | \$ 514             | 10,592                 | 16,162  |
| Fire Station 315                      | 41%                           |         | 63%     | 42%   | \$ 6,089              | 81%       | 41%     | 51%   | \$ 3,201                       | 49%   | \$ 9,290    | \$ 3,480  | \$ 1,231           | 7,244                  | 27,916  |
| Fire Station 111                      | 49%                           | 45%     | 9%      | 47%   | \$ 5,917              | 56%       | 50%     | 50%   | \$ 2,389                       | 49%   | \$ 8,306    | \$ 3,381  | \$ 919             | 5,662                  | 21,915  |
| Fire Station 323                      | 27%                           | 33%     |         | 27%   | \$ 4,217              | 55%       | 47%     | 48%   | \$ 3,876                       | 42%   | \$ 8,093    | \$ 2,410  | \$ 1,491           | 10,236                 | 31,323  |
| Fire Station 433                      | 54%                           |         | 81%     | 57%   | \$ 7,859              | 39%       |         | 6%    | \$ 138                         | 33%   | \$ 7,997    | \$ 4,491  | \$ 53              | 5,038                  | 7,175   |
| Fire Station 115                      | 42%                           | 56%     | 83%     | 51%   | \$ 7,247              |           | 22%     | 22%   | \$ 632                         | 35%   | \$ 7,879    | \$ 4,141  | \$ 243             | 5,985                  | 10,261  |
| Fire Station 113                      | 46%                           | 75%     |         | 46%   | \$ 5,167              | 62%       | 49%     | 50%   | \$ 2,030                       | 49%   | \$ 7,197    | \$ 2,953  | \$ 781             | 4,833                  | 18,728  |
| Fire Station 131                      | 44%                           | 33%     |         | 43%   | \$ 4,934              |           | 49%     | 46%   | \$ 2,100                       | 46%   | \$ 7,034    | \$ 2,819  | \$ 808             | 5,845                  | 19,054  |
| Fire Station 211                      |                               |         |         | 54%   | \$ 7,004              |           |         | 0%    | \$ -                           | 29%   | \$ 7,004    | \$ 4,002  | \$ -               | 5,005                  | 5,503   |
| Fire Station 123                      |                               |         |         | 56%   | \$ 3,792              |           |         | 74%   | \$ 2,935                       | 70%   | \$ 6,727    | \$ 2,167  | \$ 1,129           | 2,497                  | 24,189  |
| Fire Station 235                      | 31%                           | 53%     |         | 32%   | \$ 4,870              |           | 36%     | 34%   | \$ 1,822                       | 33%   | \$ 6,692    | \$ 2,783  | \$ 701             | 8,902                  | 16,990  |
| Fire Station 325                      | 28%                           |         |         | 32%   | \$ 4,105              | 58%       | 24%     | 30%   | \$ 1,807                       | 31%   | \$ 5,913    | \$ 2,346  | \$ 695             | 10,129                 | 16,285  |
| Fire Station 345                      | 2%                            | 50%     | 14%     | 7%    | \$ 1,211              | 55%       | 45%     | 46%   | \$ 4,530                       | 37%   | \$ 5,741    | \$ 692    | \$ 1,742           | 12,809                 | 33,687  |
| Fire Station 122                      |                               |         |         | 51%   | \$ 3,679              |           |         | 61%   | \$ 1,933                       | 58%   | \$ 5,612    | \$ 2,103  | \$ 743             | 3,046                  | 16,859  |
| Fire Station 333                      | 19%                           | 9%      |         | 18%   | \$ 3,162              | 47%       | 25%     | 28%   | \$ 2,065                       | 25%   | \$ 5,227    | \$ 1,807  | \$ 794             | 12,723                 | 17,411  |
| Fire Station 224                      | 49%                           | 76%     |         | 52%   | \$ 4,549              | 56%       | 22%     | 28%   | \$ 609                         | 38%   | \$ 5,158    | \$ 2,600  | \$ 234             | 3,767                  | 7,974   |

Table 105: Savings Potential for 34 Medium Savings Potential Fire Stations

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.



Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

Average % savings for each energy component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) / \text{Actual Energy Use}$  and \$/year savings for each component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) * \text{utility company rates}$  \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Indoor Recreational Facilities

---

## Table of Contents

|       |   |     |
|-------|---|-----|
| 1     | Benchmarking and Conservation Potential .....   | 219 |
| 1.1   | Energy Use and Building Characteristics.....  | 219 |
| 1.1.1 | Building Characteristics.....   | 219 |
| 1.1.2 | Summary of Energy Use and Costs .....   | 219 |
| 1.2   | Energy Targets.....   | 222 |
| 1.3   | Savings Potential.....  | 223 |
| 2     | Conservation Measures and Budget.....   | 225 |
| 2.1   | Previous Energy Efficiency Initiatives.....   | 225 |
| 2.2   | Proposed Energy Efficiency Measures .....   | 225 |
| 3     | Energy Management and Retrofit Plan .....   | 232 |
| 3.1   | Implementation Costs and Modeled Savings .....  | 232 |
| 3.2   | Implementation Process and Tools – Determining the Specific Measures for Each Building .. | 232 |
| 3.2.1 | Building Performance Audit.....   | 233 |
| 3.2.2 | Energy Assessment .....   | 234 |
| 3.2.3 | Energy Savings Checklist .....  | 234 |
| 3.3   | Implementation Budget.....  | 235 |
| 3.4   | 10-Year Implementation Plan .....   | 235 |
| 4     | Appendix A.....   | 237 |
| 4.1   | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....     | 237 |
| 4.2   | Determining Energy Use Components.....  | 238 |
| 4.3   | Determining Targets .....   | 238 |
| 4.4   | Calculating Potential Savings .....   | 240 |
| 4.5   | Implementation Costs by Measure Type and Modeled Savings.....                             | 240 |
| 4.6   | Assessment Tools.....   | 241 |
| 5     | Appendix B - Indoor Recreational Facilities .....   | 243 |
| 5.1   | Buildings and Building Characteristics .....  | 243 |
| 5.2   | Energy Use Intensities.....   | 244 |
| 5.3   | Target-setting Method and Metrics.....  | 245 |
| 5.4   | Savings Potential by Energy Use Component .....   | 249 |

## List of Tables

|   |     |
|---|-----|
| Table 107: Current Renewable Energy Systems on Indoor Recreational Facilities .....                 | 219 |
| Table 108: 2012 Energy Use and Costs for 46 City of Toronto Indoor Recreational Facilities .....    | 220 |
| Table 109: Top Quartile Targets .....   | 222 |
| Table 110: Savings Potential Summary .....  | 223 |
| Table 111: Savings Potential based on Energy Use Component for Indoor Recreational Facilities ..... | 224 |
| Table 112: 2008 Recreation Centre Lighting Project Estimated Project Costs and Savings .....        | 225 |
| Table 106: Energy Saving Measures for Indoor Recreational Facilities .....                          | 230 |
| Table 114: Proposed Renewable Energy Systems on Indoor Recreational Facilities .....                | 231 |
| Table 115: Estimated Implementation Costs and Modeled Savings .....                                 | 232 |
| Table 116: Assessment Tools Used to Determine Specific Energy-saving Measures .....                 | 233 |
| Table 117: Total Budget - Energy Management and Retrofit Plan .....                                 | 235 |
| Table 118: Cash Flow for 10-Year Implementation Plan .....  | 237 |
| Table 119: Implementation Costs by Measure Type .....   | 240 |
| Table 120: Indoor Recreational Facility Building Information .....                                  | 244 |
| Table 121: Indoor Recreational Facility 2012 Energy Intensity .....                                 | 245 |
| Table 122: Excluded Facilities .....  | 246 |
| Table 123: Savings Potential for 8 High Savings Potential Indoor Recreational Facilities .....      | 249 |
| Table 124: Savings Potential for 24 Medium Savings Potential Indoor Recreational Facilities .....   | 250 |
| Table 125: Savings Potential for 14 Low Savings Potential Indoor Recreational Facilities .....      | 250 |

## List of Figures

|  |     |
|--|-----|
| Figure 65: 2012 Energy Use and Cost Breakdown City of Toronto Indoor Recreational Facilities ..... | 220 |
| Figure 66: 2012 Total Energy Intensity Benchmark .....   | 221 |
| Figure 67: 2012 Total Electricity Intensity Benchmark .....  | 221 |
| Figure 68: 2012 Total Gas Intensity Benchmark .....  | 222 |
| Figure 69: Cash Flow for 10-Year Implementation Plan .....   | 237 |
| Figure 70: 2012 Electric Baseload Intensity Benchmark .....  | 246 |
| Figure 71: 2012 Electric Cooling Intensity Benchmark .....   | 247 |
| Figure 72: 2012 Electric Heating Intensity Benchmark .....   | 247 |
| Figure 73: 2012 Gas Baseload Intensity Benchmark .....   | 248 |
| Figure 74: 2012 Gas Heating Intensity Benchmark .....  | 248 |



## 1 Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 46 indoor recreational facilities in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B.

The total area for all of the buildings is 1,477,712 ft<sup>2</sup>. Indoor recreational facilities range in size from just over 1,000 ft<sup>2</sup> to almost 140,000 ft<sup>2</sup>.

Facilities equipped with renewable energy systems are presented in the following table:

| Building Name             | Building Address   | Renewable Installation | System Size | Unit |
|---------------------------|--------------------|------------------------|-------------|------|
| Agincourt Rec Centre      | 31 Glen Watford Dr | Solar Pool Heating     | 166         | kW   |
| Jimmie Simpson Rec Centre | 870 Queen St E     | Solar Pool Heating     | 280         | kW   |
| Roding CC                 | 600 Roding St      | Solar Photovoltaic     | 75          | kW   |
| Goulding CC               | 45 Goulding Ave    | Solar Photovoltaic     | 75          | kW   |

**Table 107: Current Renewable Energy Systems on Indoor Recreational Facilities**

The facilities range from 0% to 100% air-conditioned. No facilities are fully served by electric heat and there are a number of other facilities using between 5 and 25% electric heat. No facilities are served by ground or water source heat pumps. There are food services at a number of facilities, ranging from 2 to 50% of building served.

The indoor recreational facilities fall into four types:

- Facilities with indoor ice rinks only
- Facilities with indoor pools only
- Facilities with both indoor rinks and indoor pools
- Facilities without indoor rinks or indoor pools

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section ‘Selection of 2012 utility bills for calculation of actual energy use intensities’) for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 46 buildings are summarized below.

|                               | 2012 Energy Use |                    |
|-------------------------------|-----------------|--------------------|
|                               | Unit            | \$                 |
| Electricity (kWh)             | 32,122,056      | \$4,497,088        |
| Natural Gas (m <sup>3</sup> ) | 3,783,217       | \$983,636          |
| <b>Total</b>                  |                 | <b>\$5,480,724</b> |

Table 108: 2012 Energy Use and Costs for 46 City of Toronto Indoor Recreational Facilities




Figure 65: 2012 Energy Use and Cost Breakdown City of Toronto Indoor Recreational Facilities

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 46 buildings. Total energy use ranges from approximately 2.2 to 86.4 kWh/ft<sup>2</sup>. There are also wide ranges for electricity and gas use per ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 66: 2012 Total Energy Intensity Benchmark




Figure 67: 2012 Total Electricity Intensity Benchmark




Figure 68: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for indoor recreational facilities are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each indoor recreational facility to achieve its target over the duration of the ECDM Plan.

| Energy type  | Component | Value | Unit            |
|--------------|-----------|-------|-----------------|
| Electricity  | Base      | 9.2   | kWh/sq ft/year  |
|              | Cooling   | 0.8   | kWh/sq ft/year  |
|              | Heating   | 1.8   | kWh/sq ft/year  |
|              | Total     | 11.8  | kWh/sq ft/year  |
| Gas          | Base      | 1.8   | ekWh/sq ft/year |
|              | Heating   | 9.7   | ekWh/sq ft/year |
|              | Total     | 11.5  | ekWh/sq ft/year |
| Total energy | Total     | 23.3  | ekWh/sq ft/year |

Table 109: Top Quartile Targets

The data set for target-setting is made up of 79 indoor recreational facilities and community centres with complete and reliable data, all of which are City of Toronto facilities. Recreational facilities and community centres were combined to provide a larger data set, since they are facilities of similar type. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water

(DHW)), % of the area which is air conditioned, % of the area served by food services. The targets for facilities with indoor rinks are adjusted for size of the ice surface and time period that the ice is in. The targets for facilities with indoor pools are adjusted for the size of the pool. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each indoor recreational facility. The total savings potential for each indoor recreational facility is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 46 indoor recreational facilities are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are 8 indoor recreational facilities with annual savings potential greater than \$100,000. 24 indoor recreational facilities have annual savings potential between \$5,000 and \$100,000, and 14 indoor recreational facilities have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 46 buildings is \$2,633,308 (\$2,121,029 for electricity and \$512,279 for gas) with an average total energy savings of 50%.

For the 8 high-potential savings facilities, the total annual savings potential is \$1,740,882 (\$1,501,903 for electricity and \$238,979 for gas) with an average total energy savings of 63%.

For the 24 mid-potential savings facilities, the total annual savings potential is \$869,097 (\$605,918 for electricity and \$263,179 for gas) with an average total energy savings of 41%.

For the 14 low-potential savings facilities, the total annual savings potential is \$23,329 (\$13,208 for electricity and \$10,121 for gas) with an average total energy savings of 20%.


| Operation name                        | Electricity Savings Potential |            |            |            | \$/yr              | Gas Savings Potential |            |            | \$/yr            | Total Energy Savings Potential |                    | Incentives         |                  | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|------------|------------|------------|--------------------|-----------------------|------------|------------|------------------|--------------------------------|--------------------|--------------------|------------------|--------------------------------|------------------------|
|                                       | Average %                     |            |            |            |                    | Average %             |            |            |                  | Avg %                          | \$/yr              | Electricity        | Gas              |                                |                        |
|                                       | Base-load                     | Cooling    | Heating    | Total      | Base-load          | Heating               | Total      |            |                  |                                |                    |                    |                  |                                |                        |
| <b>TOTAL: 46 facilities</b>           | <b>48%</b>                    | <b>64%</b> | <b>59%</b> | <b>47%</b> | <b>\$2,121,029</b> | <b>65%</b>            | <b>45%</b> | <b>52%</b> | <b>\$512,279</b> | <b>50%</b>                     | <b>\$2,633,308</b> | <b>\$1,212,017</b> | <b>\$197,030</b> | <b>1,477,712</b>               | <b>5,368,725</b>       |
| High potential savings facilities (8) | 66%                           | 100%       | 54%        | 66%        | \$ 1,501,903       | 85%                   | 38%        | 59%        | \$238,979        | 63%                            | \$1,740,882        | \$ 858,231         | \$ 91,915        | 573,857                        | 2,907,148              |
| Mid-potential savings facilities (24) | 27%                           | 46%        | 62%        | 29%        | \$ 605,918         | 43%                   | 50%        | 49%        | \$263,179        | 41%                            | \$ 869,097         | \$ 346,239         | \$101,223        | 775,356                        | 2,378,053              |
| Low potential savings facilities (14) | 08%                           | 100%       | 08%        | 10%        | \$ 13,208          | 02%                   | 38%        | 27%        | \$ 10,121        | 20%                            | \$ 23,329          | \$ 7,547           | \$ 3,893         | 128,499                        | 83,524                 |

**Table 110: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 46 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 22.5        | 11.7        | 48%                 | \$ 1,960,904         |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 1.1         | 0.4         | 64%                 | \$ 69,756            |
| Electric Heating (kWh/ft <sup>2</sup> )   | 1.2         | 0.5         | 59%                 | \$ 49,457            |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 8.9         | 7.3         | 18%                 | \$ 40,912            |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 10.5        | 3.6         | 65%                 | \$ 222,100           |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 17.3        | 9.5         | 45%                 | \$ 254,664           |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 17.4        | 9.8         | 44%                 | \$ 35,514            |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>48.2</b> | <b>24.2</b> | <b>50%</b>          | <b>\$ 2,633,308</b>  |



**Table 111: Savings Potential based on Energy Use Component for Indoor Recreational Facilities**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2008, the City of Toronto undertook a study to identify lighting improvement measures that would improve energy efficiency and reduce the operating cost and environmental impact of recreation centres located throughout the City of Toronto.

Table 5 below summarizes the estimated overall project costs, savings and estimated energy reduction for 124 recreation centres as a result of the 2008 lighting project.

| Project Name & Year             | Num. of Bldgs | Total Floor Area (m2) | Project Cost & Annual Savings (estimated) |                 |                    |                            | Estimated Energy Reduction |                         |                        |                        |                  |
|---------------------------------|---------------|-----------------------|---|-----------------|--------------------|----------------------------|----------------------------|-------------------------|------------------------|------------------------|------------------|
|                                 |               |                       | Retrofit Cost                             | Total \$Savings | Total ekWh Savings | Total CO2 Savings (tonnes) | Payback                    | Electricity Savings kWh | Electricity Savings kW | Natural Gas Savings m3 | Water Savings m3 |
| Recreation Center Lighting 2008 | 124           | 30,000                | \$1,750,000                               | \$218,750       | 2,302,600          | 562                        | 8.0                        | 2,302,600               | 700                    | 0                      | 0                |

**Table 112: 2008 Recreation Centre Lighting Project Estimated Project Costs and Savings**

In 2004, the City of Toronto undertook a study to identify building improvement measures that would improve energy and water efficiency and reduce the operating cost and environmental impact of arenas located throughout the City of Toronto. The following measures are only applicable to the indoor recreational facilities that have arenas.

The design and construction of the measures took place from January 2005 to June 2007. Various Energy Conservation Measures (ECMs) were installed in 89 ice arenas, outdoor rinks and community centres. The majority of the indoor arenas in this ECDM Plan were part of this 2004 project. These measures included design and retrofit of energy efficient lighting, lighting controls, improved temperature controls, ventilation controls, insulation, building envelope and refrigeration controls. Training and energy awareness was also provided as part of this project.

### 2.2 Proposed Energy Efficiency Measures

Table 6 below shows the full range of possible energy efficiency measures for the entire portfolio of indoor recreational facilities. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 46 facilities indicate that the largest percentage reductions will come from measures associated with electric cooling, electric heating and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

- 4 – Savings potential is greater than 40%
- 3 – Savings potential is 30-40%
- 2 – Savings potential is 20-30%
- 1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

- 4 – Measure can be done immediately by building occupants or service contractors (little/no cost)
- 3 – Measure involves testing, tuning, measuring (low cost)
- 2 – Measure involves significant investigation/optimization (more significant costs)
- 1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).



| Electric Baseload Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>ELECTRIC BASELOAD - refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent</b> |  |                        |                          |             |          |                       |                    |
| B1   | Turn off/unplug machines, office and kitchen equipment, chargers when not needed                 | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B2   | Enable ENERGY STAR power settings, turn off computers when not in use                            | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B3   | Turn off lights when areas not in use  | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| B4   | Make use of natural light instead of turning on lights where possible                            | 4                      | 4                        | 8           | Year 1   | Annual Review         | Building Occupants |
| P1   | Upgrade control of under-pad heating   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P3   | Upgrade/adjust ice temperature control   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P6   | Repair low-emissivity ceiling  | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P10  | Install compressor head pressure control   | 4                      | 4                        | 8           | Year 1   | Seasonal Review       |                    |
| P2   | Lower water use for ice resurfacing  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P4   | Implement ice temperature reset based on types of use  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P5   | Reduce ice thickness   | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| P7   | Reduce brine pump operation  | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| M1   | Optimize operating schedules for fans and pumps  | 3                      | 4                        | 7           | Year 2   | Seasonal Review       |                    |
| M2   | Test and adjust ventilation systems to reduce fan power  | 3                      | 4                        | 7           | Year 2   | Seasonal Review       |                    |
| P8   | Reduce rink lighting operation   | 4                      | 4                        | 8           | Year 2   | Seasonal Review       |                    |
| EL4  | Install power factor correction  | 3                      | 4                        | 7           | Year 2   | 15+                   |                    |
| P11  | Insulate brine headers   | 3                      | 4                        | 7           | Year 2   | 5 to 10               |                    |
| P9   | Install/make better use of multi-level rink lighting control                                     | 2                      | 4                        | 6           | Year 3   | Seasonal Review       |                    |
| L1   | Replace incandescent and halogen light bulbs with high efficiency lighting                       | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L2   | Install motion sensors in washrooms/occasional use spaces to shut                                | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L3   | Install photo-sensors and/or a timer on outdoor and daylight interior area lighting              | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L4   | Replace HID lighting with high efficiency fluorescent  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L5   | Replace outdoor lights and signage with high efficiency fixtures                                 | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L6   | Replace festive lighting with LED  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| L7   | Install sufficient manual switching to allow occupants to effectively control lighting operation | 1                      | 4                        | 5           | Year 4   | 15+                   |                    |
| EL1  | Replace refrigerators, dishwasher, microwaves with ENERGY STAR rated appliances                  | 1                      | 4                        | 5           | Year 4   | 8 to 12               |                    |
| EL2  | Replace computers with ENERGY STAR rated units   | 1                      | 4                        | 5           | Year 4   | 4 to 6                |                    |
| EL3  | Install controls on vending machines   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| EN1  | Install low-emissivity ceiling   | 1                      | 4                        | 5           | Year 4   | 10 to 12              |                    |
| M3   | Replace/right-size pumps   | 1                      | 4                        | 5           | Year 4   | 10 to 20              |                    |
| M4   | Install variable speed drive on brine pump   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M5   | Install multi-pass refrigerant pipe configuration  | 1                      | 4                        | 5           | Year 4   | 20 to 30              |                    |
| M6   | Install de-ionized water system  | 1                      | 4                        | 5           | Year 4   | 5 to 10               |                    |
| M7   | Replace ice resurfacer with high efficiency unit   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M8   | Replace ice plant with high efficiency unit  | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M9   | Install variable frequency drives (VFDs) on suitable fans and pumps                              | 1                      | 4                        | 5           | Year 4   | 10 to 20              |                    |
| M10  | Convert electric hot water heaters to natural gas  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| Other: _____   |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |
| _____  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
Operational Measures  
Retrofit/Capital Measures

| Electric Heating Measures |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility |
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|

**ELECTRIC HEATING (IF APPLICABLE) - refers to electricity use for heating purposes**

|              |  |   |   |   |        |                 |                    |
|--------------|--|---|---|---|--------|-----------------|--------------------|
| B5           | Adjust blinds (to retain heat in winter)   | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B6           | Avoid use of electric heaters  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B7           | Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| M11          | Control fan coil and entrance heaters to optimize run-times                                | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M12          | Evaluate conversion from electric heating to natural gas                                   | 2 | 4 | 6 | Year 2 | n/a             |                    |
| M13          | Convert electric to gas dehumidifiers  | 1 | 4 | 5 | Year 2 | 15 to 20        |                    |
| P12          | Control car plug-in outlets  | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M14          | Install snow sensors to control the snow-melting system                                    | 1 | 4 | 5 | Year 4 | seasonal review |                    |
| M15          | Upgrade base building heating system to avoid use of electric heaters                      | 1 | 4 | 5 | Year 4 | seasonal review |                    |
| M16          | Upgrade electric heating controls to optimize space temperatures and operating periods     | 1 | 4 | 5 | Year 4 | seasonal review |                    |
| Other: _____ |  |   |   |   |        |                 |                    |
| _____        |  |   |   |   |        |                 |                    |
| _____        |  |   |   |   |        |                 |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Electric Cooling Measures |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility |
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|
|---------------------------|--|------------------------|--------------------------|-------------|----------|-----------------------|----------------|

**ELECTRIC COOLING (IF APPLICABLE) - refers to electricity use for cooling purposes**

|              |  |   |   |   |        |                 |                    |
|--------------|--|---|---|---|--------|-----------------|--------------------|
| B8           | Use recommended thermostat set points (during the summer, set to 78 degrees or more)         | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B9           | Only cool rooms that are being used  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B10          | Install and use energy efficient ceiling fans  | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B11          | Close blinds (to shade space from direct sunlight)   | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| B12          | Install window film, solar screens or awnings on south and west facing windows               | 4 | 4 | 8 | Year 1 | annual review   | Building Occupants |
| P13          | Upgrade/adjust dehumidifier controls   | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M18          | Upgrade control of air conditioning units to optimize space temperatures & operating periods | 3 | 4 | 7 | Year 2 | seasonal review |                    |
| M19          | Test and tune the air conditioning units   | 3 | 4 | 7 | Year 2 | 3               |                    |
| M17          | Optimize operating periods of ventilation systems supplying air conditioned spaces           | 2 | 4 | 6 | Year 2 | seasonal review |                    |
| M20          | Replace and right-size air conditioning units with ENERGY STAR rated units                   | 1 | 4 | 5 | Year 4 | 10 to 15        |                    |
| Other: _____ |  |   |   |   |        |                 |                    |
| _____        |  |   |   |   |        |                 |                    |
| _____        |  |   |   |   |        |                 |                    |

Behavioural Measures  
 Operational Measures  
 Retrofit/Capital Measures

| Gas Baseload Measures   |   | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|---|---|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| GAS BASELOAD - refers to the annual natural gas energy used for domestic hot water and other equipment that runs year round |   |                        |                          |             |          |                       |                    |
| B13   | Optimize dishwasher operation (only run when full)          | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| P16   | Identify and repair hot water leaks                         | 4                      | 4                        | 8           | Year 1   | annual review         |                    |
| P15   | Test and tune DHW boiler efficiency                         | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| M21   | Investigate and repair possible gas leaks                   | 3                      | 4                        | 7           | Year 2   | annual review         |                    |
| P19   | Optimize pool water temperature control, reset based on use | 4                      | 4                        | 8           | Year 2   | seasonal review       |                    |
| P14   | Optimize DHW temperature control                            | 2                      | 4                        | 6           | Year 2   | annual review         |                    |
| M22   | Insulate DHW tanks and distribution piping                  | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| P17   | Implement DHW circulation pump control                      | 1                      | 4                        | 5           | Year 2   | annual review         |                    |
| P18   | Install low flow showerheads and faucet aerators            | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M23   | Install ice plant heat recovery                             | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M24   | Install solar hot water heating                             | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M25   | Install heat recovery dehumidification system               | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M26   | Replace DHW boilers with more efficient models              | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| Other:  |   |                        |                          |             |          |                       |                    |
|   |   |                        |                          |             |          |                       |                    |
|   |   |                        |                          |             |          |                       |                    |

- Behavioural Measures
- Operational Measures
- Retrofit/Capital Measures

| Gas Heating Measures   |  | Ease of Implementation | Energy Savings Potential | Total Score | Timeline | Life Expectancy (yrs) | Responsibility     |
|--|--|------------------------|--------------------------|-------------|----------|-----------------------|--------------------|
| <b>GAS HEATING - refers to the additional energy used in winter for heating and humidification</b> |  |                        |                          |             |          |                       |                    |
| B14  | Check and clear baseboard heaters of obstructions  | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B15  | Adjust blinds (to retain heat in winter)<br>Use recommended thermostat set points (in winter set to 68 degrees or less during daytime) | 4                      | 4                        | 8           | Year 1   | annual review         | Building Occupants |
| B16  | Isolate idle boilers   | 4                      | 4                        | 8           | Year 1   | seasonal review       | Building Occupants |
| P21  | Reduce circulating pump operation in mild weather  | 4                      | 4                        | 8           | Year 1   | seasonal review       |                    |
| P22  | Optimize operating periods of ventilation systems  | 2                      | 4                        | 6           | Year 2   | seasonal review       |                    |
| M27  | Test and adjust ventilation systems to optimize outside air volumes  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M28  | Test and tune boiler efficiency  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M29  | Check heating system for flow balancing and air venting  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M30  | Check and seal exterior walls and openings   | 3                      | 4                        | 7           | Year 2   | 10 to 15              |                    |
| EN2  | Seal window and door frames  | 3                      | 4                        | 7           | Year 2   | 5                     |                    |
| EN3  | Insulate and seal dividing walls between arena and heated areas  | 3                      | 4                        | 7           | Year 2   | 5                     |                    |
| EN4  | Optimize fan-coil unit and entrance heater controls  | 3                      | 4                        | 7           | Year 2   | seasonal review       |                    |
| M29  | Control loading dock heating   | 4                      | 4                        | 8           | Year 2   | annual review         |                    |
| P20  | Test, repair, replace and right-size heating control valves and outside air dampers  | 2                      | 4                        | 6           | Year 3   | 10 to 15              |                    |
| M32  | Replace spectator heating system with radiant heat   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M31  | Upgrade heating system control to optimize space temperatures and operating periods  | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M33  | Replace single-pane windows with double-pane windows   | 1                      | 4                        | 5           | Year 4   | 20 to 25              |                    |
| EN5  | If replacing the roof, ensure R-value at least 22  | 1                      | 4                        | 5           | Year 4   | n/a                   |                    |
| EN6  | Install high efficiency burners  | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M34  | Replace boilers with more efficient models   | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M35  | Replace old rooftop units with energy efficient units  | 1                      | 4                        | 5           | Year 4   | 15 to 20              |                    |
| M36  | Install heat recovery or solar heating units   | 1                      | 4                        | 5           | Year 4   | 10 to 15              |                    |
| M37  | Other:   |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |
|  |  |                        |                          |             |          |                       |                    |

Behavioural Measures  
Operational Measures  
Retrofit/Capital Measures

**Table 113: Energy Saving Measures for Indoor Recreational Facilities**

The specific measures and implementation timeline for each individual indoor recreational facility will be determined from the results of the Energy Assessments and Checklists (explained in the Implementation section of this plan).

**Proposed / Future Renewable Energy Installations**

| <b>Building Name</b>          | <b>Building Address</b> | <b>Renewable Installation</b> | <b>System Size</b> | <b>Unit</b> |
|-------------------------------|-------------------------|-------------------------------|--------------------|-------------|
| Etobicoke Olympium Pool       | 590 Rathburn Rd         | Geothermal                    | 700                | kW          |
| Etobicoke Olympium Pool       | 590 Rathburn Rd         | Solar PV                      | 150                | kW          |
| East York Curling Club        | 901 Cosburn Ave         | Solar PV                      | 50                 | kW          |
| Gord & Irene Risk CC          | 2650 Finch Ave W        | Solar PV                      | 112                | kW          |
| Leaside Memorial Gardens Pool | 1073 Millwood Rd        | Solar PV                      | 156                | kW          |
| McCormick RC/Pool             | 66 Sheridan Ave         | Solar PV                      | 150                | kW          |
| North Toronto Memorial Arena  | 200 Eglinton Ave W      | Solar PV                      | 170                | kW          |
| Oriole CRC                    | 2975 Don Mills Rd       | Solar PV                      | 183                | kW          |
| Scarborough Centennial RC     | 1967 Ellesmere Ave      | Solar PV                      | 120                | kW          |

**Table 114: Proposed Renewable Energy Systems on Indoor Recreational Facilities**

### 3 Energy Management and Retrofit Plan

#### 3.1 Implementation Costs and Modeled Savings

The average budgeted cost for implementing suggested measures, based on previous experience with similar facilities, is \$9.38/ft<sup>2</sup> (see Appendix A). The budget allows for lighting audits, lighting retrofits and controls, mechanical system efficiency improvements, appliance replacement and controls and localized efficiency measures for the building envelope. The budget does not allow for major plant or equipment replacement or substantial building upgrades such as roof or window replacement. These items may be included if appropriate in projects for individual buildings, but would not provide rational Return on Investments (ROIs) based on energy savings alone and would therefore be budgeted separately.

Similar measures for consideration apply to high and medium potential buildings. A 20 percent premium is included for high potential buildings to ensure that all improvements necessary to achieve the targets are covered. Still, the ROIs for high potential buildings will be better than the rest.

Low potential buildings do not merit the more in-depth investigations planned for the other two categories. Rather, a checklist approach, guided by the indicated component energy savings potential, would identify the particular measures for each building. The budget allowance for low potential buildings is set \$0.75 to provide a rational ROI for this group.

The total implementation costs, payback and cash flows for the portfolios of high, medium and low potential indoor recreational facilities are summarized in Table 7 below.

| Annual Savings Potential | Number of facilities | Average Area (ft <sup>2</sup> ) | Estimated Implementation Cost \$/ft <sup>2</sup> | Estimated Implementation Cost \$ | Estimated Savings potential \$ | % of total savings | Payback     |
|--------------------------|----------------------|---------------------------------|--|----------------------------------|--------------------------------|--------------------|-------------|
| > \$100,000              | 8                    | 71,732                          | 11.25  | \$ 6,455,887                     | \$ 1,740,882                   | 66.1%              | 3.71        |
| \$5,000 - \$100,000      | 24                   | 32,307                          | 9.38   | \$ 7,268,963                     | \$ 869,097                     | 33.0%              | 8.36        |
| < \$5,000                | 14                   | 9,179                           | 0.75   | \$ 96,375                        | \$ 23,329                      | 0.9%               | 4.13        |
|                          | <b>46</b>            |                                 |  | <b>\$ 13,821,224</b>             | <b>\$ 2,633,308</b>            |                    | <b>5.25</b> |

**Table 115: Estimated Implementation Costs and Modeled Savings**

Paybacks are determined by actual current implementation costs divided by first year savings (so costs are not adjusted for inflation and utility prices are not adjusted for escalation).

#### 3.2 Implementation Process and Tools – Determining the Specific Measures for Each Building

Three types of tools are recommended to enable identification of specific measures in individual buildings:

- High Potential Buildings will undergo a Building Performance Audit incorporating measurement and testing to define retrofits and operational improvements. This also includes interval meter analysis and water consumption.

- Mid Potential Buildings will undergo an Energy Assessment including more in-depth analysis of monthly utility billing data for a number of years and analysis of interval meter or data-logger recordings of daily electricity use.
- Low Potential Buildings will use a simple Checklist to identify priority measures based on the conservation potential profile in this Plan.

The three approaches, budgeted analysis cost and numbers of buildings to which they apply are summarized in Table 8 below.

|                |                                  | #  | Cost     | Savings Potential   | Resources                   |
|----------------|----------------------------------|----|----------|---------------------|-----------------------------|
| High Potential | Building Performance Audit (BPA) | 8  | \$ 7,500 | > \$100,000         | engineer; energy analyst    |
| Mid Potential  | Energy Assessments               | 24 | \$ 750   | \$5,000 - \$100,000 | energy analyst              |
| Low Potential  | Checklists                       | 14 | \$ 150   | < \$5,000           | Division Champion and staff |
|                |                                  | 46 |          |                     |                             |

**Table 116: Assessment Tools Used to Determine Specific Energy-saving Measures**

### 3.2.1 Building Performance Audit

There are 8 indoor recreational facilities with over \$100,000 in annual energy saving potential. Over 67% of the total energy savings for all indoor recreational facilities can be found at these 8 facilities.

These 8 indoor recreational facilities can save an average of 63% of their total energy use. The total annual energy savings are estimated to be over \$1,740,880 and individual building annual savings range from approximately \$115,500 to over \$297,000. The annual GHG savings are estimated to be approximately 2,907,000 kg.

These 8 indoor recreational facilities can save an average of 66% of their total electricity use (66% Electric Baseload, 100% Electric Cooling and 54% Electric Heating). The total annual electricity savings are estimated to be approximately \$1,501,900 and individual building annual savings range from \$111,880 to over \$274,400.

These 8 indoor recreational facilities can save an average of 59% of their total gas use (85% Gas Baseload and 38% Gas Heating). The total annual gas savings are estimated to be approximately \$239,000 and individual building annual savings range from approximately \$3,600 to over \$22,650.

These 8 indoor recreational facilities will undergo Building Performance Audits (see the Implementation Plan for further details). For a complete description of the Building Performance Audit, refer to Appendix A.

See Appendix B for the associated energy savings potential by energy use component.

The highest percentage reductions for these facilities can be found in Gas Baseload and Electric Cooling. After the implementation of the proposed measures, these facilities are eligible to receive over \$950,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.2 Energy Assessment

There are 23 indoor recreational facilities with between \$5,000 and \$100,000 in annual energy saving potential. Approximately 31% of the total energy savings for all 46 indoor recreational facilities can be found in these 23 facilities.

These 23 indoor recreational facilities can save an average of 38% of their total energy use. The total annual energy savings are estimated to be over \$818,000 and individual building annual savings range from approximately \$6,500 to almost \$97,000. The annual GHG savings are approximately 2,029,000 kg.

These 23 indoor recreational facilities can save an average of 31% of their total electricity use (30% Electric Baseload, 50% Electric Cooling and 62% Electric Heating). The total annual electricity savings are estimated to be approximately \$603,000 and individual building annual savings range from \$0 to over \$86,000.

These 23 indoor recreational facilities can save an average of 42% of their total gas use (34% Gas Baseload and 45% Gas Heating). The total annual gas savings are estimated to be approximately \$215,000 and individual building annual savings range from \$0 to over \$47,600.

These 23 facilities will undergo an Energy Assessment with highest potential indoor recreational facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 23 indoor recreational facilities and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 23 indoor recreational facilities can be found in Electric Cooling and Gas Baseload. For each individual building, the energy components with highest percentage savings potential will be the focus of the Energy Assessment in order to maximize energy savings. For a complete description of the Energy Assessment, refer to Appendix A.

After the implementation of the proposed measures, these indoor recreational facilities are eligible to receive over \$427,000 in incentives based on current incentives available from the Ontario Power Authority.

### 3.2.3 Energy Savings Checklist

There are 15 indoor recreational facilities with less than \$5,000 in savings potential. Approximately 1% of the total energy savings for all 46 indoor recreational facilities can be found in these 15 facilities.

These 15 indoor recreational facilities can save an average of 10% of their total energy use. The total annual energy savings are estimated to be approximately \$26,000 and individual building annual savings range from \$0 to over \$4,600. The annual GHG savings are approximately 85,800 kg.



These 15 indoor recreational facilities can save an average of 6% of their total electricity use (2% Electric Baseload, 51% Electric Cooling and 8% Electric Heating). The total annual electricity savings are estimated to be approximately \$16,000 and individual building annual savings range from \$0 to over \$3,200.

These 15 indoor recreational facilities can save an average of 14% of their total gas use (all in Gas Heating). The total annual gas savings are estimated to be approximately \$10,000 and individual building annual savings range from \$0 to over \$1,800.

These 15 facilities will undergo a checklist approach with highest potential indoor recreational facilities focused on first (see the Implementation Plan for further details).

See Appendix B for a list of these 15 indoor recreational facilities and their associated energy savings potential by energy use component.

The highest percentage reductions for this group of 15 indoor recreational facilities can be found in Electric Cooling and Gas Heating.

The energy savings checklist will be used by the Division Champion for the indoor recreational facilities in conjunction with the building operator and/or service contractor for each indoor recreational facility. They will focus on measures related to energy components with high potential savings (colour-coded red) in order to maximize savings.

### 3.3 Implementation Budget

Table 9 below shows the total budget to implement the energy management and retrofit plan, including costs for identifying measures and the implementation costs for all 46 facilities. The total costs to implement the energy management and retrofit plan for indoor recreational facilities are estimated to be \$13,296,716. Note the Implementation costs are not adjusted for inflation.

| BUDGET                           |                      |
|----------------------------------|----------------------|
| Building Performance Audit (BPA) | \$ 60,000            |
| Energy Assessment                | \$ 18,000            |
| Checklist                        | \$ 2,100             |
| Implementation                   | \$ 13,821,224        |
| <b>Total</b>                     | <b>\$ 13,901,324</b> |

Table 117: Total Budget - Energy Management and Retrofit Plan

### 3.4 10-Year Implementation Plan

The 10-year implementation plan is summarized in Table 10 and Figure 5 below.

The plan will roll-out over 10 years, and the buildings with the highest savings potential will be focused on first.

Identification of measures from the Building Performance Audit will occur in Year 1, with all 8 Building Performance Audits completed by the end of Year 4. The implementation of these measures will begin in Year 2 and will be completed by the end of Year 5. Identification of measures from Energy Assessments will begin in Year 1, with all 23 Energy Assessments completed by the end of Year 5. The implementation of these measures will begin in Year 2, and will be completed by the end of Year 6. Identification of measures from the Checklists will begin in Year 2, with all 15 Checklists completed by the end of Year 4. The implementation of these measures will begin in Year 3.

Annual Costs refer to the assessment and implementation costs, training, measurement and verification (M&V), and maintenance costs.

Over a 10 year period, the cumulative net cash flow for this plan is estimated to be \$5,465,829. The cumulative net cash flow becomes positive in Year 9.

The implementation plan includes the following assumptions:

- Approximately 78% of the project budget will be spent in the first 5 years, and the other 22% in the following 5 years.
- The percentage of facilities to be retrofitted in each year is proportional to the percentage of the budget spent in that year. 78% of facilities will be retrofitted in the first 5 years and 22% in the following 5 years.
- 25% of energy savings potential of retrofitted facilities is achieved in the first year, 75% in the second year, and 100% in each of the following years.
- Project costs are adjusted for inflation (2% annually) and energy savings are adjusted for utility price escalation (5% annually).
- 100% of incentives are achieved in the year when facilities are retrofitted, and incentives are NOT adjusted for utility price escalation.

|   | Year 1     | Year 2        | Year 3          | Year 4          | Year 5          | Year 6          | Year 7          | Year 8          | Year 9          | Year 10         | Totals        |
|---|------------|---------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|---------------|
| High Potential - Building Performance Audit                           | 2          | 2             | 2               | 2               | 0               | 0               | 0               | 0               | 0               | 0               | 8             |
| Mid Potential - Energy Assessment                                     | 5          | 5             | 5               | 5               | 4               | 0               | 0               | 0               | 0               | 0               | 24            |
| Low Potential - Checklist   | 0          | 5             | 5               | 4               | 0               | 0               | 0               | 0               | 0               | 0               | 14            |
| Assessment Costs  | \$ 18,750  | \$ 19,530     | \$ 19,546       | \$ 19,399       | \$ 3,000        | \$ -            | \$ -            | \$ -            | \$ -            | \$ -            | \$ 80,226     |
| Implementation Costs  | \$ -       | \$ 3,254,724  | \$ 3,356,345    | \$ 3,423,471    | \$ 3,484,340    | \$ 1,364,339    | \$ -            | \$ -            | \$ -            | \$ -            | \$ 14,883,219 |
| Training and M&V costs (10.0% of Assessment and Implementation Costs) | \$ 1,875   | \$ 327,425    | \$ 337,589      | \$ 344,287      | \$ 348,734      | \$ 136,434      | \$ -            | \$ -            | \$ -            | \$ -            | \$ 1,496,344  |
| Maintenance costs (5.0% of Implementation Costs, cumulative)          | \$ -       | \$ 162,736    | \$ 330,553      | \$ 501,727      | \$ 675,944      | \$ 744,161      | \$ 744,161      | \$ 744,161      | \$ 744,161      | \$ 744,161      | \$ 744,160.95 |
| Annual Costs  | \$ 20,625  | \$ 3,764,416  | \$ 4,044,033    | \$ 4,288,885    | \$ 4,512,019    | \$ 2,244,934    | \$ 744,161      | \$ 744,161      | \$ 744,161      | \$ 744,161      | \$ 21,851,555 |
| Estimated Achieved Annual Savings                                     | \$ -       | \$ 268,328.83 | \$ 1,022,210.40 | \$ 2,021,776.95 | \$ 2,802,839.16 | \$ 3,370,099.09 | \$ 3,692,634.63 | \$ 3,890,595.49 | \$ 4,085,125.26 | \$ 4,289,381.52 | \$ 25,442,991 |
| Estimated Incentives  | \$ -       | \$ 522,036    | \$ 403,958      | \$ 272,731      | \$ 193,338      | \$ 16,984       | \$ -            | \$ -            | \$ -            | \$ -            | \$ 1,409,047  |
| Annual Savings and Incentives   | \$ -       | \$ 790,365    | \$ 1,426,168    | \$ 2,294,508    | \$ 2,996,177    | \$ 3,387,083    | \$ 3,692,635    | \$ 3,890,595    | \$ 4,085,125    | \$ 4,289,382    | \$ 26,852,038 |
| Borrowing costs based on cumulative cash flows (4.0% per annum)       | \$ -       | \$ 825        | \$ 119,787      | \$ 224,502      | \$ 304,277      | \$ 364,910      | \$ 319,224      | \$ 201,285      | \$ 75,428       | \$ -            | \$ 1,610,239  |
| Net Cash Flow incl borrowing costs                                    | \$ -20,625 | \$ -2,974,876 | \$ -2,737,652   | \$ -2,218,878   | \$ -1,820,118   | \$ -777,239     | \$ 2,629,249    | \$ 2,945,149    | \$ 3,265,536    | \$ 3,545,221    | \$ 3,390,245  |
| Cumulative Net Cash Flow  | \$ -20,625 | \$ -2,994,676 | \$ -5,612,541   | \$ -7,606,917   | \$ -9,122,759   | \$ -7,980,609   | \$ -5,032,136   | \$ -1,885,701   | \$ 1,455,263    | \$ 5,000,484    |               |

Table 118: Cash Flow for 10-Year Implementation Plan




Figure 69: Cash Flow for 10-Year Implementation Plan

## 4 Appendix A

### 4.1 Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities

Utility bills were used covering the period from January to December 2012.

If the total number of days in the combined bills was greater than 385 or less than 345 (because of adjustment bills spanning a few months), the facility was excluded from the dataset used to determine energy use components and targets.

To calculate 2012 actual energy use, the combined usage was normalized for the number of days in the calendar year 2012 (366).

## 4.2 Determining Energy Use Components

The energy use components and targets were calculated using data available for eligible facilities at the City of Toronto (see above). Energy use components were determined as follows:

**Electric Baseload:** Relates to systems which run year-round such as lighting, fans and equipment. Electric Baseload for indoor recreational facilities is determined as the average kWh/day for March, April, October and November multiplied by 366 days.

**Electric Cooling:** Was determined as the additional electricity use above the year-round base from May to September, and relates to air conditioning.

**Electric Heating:** Was determined as the additional use in January, February and December, and relates to electric heat or electricity use for heating systems (pumps, blowers etc.).

**Gas Baseload:** Relates to systems which run year-round (domestic hot water) and is determined as the average m<sup>3</sup>/day for June, July and August multiplied by 366 days.

**Gas Heating:** Was determined as the additional gas use to heat the building from January to May, and September to December.

## 4.3 Determining Targets

Component energy targets were set based on the top quartile intensity of the eligible data set. Thus achievement of the targets anticipates all buildings with component energy intensities greater than the top quartile will reach that level already attained by one quarter of the buildings.

All values less than 5% of the average of the top 3 facilities were removed for the calculation of the component energy targets.

Before the calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type. Individual targets are adjusted for energy types, non-standard space types or equipment, and high energy intensity spaces or equipment. The target adjustments are listed below.

### Target Adjustments

**Electric Heating:** Add Gas Heating multiplied by % of area served and 75% efficiency to Electric Heating AND Multiply Gas Heating by (100% - % of area served)

**GSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating AND Subtract Gas Heating \* 0.13 \* % of area served from Gas Heating

**WSHP:** Add Gas Heating \* 0.19 \* % of area served to Electric Heating Electricity AND Subtract Gas Heating \* 0.75 \* % of area served from Gas Heating

**Electric DHW:** Add Gas Baseload \* % of area served \* 75% efficiency to Electric Baseload AND Multiply Gas Baseload by (100% - % of area served)

**Air-Conditioning:** Divide Electric Cooling by Average % of building served by A/C for all facilities of the type and multiply by % of the facility area served by A/C

**Data Centre:** Add 50 kWh/ft<sup>2</sup> \* % of building occupied by Data Centre to Electric Baseload

**Food Services:** Add 30 kWh/ft<sup>2</sup> \* % of facility area occupied by Food Services (including seating area) to Electric Baseload

**Outdoor Rink:** If rink has associated ice plant, add (1.04 kWh/ft<sup>2</sup> of ice/week \* ft<sup>2</sup> of ice surface area \* 16 weeks/year) divided by ft<sup>2</sup> of the total building area to Electric Baseload

**Solar Hot Water:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh (t)/kW) divided by the facility area (ft<sup>2</sup>) from Gas Baseload (ekWh/ft<sup>2</sup>)

**Solar Photovoltaic:** Subtract the product of System Power Rating (kW thermal) and (Average Actual) Annual Performance (kWh(t)/kW) divided by the facility area (ft<sup>2</sup>) from Electric Baseload (kWh/ft<sup>2</sup>)

**Garage:** Add 20 ekWh/ft<sup>2</sup> to Gas Heating

**High-intensity electric equipment:** Add 30 kWh/ft<sup>2</sup> to Electric Baseload

**Indoor Rink(s) and/or Indoor Pool(s) within Community Centres and Indoor Recreational Facilities:**

Adjustment for Electric Baseload – Electric Baseload adjusted for Indoor Rink and/or Indoor Pool, kWh/ft<sup>2</sup> of total area = (Electric Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Assumed Electricity Requirement of Ice Plant (ekWh/ft<sup>2</sup> of ice/week) \* Months ice-in \* 52wks a year /12 months a year \* Rink area, ft<sup>2</sup> + Electric Baseload for Pool (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>) / Total Area, ft<sup>2</sup>

Adjustment for Gas Baseload – Gas Baseload adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Baseload for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Baseload for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Baseload for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

Adjustment for Gas Heating – Gas Heating adjusted for Indoor Rink and/or Indoor Pool, ekWh/ft<sup>2</sup> of total area = Gas Heating for Composite Recreational Facility (ekWh/ft<sup>2</sup> of total facility) \* (Total area, ft<sup>2</sup> - (Rink area, ft<sup>2</sup> + Pool area, ft<sup>2</sup>)) + Gas Heating for Indoor Sports Arenas (ekWh/ft<sup>2</sup> of rink) \* Rink area, ft<sup>2</sup> + Gas Heating for Indoor Swimming Pools (ekWh/ft<sup>2</sup> of pool) \* Pool area, ft<sup>2</sup>

#### 4.4 Calculating Potential Savings

The difference between the actual energy use component intensity and adjusted target represents potential annual savings for the component after multiplication by the facility area (and conversion from kWh to m<sup>3</sup> in the case of gas).

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated based on total electricity and gas use (normalized to 366 days) compared with total adjusted electricity and natural gas targets.

#### 4.5 Implementation Costs by Measure Type and Modeled Savings

The following table summarizes the implementation costs and savings estimates for measures under each type of operational system. Note that the costs are based on previous experience with similar projects.

These apply to the following building types:

- Indoor swimming pools
- Indoor sports arenas
- Community centres
- Recreational facilities

|              | Cost \$/ft <sup>2</sup> | % electric | Payback (yrs) | kWh/ft <sup>2</sup> /yr | m <sup>3</sup> /ft <sup>2</sup> /yr |
|--------------|-------------------------|------------|---------------|-------------------------|-------------------------------------|
| Lighting     | 2.25                    | 100%       | 6.5           | 2.9                     |                                     |
| Mechanical   | 1.88                    | 30%        | 6             | 0.8                     | 0.9                                 |
| Electrical   | 0.25                    | 100%       | 8             | 0.3                     |                                     |
| Envelope     | 0.50                    | 100%       | 10            |                         | 0.0                                 |
| Process      | 4.5                     | 30%        | 5             |                         | 2.5                                 |
| <b>Total</b> | <b>9.38</b>             |            | <b>5.9</b>    | <b>3.93</b>             | <b>3.40</b>                         |

**Table 119: Implementation Costs by Measure Type**

Implementation costs for lighting include measures such as re-lamping and re-ballasting with about 20% fixture retrofits, replacement or relocation, along with selective, local occupancy and photo-controls. They also include lighting audits.

Costs for mechanical system measures include mechanical system testing and minor retrofits such as VFDs, re-balancing, right-sizing, tuning and repairs, along with upgraded controls.

Costs for electrical measures include appliance and equipment replacements and upgraded controls.

Costs for envelope measures include thermographic testing along with draft-proofing, re-insulation and roof/wall air sealing.

Costs for process measures (for facilities with rinks or pools) include cost effective retrofits to the pool circulation pump, dehumidification, heat recovery, retrofits to ice plant and related equipment and controls (if applicable). Costs for process measures (for facilities without rinks or pools) include low flow shower heads and aerators, controls on hot water use for vehicle washing and minor retrofits such as pipe insulation.

## 4.6 Assessment Tools

### Building Performance Audit

The Building Performance Audit determines how well a building's existing systems and operational practices compare to other similar buildings, including top performers. The audit identifies problem areas in building systems, examines building operations, and determines improvements that will deliver the greatest energy savings and maximize return on investment. The outcome will be a clear, evidence-based picture of how much can be saved and what areas to focus on to optimize performance.

The Building Performance Audit includes:

- Benchmarking against comparable buildings including top-performers
- Performance based target setting customized for your building
- Interval meter analysis and examination of prior years' energy trends pinpointing specific system and operational inefficiencies
- Motor testing and equipment data-logging analysis
- Deeper understanding of operating practices through energy use profiles
- Power density and plant capacity analysis to identify retrofit opportunities
- Power factor analysis to uncover over-sized equipment
- Inventory and efficiency analysis of main energy-using equipment
- Verification and documentation of the proper operation of the building systems
- Payback and business case analysis

### Initial Energy Targets

Initial energy targets are created by a mass screening tool which uses a standardized logic to produce a preliminary estimate of savings potential for every building, and thereby identify high-, medium- and low-potential buildings. This initial target-setting process creates the overall economic envelope for the program.

### Energy Assessment

Medium-potential buildings are subjected to more in-depth analysis through an Energy Assessment which drills deeper into utility consumption data to refine the savings target and uncover more specific conservation measures. Regression analysis of monthly billing data against heating and cooling degree-days highlights billing anomalies such as estimated bills, and provides a more accurate breakdown of energy components, and hence component energy savings. Where multiple years of billing data are available, the Energy Assessment produces weather-normalized performance trends which can uncover changes in energy use and seasonal anomalies which point to specific energy saving opportunities. The Energy Assessment also analyzes electrical interval meter (or data-logger test results) to help identify operational improvements such as equipment running when the building is unoccupied.



## 5 Appendix B - Indoor Recreational Facilities

### 5.1 Buildings and Building Characteristics

Below are the names, addresses and building areas for the 46 indoor recreational facility buildings included in this report and Plan.

| <b>Building</b>               | <b>Address</b>      | <b>Building Area (ft<sup>2</sup>)</b> |
|-------------------------------|---------------------|---------------------------------------|
| Agincourt Arena and R.C       | 31 Glen Watford Dr  | 93,398                                |
| Antibes Park                  | 140 Antibes Dr      | 18,492                                |
| Bennington Heights Clubhouse  | 457 Heath Ave       | 1,432                                 |
| Broadlands R.C & A.I.R        | 19 Castlegrove Blvd | 10,667                                |
| Centennial R.C (Ice Galaxy)   | 1967 Ellesmere Rd   | 102,375                               |
| Central Arena                 | 44 Montgomery Rd    | 45,446                                |
| Davisville Park/Tennis        | 218 Davisville Ave  | 2,777                                 |
| Dovercourt B&G Club           | 155 Bartlett Ave    | 23,971                                |
| East York Clubhouse           | 323-525 Cosburn Ave | 1,001                                 |
| East York Curling Club House  | 901 Cosburn Ave     | 17,868                                |
| Etobicoke Olympium            | 590 Rathburn Rd     | 139,995                               |
| Fairfield Senior Centre       | 80 Lothian Ave      | 14,316                                |
| Flemingdon RC & Pool          | 29 St Dennis Dr     | 34,348                                |
| George Webster Clubhouse      | 30-40 Chapman Ave   | 1,302                                 |
| Gord & Irene Risk Arena & R.C | 2650 Finch Ave W    | 44,304                                |
| Goulding Arena & R.C          | 45 Goulding Ave     | 43,540                                |
| Grandravine Arena & R.C       | 25 Grandravine Dr   | 33,637                                |
| Horner Senior Centre          | 320 Horner Ave      | 4,252                                 |
| Islington Senior Centre       | 4968 Dundas St W    | 9,967                                 |
| Jimmie Simpson R.C            | 870 Queen St E      | 43,906                                |
| John Booth Arena & R.C        | 230 Gosford Blvd    | 27,007                                |
| Joseph J. Piccininni R.C      | 1369 St Clair Ave W | 70,030                                |
| Keele St 1652                 | 1652 Keele St       | 22,497                                |
| Leaside Gardens Curling Club  | 1073A Millwood Ave  | 27,814                                |
| Malvern R.C                   | 30 Sewells Rd       | 106,466                               |
| Maple Leaf Cottage            | 62 Laing St         | 2,842                                 |
| Markdale Rec & Daycare        | 41 Markdale Ave     | 30,516                                |
| Matty Eckler R.C              | 953 Gerrard St E    | 47,383                                |
| McCormick R.C                 | 66 Sheridan Ave     | 43,099                                |
| Mililken Park Rec Center      | 4325 McCowan Rd     | 17,631                                |
| North Toronto Mem Rec Ctr     | 200 Eglinton Ave W  | 74,820                                |
| Oriole Arena & R.C            | 2975 Don Mills Rd   | 64,347                                |

|                                 |                    |        |
|---------------------------------|--------------------|--------|
| Pelmo Park Tennis               | 185 Pelmo Cres     | 2,573  |
| Pleasantview Arena & R.C        | 545 Van Horne Ave  | 30,559 |
| Roding Arena & R.C              | 600 Roding St      | 30,494 |
| S.H Armstrong R.C               | 56 Woodfield Rd    | 18,277 |
| St Albans Boys Club             | 843 Palmerston Ave | 23,293 |
| Stan Wadlow Clubhouse           | 373 Cedarvale Ave  | 10,323 |
| Todmorden Mills Butler Building | 67 Pottery Rd      | 17,707 |
| Topham Park Clubhouse           | 1 Tiago Ave        | 3,283  |
| Trace Manes Clubhouse           | 110 Rumsey Rd      | 6,329  |
| Trinity Comm Rec Ctr            | 155 Crawford St    | 36,909 |
| University Settlement House R.C | 23 Grange Rd       | 47,566 |
| W Acres Senior Ctr              | 10A Arbordell Rd   | 1,798  |
| Whitlam Warehouse               | 25 Whitlam Ave     | 24,865 |
| Willowdale Lawn Bowling         | 150 Beecroft Rd    | 2,293  |

**Table 120: Indoor Recreational Facility Building Information**

## 5.2 Energy Use Intensities

Below are the energy use intensities (total electricity, total gas and total energy) for the 46 indoor recreational facility buildings included in this report and Plan. They are sorted by total energy use intensity, from lowest to highest energy use intensity.

| <b>Building</b>              | <b>2012 Total Electricity Intensity (kWh/ft<sup>2</sup>)</b> | <b>2012 Total Gas Intensity (ekWh/ft<sup>2</sup>)</b> | <b>2012 Total Energy Intensity (ekWh/ft<sup>2</sup>)</b> |
|------------------------------|--|---|--|
| Markdale Rec & Daycare       | 1.18   | 1.02  | 2.20   |
| Maple Leaf Cottage           | 4.12   | 9.28  | 13.40  |
| Islington Senior Centre      | 7.32   | 9.17  | 16.49  |
| Horner Senior Centre         | 8.12   | 11.07   | 19.19  |
| Leaside Gardens Curling Club | 10.08  | 12.34   | 22.41  |
| Whitlam Warehouse            | 8.50   | 14.47   | 22.97  |
| Bennington Heights Clubhouse | 4.78   | 18.70   | 23.48  |
| Trace Manes Clubhouse        | 4.91   | 19.45   | 24.36  |
| Stan Wadlow Clubhouse        | 10.42  | 15.31   | 25.73  |
| S.H Armstrong R.C            | 13.08  | 16.69   | 29.77  |
| Keele St 1652                | 29.02  | 1.67  | 30.69  |
| Mililken Park Rec Center     | 17.37  | 13.51   | 30.88  |
| Roding Arena & R.C           | 19.61  | 11.38   | 30.98  |
| Matty Eckler R.C             | 8.19   | 22.98   | 31.17  |
| Topham Park Clubhouse        | 8.83   | 23.90   | 32.73  |

|                                 |       |       |       |
|---------------------------------|-------|-------|-------|
| Grandravine Arena & R.C         | 14.51 | 18.43 | 32.93 |
| Flemingdon RC & Pool            | 20.01 | 12.95 | 32.96 |
| Todmorden Mills Butler Building | 17.38 | 15.72 | 33.10 |
| Oriole Arena & R.C              | 21.84 | 12.87 | 34.72 |
| Joseph J. Piccininni R.C        | 15.66 | 20.35 | 36.01 |
| East York Clubhouse             | 15.59 | 21.14 | 36.73 |
| John Booth Arena & R.C          | 22.99 | 13.75 | 36.73 |
| Goulding Arena & R.C            | 17.45 | 19.64 | 37.10 |
| Gord & Irene Risk Arena & R.C   | 17.79 | 20.06 | 37.84 |
| Dovercourt B&G Club             | 7.50  | 31.06 | 38.56 |
| East York Curling Club House    | 20.68 | 19.94 | 40.62 |
| Malvern R.C                     | 25.56 | 15.73 | 41.29 |
| Davisville Park/Tennis          | 13.78 | 28.72 | 42.50 |
| George Webster Clubhouse        | 17.40 | 25.49 | 42.89 |
| Fairfield Senior Centre         | 7.02  | 36.37 | 43.39 |
| St Albans Boys Club             | 12.74 | 32.01 | 44.75 |
| University Settlement House R.C | 13.30 | 34.03 | 47.33 |
| Centennial R.C (Ice Galaxy)     | 27.32 | 20.22 | 47.54 |
| North Toronto Mem Rec Ctr       | 23.10 | 30.24 | 53.34 |
| Broadlands R.C & A.I.R          | 35.05 | 19.85 | 54.89 |
| Antibes Park                    | 21.03 | 36.67 | 57.69 |
| Agincourt Arena and R.C         | 24.69 | 35.96 | 60.64 |
| Pleasantview Arena & R.C        | 27.43 | 35.33 | 62.76 |
| Pelmo Park Tennis               | 37.90 | 27.18 | 65.08 |
| Etobicoke Olympium              | 21.09 | 44.58 | 65.66 |
| Willowdale Lawn Bowling         | 24.62 | 41.46 | 66.07 |
| W Acres Senior Ctr              | 20.47 | 46.23 | 66.70 |
| Central Arena                   | 32.64 | 42.83 | 75.47 |
| Trinity Comm Rec Ctr            | 18.45 | 62.79 | 81.23 |
| Jimmie Simpson R.C              | 31.43 | 50.73 | 82.16 |
| McCormick R.C                   | 46.76 | 39.60 | 86.36 |

**Table 121: Indoor Recreational Facility 2012 Energy Intensity**

### 5.3 Target-setting Method and Metrics

11 indoor recreational facilities were determined to be ineligible for determination of energy components or target-setting. See Appendix A. The excluded facilities are listed below.

| Facility            | Days in 2012 | Energy type |
|---------------------|--------------|-------------|
| Pelmo Park Tennis   | 215          | Electricity |
| Dovercourt B&G Club | No 2012 data | Electricity |


|                              |  |             |
|------------------------------|--|-------------|
| Bennington Heights Clubhouse | 399  | Electricity |
| East York Clubhouse          | 327  | Electricity |
| East York Curling Club House | 330  | Electricity |
| Leaside Gardens Curling Club | 264  | Electricity |
| Markdale Rec & Daycare       | 399  | Electricity |
| Matty Eckler R.C             | 402  | Electricity |
| Trace Manes Clubhouse        | Big negative consumption in February bill  | Electricity |
| Whitlam Warehouse            | Big negative consumption in September bill | Electricity |
| Davisville Park/Tennis       | Significant adjustment in April bill       | Electricity |

**Table 122: Excluded Facilities**

After excluding these 11 facilities, 79 indoor recreational facilities and community centres were used to calculate the energy use components.

The following benchmark charts show the resulting electricity and gas use by component. Electricity use was broken down into baseload, cooling and heating electricity as described in Appendix A, and gas use was broken down into baseload and heating.

The red line on each chart indicates the top quartile for each component which is the target for that component.



**Figure 70: 2012 Electric Baseload Intensity Benchmark**

Electric Baseload refers to year-round electricity use for lighting, fans, equipment and other systems that are not weather dependent. Electric Baseload for indoor recreational facilities ranges from 3.3 to 43.0 kWh/ft<sup>2</sup> and the top-quartile is 9.21 kWh/ft<sup>2</sup>.




Figure 71: 2012 Electric Cooling Intensity Benchmark

Electric Cooling refers to additional electricity use in summer for cooling purposes. Electric Cooling for indoor recreational facilities ranges from 0.5 to 14.3 ekWh/ft<sup>2</sup> and the top-quartile is 0.77 ekWh/ft<sup>2</sup>.




Figure 72: 2012 Electric Heating Intensity Benchmark

Electric Heating refers to additional electricity use in winter months for heating purposes. Electric Heating for indoor recreational facilities ranges from 1.0 to 20.3 ekWh/ft<sup>2</sup> and the top-quartile is 1.76 ekWh/ft<sup>2</sup>.




Figure 73: 2012 Gas Baseload Intensity Benchmark

Gas Baseload refers to natural gas used for domestic hot water and other equipment that runs year round. Gas Baseload for indoor recreational facilities ranges from 1.1 to 23.9 ekWh/ft<sup>2</sup> and the top-quartile is 1.83 ekWh/ft<sup>2</sup>.




Figure 74: 2012 Gas Heating Intensity Benchmark

Gas Heating refers to the additional energy used in winter for heating and humidification. Gas Heating for indoor recreational facilities ranges from 3.4 to 44.6 ekWh/ft<sup>2</sup> and the top-quartile is 9.71 ekWh/ft<sup>2</sup>.

As explained in Appendix A, all values less than 5% of the average of the top 3 facilities were removed for the calculation of the energy use components.

The top quartile values for each energy use component were adopted as targets.

Before calculation of potential savings for each building, component targets were adjusted taking into account factors specific to the facility type (see Appendix A). In the case of indoor recreational facilities, the factors are % of the facility area served by electric heat, % of DHW heated by electricity, use of ground-source or water-source heat pumps, % of the area served by electric air conditioning, % of area

served by food services, presence and size of ice surface (including months of ice-in) and presence and size of indoor swimming pool.

For the facilities that were previously excluded from the dataset for setting targets, potential savings were calculated by subtraction of the sum of individual energy use component targets adjusted to specific characteristics of the facility from Total Electricity use (or Total Gas use).

## 5.4 Savings Potential by Energy Use Component

### Savings Potential by Energy Use Component for the 8 High Savings Potential Indoor Recreational facilities

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 8 indoor recreational facilities with over \$100,000 in annual savings potential.

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |         |       | Total Energy Savings Potential |       | Incentives  |            | Indoor Area | GHG Emissions |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|---------|-------|--------------------------------|-------|-------------|------------|-------------|---------------|-----------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           |         | \$/yr | Avg %                          | \$/yr | Electricity | Gas        |             |               |           |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load | Heating |       |                                |       |             |            | Total       |               |           |
|                                       |                               |         |         |       |                       |           |         |       |                                |       |             |            | ft²         | kg/yr         |           |
| High potential savings facilities (8) | 66%                           | 100%    | 54%     | 66%   | \$1,501,903           | 85%       | 38%     | 59%   | \$238,979                      | 63%   | \$1,740,882 | \$ 858,231 | \$ 91,915   | 573,857       | 2,907,148 |
| Centennial R.C (Ice Galaxy)           | 68%                           |         |         | 70%   | \$ 274,484            | 71%       | 31%     | 44%   | \$ 22,659                      | 59%   | \$ 297,143  | \$ 156,848 | \$ 8,715    | 102,375       | 379,422   |
| Malvern R.C                           | 64%                           | 100%    |         | 65%   | \$ 248,918            | 50%       | 20%     | 27%   | \$ 11,181                      | 51%   | \$ 260,099  | \$ 142,239 | \$ 4,300    | 106,466       | 276,383   |
| McCormick R.C                         | 80%                           | 100%    |         | 80%   | \$ 227,077            | 85%       | 64%     | 71%   | \$ 30,306                      | 76%   | \$ 257,383  | \$ 129,758 | \$ 11,656   | 43,099        | 397,436   |
| Agincourt Arena and R.C               | 62%                           |         |         | 62%   | \$ 199,440            | 90%       | 42%     | 68%   | \$ 57,263                      | 65%   | \$ 256,703  | \$ 113,965 | \$ 22,024   | 93,398        | 570,539   |
| Central Arena                         | 73%                           |         |         | 75%   | \$ 155,962            | 93%       | 42%     | 73%   | \$ 35,696                      | 74%   | \$ 191,658  | \$ 89,121  | \$ 13,729   | 45,446        | 380,517   |
| North Toronto Mem Rec Ctr             | 57%                           | 100%    |         | 61%   | \$ 147,662            | 91%       | 7%      | 62%   | \$ 35,125                      | 61%   | \$ 182,788  | \$ 84,379  | \$ 13,510   | 74,820        | 369,870   |
| Jimmie Simpson R.C                    | 69%                           |         | 76%     | 71%   | \$ 136,480            | 91%       | 69%     | 77%   | \$ 43,140                      | 75%   | \$ 179,620  | \$ 77,988  | \$ 16,592   | 43,906        | 419,003   |
| Oriole Arena & R.C                    | 52%                           |         |         | 57%   | \$ 111,881            | 55%       |         | 17%   | \$ 3,608                       | 42%   | \$ 115,489  | \$ 63,932  | \$ 1,388    | 64,347        | 113,979   |

Table 123: Savings Potential for 8 High Savings Potential Indoor Recreational Facilities

### Savings Potential by Energy Use Component for the 24 Mid Savings Potential Indoor recreational facilities

Buildings are sorted by total annual savings potential, starting with the highest savings potential buildings.

There are 24 indoor recreational facilities with between \$5,000 and \$100,000 in annual savings potential. The highest potential buildings will be focused on first.

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |       | Total Energy Savings Potential |           | Incentives  |            | Indoor Area | GHG Emissions |         |           |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|-------|--------------------------------|-----------|-------------|------------|-------------|---------------|---------|-----------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           | \$/yr | Avg %                          | \$/yr     | Electricity | Gas        |             |               |         |           |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load |       |                                |           |             |            | Heating     | Total         |         |           |
| Mid-potential savings facilities (24) | 27%                           | 46%     | 62%     | 29%   | \$ 605,918            | 43%       | 50%   | 49%                            | \$263,179 | 41%         | \$ 869,097 | \$ 346,239  | \$101,223     | 775,356 | 2,378,053 |
| Trinity Comm Rec Ctr                  | 48%                           | 100%    |         | 52%   | \$ 49,378             | 91%       | 78%   | 82%                            | \$ 47,608 | 75%         | \$ 96,986  | \$ 28,216   | \$ 18,311     | 36,909  | 382,856   |
| Pleasantview Arena & R.C              | 55%                           |         | 67%     | 61%   | \$ 71,127             | 80%       | 64%   | 69%                            | \$ 18,634 | 65%         | \$ 89,760  | \$ 40,644   | \$ 7,167      | 30,559  | 190,550   |
| Keele St 1652                         | 75%                           |         |         | 94%   | \$ 86,145             |           |       | 0%                             | \$ -      | 89%         | \$ 86,145  | \$ 49,226   | \$ -          | 22,497  | 67,685    |
| Etobicoke Olympium                    |                               | 29%     |         | 2%    | \$ 7,628              | 25%       | 60%   | 47%                            | \$ 73,277 | 32%         | \$ 80,905  | \$ 4,359    | \$ 28,183     | 139,995 | 535,559   |
| Gord & Irene Risk Arena & R.C         | 37%                           |         |         | 48%   | \$ 52,427             | 54%       | 45%   | \$ 10,064                      | 46%       | \$ 62,491   | \$ 29,958  | \$ 3,871    | 44,304        | 113,925 |           |
| John Booth Arena & R.C                | 54%                           |         |         | 62%   | \$ 53,559             | 29%       | 26%   | \$ 2,422                       | 48%       | \$ 55,981   | \$ 30,605  | \$ 931      | 27,007        | 59,584  |           |
| Flemingdon R.C & Pool                 | 50%                           | 53%     |         | 52%   | \$ 49,936             | 72%       | 36%   | \$ 4,046                       | 46%       | \$ 53,982   | \$ 28,535  | \$ 1,556    | 34,348        | 68,475  |           |
| Broadlands R.C & A.I.R                | 36%                           |         | 97%     | 71%   | \$ 37,320             | 77%       | 19%   | 43%                            | \$ 2,262  | 61%         | \$ 39,582  | \$ 21,326   | \$ 870        | 10,667  | 45,672    |
| University Settlement House R.C       | 15%                           |         |         | 14%   | \$ 12,275             | 88%       | 48%   | 66%                            | \$ 26,943 | 52%         | \$ 39,218  | \$ 7,014    | \$ 10,363     | 47,566  | 204,362   |
| East York Curling Club House          |                               |         |         | 53%   | \$ 27,265             |           |       | 42%                            | \$ 3,774  | 48%         | \$ 31,038  | \$ 15,580   | \$ 1,451      | 17,868  | 48,694    |
| Roding Arena & R.C                    | 32%                           |         |         | 36%   | \$ 30,542             |           |       | 0%                             | \$ -      | 23%         | \$ 30,542  | \$ 17,452   | \$ -          | 30,494  | 23,997    |
| Miliken Park Rec Center               | 49%                           | 100%    |         | 57%   | \$ 24,480             | 44%       | 5%    | 14%                            | \$ 855    | 38%         | \$ 25,335  | \$ 13,989   | \$ 329        | 17,631  | 25,411    |
| Goulding Arena & R.C                  | 20%                           |         |         | 21%   | \$ 22,594             | 19%       | 12%   | \$ 2,489                       | 16%       | \$ 25,083   | \$ 12,911  | \$ 957      | 43,540        | 35,739  |           |
| Todmorden Mills Butler Building       | 48%                           |         |         | 49%   | \$ 20,989             | 38%       | 38%   | \$ 2,684                       | 44%       | \$ 23,673   | \$ 11,994  | \$ 1,032    | 17,707        | 35,886  |           |
| St Albans Boys Club                   | 22%                           | 100%    |         | 24%   | \$ 10,168             | 81%       | 56%   | 64%                            | \$ 11,994 | 53%         | \$ 22,162  | \$ 5,810    | \$ 4,613      | 23,293  | 94,669    |
| Antibes Park                          | 22%                           | 42%     | 3%      | 22%   | \$ 12,153             | 37%       | 44%   | 40%                            | \$ 6,856  | 34%         | \$ 19,009  | \$ 6,945    | \$ 2,637      | 18,492  | 59,094    |
| Grandravine Arena & R.C               | 11%                           |         | 44%     | 16%   | \$ 11,188             | 29%       | 22%   | \$ 3,412                       | 19%       | \$ 14,600   | \$ 6,393   | \$ 1,312    | 33,637        | 33,449  |           |
| Matty Eckler R.C                      |                               |         |         | 0%    | \$ -                  |           |       | 50%                            | \$ 13,627 | 37%         | \$ 13,627  | \$ -        | \$ 5,241      | 47,383  | 98,478    |
| Dovercourt B&G Club                   |                               |         |         | 0%    | \$ -                  |           |       | 63%                            | \$ 11,755 | 51%         | \$ 11,755  | \$ -        | \$ 4,521      | 23,971  | 84,949    |
| Peimo Park Tennis                     |                               |         |         | 74%   | \$ 10,128             |           |       | 58%                            | \$ 1,011  | 67%         | \$ 11,138  | \$ 5,787    | \$ 389        | 2,573   | 15,263    |
| S.H Armstrong R.C                     | 16%                           | 100%    | 32%     | 25%   | \$ 8,287              | 66%       | 14%   | 30%                            | \$ 2,335  | 28%         | \$ 10,622  | \$ 4,735    | \$ 898        | 18,277  | 23,383    |
| Fairfield Senior Centre               |                               | 100%    |         | 5%    | \$ 738                | 13%       | 72%   | 68%                            | \$ 8,885  | 58%         | \$ 9,623   | \$ 422      | \$ 3,417      | 14,316  | 64,792    |
| Joseph J. Piccininni R.C              |                               | 24%     |         | 2%    | \$ 2,871              |           | 26%   | 18%                            | \$ 6,439  | 11%         | \$ 9,309   | \$ 1,640    | \$ 2,476      | 70,030  | 48,787    |
| Willowdale Lawn Bowling               | 42%                           | 100%    | 76%     | 60%   | \$ 4,723              | 76%       | 76%   | \$ 1,810                       | 70%       | \$ 6,533    | \$ 2,699   | \$ 696      | 2,293         | 16,793  |           |

**Table 124: Savings Potential for 24 Medium Savings Potential Indoor Recreational Facilities**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.

### Savings Potential by Energy Use Component for the 14 Low Savings Potential Indoor Recreational Facilities

Buildings are sorted by total savings potential, starting with the highest saving potential buildings.

There are 14 indoor recreational facilities with less than \$5,000 in savings potential. The highest potential buildings will be focused on first.

| Operation name                        | Electricity Savings Potential |         |         |       | Gas Savings Potential |           |       | Total Energy Savings Potential |           | Incentives  |           | Indoor Area | GHG Emissions |         |        |
|---------------------------------------|-------------------------------|---------|---------|-------|-----------------------|-----------|-------|--------------------------------|-----------|-------------|-----------|-------------|---------------|---------|--------|
|                                       | Average %                     |         |         | \$/yr | Average %             |           | \$/yr | Avg %                          | \$/yr     | Electricity | Gas       |             |               |         |        |
|                                       | Base-load                     | Cooling | Heating |       | Total                 | Base-load |       |                                |           |             |           | Heating     | Total         |         |        |
| Low potential savings facilities (14) | 08%                           | 100%    | 08%     | 10%   | \$ 13,208             | 02%       | 38%   | 27%                            | \$ 10,121 | 20%         | \$ 23,329 | \$ 7,547    | \$ 3,893      | 128,499 | 83,524 |
| Stan Wadlow Clubhouse                 |                               | 100%    |         | 21%   | \$ 3,203              |           | 37%   | 37%                            | \$ 1,454  | 30%         | \$ 4,657  | \$ 1,830    | \$ 559        | 10,323  | 13,026 |
| W Acres Senior Ctr                    | 55%                           |         |         | 54%   | \$ 2,797              |           | 78%   | 75%                            | \$ 1,576  | 69%         | \$ 4,373  | \$ 1,598    | \$ 606        | 1,798   | 13,585 |
| George Webster Clubhouse              |                               | 100%    |         | 82%   | \$ 2,613              | 15%       | 59%   | 56%                            | \$ 468    | 67%         | \$ 3,081  | \$ 1,493    | \$ 180        | 1,302   | 5,435  |
| Davisville Park/Tennis                |                               |         |         | 29%   | \$ 1,556              |           |       | 60%                            | \$ 1,199  | 50%         | \$ 2,755  | \$ 889      | \$ 461        | 2,777   | 9,886  |
| Whittam Warehouse                     |                               |         |         | 0%    | \$ -                  |           |       | 20%                            | \$ 1,833  | 13%         | \$ 1,833  | \$ -        | \$ 705        | 24,865  | 13,244 |
| Leaside Gardens Curling Club          |                               |         |         | 3%    | \$ 1,150              |           |       | 6%                             | \$ 560    | 5%          | \$ 1,710  | \$ 657      | \$ 215        | 27,814  | 4,949  |
| Topham Park Clubhouse                 |                               | 100%    |         | 13%   | \$ 539                |           | 59%   | 58%                            | \$ 1,140  | 46%         | \$ 1,678  | \$ 308      | \$ 438        | 3,283   | 8,659  |
| Trace Manes Clubhouse                 |                               |         |         | 0%    | \$ -                  |           |       | 41%                            | \$ 1,258  | 32%         | \$ 1,258  | \$ -        | \$ 484        | 6,329   | 9,094  |
| East York Clubhouse                   |                               |         |         | 37%   | \$ 814                |           |       | 45%                            | \$ 242    | 42%         | \$ 1,056  | \$ 465      | \$ 93         | 1,001   | 2,385  |
| Horner Senior Centre                  |                               | 100%    |         | 7%    | \$ 337                |           | 12%   | 11%                            | \$ 135    | 10%         | \$ 472    | \$ 193      | \$ 52         | 4,252   | 1,243  |
| Bennington Heights Clubhouse          |                               |         |         | 0%    | \$ -                  |           |       | 38%                            | \$ 258    | 31%         | \$ 258    | \$ -        | \$ 99         | 1,432   | 1,861  |
| Islington Senior Centre               |                               |         | 14%     | 1%    | \$ 128                |           |       | 0%                             | \$ -      | 1%          | \$ 128    | \$ 73       | \$ -          | 9,967   | 101    |
| Maple Leaf Cottage                    |                               | 100%    |         | 4%    | \$ 70                 |           |       | 0%                             | \$ -      | 1%          | \$ 70     | \$ 40       | \$ -          | 2,842   | 55     |
| Markdale Rec & Daycare                |                               |         |         | 0%    | \$ -                  |           |       | 0%                             | \$ -      | 0%          | \$ -      | \$ -        | \$ -          | 30,516  | 0      |

**Table 125: Savings Potential for 14 Low Savings Potential Indoor Recreational Facilities**

Savings potential is considered high if 30% or more, moderate if between 11 and 29%, and low if 10% or less.



Average % savings for each energy component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) / \text{Actual Energy Use}$  and \$/year savings for each component are calculated as  $(\text{Actual Energy Use} - \text{Target Energy Use}) * \text{utility company rates}$  \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas.

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company CDM Incentives are calculated based on \$0.08/kWh of electricity and \$0.10/m<sup>3</sup> of natural gas saved.

# Indoor Sports Arenas

---

## Table of Contents

|          |   |            |
|----------|---|------------|
| <b>1</b> | <b>Benchmarking and Conservation Potential .....</b>                                      | <b>255</b> |
| 1.1      | Energy Use and Building Characteristics.....  | 255        |
| 1.1.1    | Building Characteristics.....   | 255        |
| 1.1.2    | Summary of Energy Use and Costs .....   | 255        |
| 1.2      | Energy Targets.....   | 258        |
| 1.3      | Savings Potential.....  | 259        |
| <b>2</b> | <b>Conservation Measures and Budget.....</b>  | <b>261</b> |
| 2.1      | Previous Energy Efficiency Initiatives.....   | 261        |
| 2.2      | Proposed Energy Efficiency Measures .....   | 261        |
| <b>3</b> | <b>Energy Management and Retrofit Plan .....</b>  | <b>268</b> |
| 3.1      | Implementation Costs and Modeled Savings .....  | 268        |
| 3.2      | Implementation Process and Tools – Determining the Specific Measures for Each Building .. | 268        |
| 3.2.1    | Building Performance Audit.....   | 269        |
| 3.2.2    | Energy Assessment .....   | 270        |
| 3.2.3    | Energy Savings Checklist .....  | 270        |
| 3.3      | Implementation Budget.....  | 271        |
| 3.4      | 10-Year Implementation Plan .....   | 271        |
| <b>4</b> | <b>Appendix A.....</b>  | <b>274</b> |
| 4.1      | Selection of 2012 Utility Bills for Calculation of Actual Energy Use Intensities.....     | 274        |
| 4.2      | Determining Energy Use Components.....  | 274        |
| 4.3      | Determining Targets .....   | 274        |
| 4.4      | Calculating Potential Savings .....   | 276        |
| 4.5      | Implementation Costs by Measure Type and Modeled Savings.....                             | 276        |
| 4.6      | Assessment Tools.....   | 277        |
| <b>5</b> | <b>Appendix B - Indoor Sports Arenas .....</b>  | <b>279</b> |
| 5.1      | Buildings and Building Characteristics .....  | 279        |
| 5.2      | Energy Use Intensities.....   | 280        |
| 5.3      | Target-setting Method and Metrics.....  | 281        |

## List of Tables

|   |     |
|---|-----|
| Table 126: Current Renewable Energy Systems on Indoor Sports Arena.....                     | 255 |
| Table 127: 2012 Energy Use and Costs for 27 City of Toronto Indoor Sports Arenas .....      | 256 |
| Table 128: Top Quartile Targets .....   | 258 |
| Table 129: Savings Potential Summary.....   | 259 |
| Table 130: Savings Potential Based on Energy Use Component for 27 Indoor Sports Arenas..... | 260 |
| Table 131: 2004 Arenas Project Estimated Project Costs and Savings .....                    | 261 |
| Table 123: Energy Saving Measures for Indoor Sports Arenas.....                             | 266 |
| Table 133: Proposed Renewable Energy Systems on Indoor Sports Arenas .....                  | 267 |
| Table 134: Estimated Implementation Costs and Modeled Savings .....                         | 268 |
| Table 135: Assessment Tools Used to Determine Specific Energy-saving Measures .....         | 269 |
| Table 136: Total Budget - Energy Management and Retrofit Plan .....                         | 271 |
| Table 137: Cash Flow for 10-Year Implementation Plan .....                                  | 272 |
| Table 138: Implementation Costs by Measure Type .....                                       | 276 |
| Table 139: Indoor Sports Arena Building Information .....                                   | 279 |
| Table 140: Indoor Sports Arena 2012 Energy Intensity .....                                  | 280 |
| Table 141: Excluded Facilities .....  | 281 |
| Table 142: Savings Potential for 2 High Savings Potential Indoor Sports Arenas.....         | 284 |
| Table 143: Savings Potential for 20 Medium Savings Potential Indoor Sports Arenas.....      | 285 |
| Table 144: Savings Potential for 5 Low-Savings Potential Indoor Sports Arenas .....         | 285 |

## List of Figures

|   |     |
|---|-----|
| Figure 75: 2012 Energy Use and Cost Breakdown for 27 City of Toronto Indoor Sports Arenas ..... | 256 |
| Figure 76: 2012 Total Energy Intensity Benchmark.....   | 257 |
| Figure 77: 2012 Total Electricity Intensity Benchmark .....                                     | 257 |
| Figure 78: 2012 Total Gas Intensity Benchmark .....   | 258 |
| Figure 79: Cash Flow for 10-Year Implementation Plan .....                                      | 273 |
| Figure 80: 2012 Electric Baseload Intensity Benchmark.....                                      | 281 |
| Figure 81: 2012 Electric Cooling Intensity Benchmark .....                                      | 282 |
| Figure 82: 2012 Electric Heating Intensity Benchmark.....                                       | 282 |
| Figure 83: 2012 Gas Baseload Intensity Benchmark.....   | 283 |
| Figure 84: 2012 Gas Heating Intensity Benchmark.....  | 283 |

## 1 Benchmarking and Conservation Potential

### 1.1 Energy Use and Building Characteristics

#### 1.1.1 Building Characteristics

The City of Toronto is reporting on 27 indoor sports arenas in the Energy Conservation Demand Management (ECDM) Plan. The names, addresses and building areas are provided in Appendix B.

The total area for all of the buildings is 862,996 ft<sup>2</sup>. Indoor sports arenas range in size from just over 22,300 ft<sup>2</sup> to over 65,400 ft<sup>2</sup>.

The facilities equipped with a renewable energy system are presented in the table below:

| Building Name          | Building Address   | Renewable Installation | System Size | Unit |
|------------------------|--------------------|------------------------|-------------|------|
| Agincourt Arena        | 31 Glen Watford Dr | Solar Photovoltaic     | 48          | kW   |
| Mimico Arena           | 31 Drummond St     | Solar Photovoltaic     | 50          | kW   |
| York Mills CC Arena    | 2539 Bayview Ave   | Solar Photovoltaic     | 75          | kW   |
| Victoria Village Arena | 190 Bermondsey Rd  | Solar Photovoltaic     | 84          | kW   |

**Table 126: Current Renewable Energy Systems on Indoor Sports Arena**

The facilities range from 0% to 100% air-conditioned. There are a number of other facilities using between 5 and 20% electric heat. No facilities are served by water source heat pumps. There are food services at the majority of the facilities, all with approximately 5% of the building served. The majority of the arenas have 1 ice pad, with the exception of Etobicoke Centennial Arena which has 2 ice pads. The ice pads range in size from 14,400 to 17,000 ft<sup>2</sup>. The time period of ice-in ranges from 6 to 8 months.

#### 1.1.2 Summary of Energy Use and Costs

This Energy Conservation Demand Management (ECDM) Plan is based on energy use taken from monthly bills for the 2012 calendar year. Energy costs are presented throughout using \$0.14 per kWh of electricity and \$0.26 per m<sup>3</sup> of gas. Refer to Appendix A (section 'Selection of 2012 utility bills for calculation of actual energy use intensities') for the methodology used to calculate the energy use intensities from the utility bills. Total energy use and costs for the 27 buildings are summarized below.

|                               | 2012 Energy Use |                    |
|-------------------------------|-----------------|--------------------|
|                               | Unit            | \$                 |
| Electricity (kWh)             | 19,946,566      | \$2,792,519        |
| Natural Gas (m <sup>3</sup> ) | 1,490,132       | \$387,434          |
| <b>Total</b>                  |                 | <b>\$3,179,954</b> |

Table 127: 2012 Energy Use and Costs for 27 City of Toronto Indoor Sports Arenas




Figure 75: 2012 Energy Use and Cost Breakdown for 27 City of Toronto Indoor Sports Arenas

There is a wide range of energy use intensities as presented below, due primarily to differences in efficiency between the 27 buildings. Total energy use ranges from approximately 21.6 to 93.6 ekWh/ft<sup>2</sup>. There are also wide ranges for electricity and gas use per ft<sup>2</sup>. The red line represents the top quartile. The corresponding data for total energy, total electricity and total gas for each building is located in Appendix B.




Figure 76: 2012 Total Energy Intensity Benchmark




Figure 77: 2012 Total Electricity Intensity Benchmark




Figure 78: 2012 Total Gas Intensity Benchmark

## 1.2 Energy Targets

The energy targets for indoor sports arenas are presented in the table below. The target-setting methodology is based upon all buildings improving to the top quartile intensity for each component of energy use, and is described in Appendix B. The goal is for each indoor sports arena to achieve its target over the duration of the ECDM Plan.

| Energy type  | Component | Value | Unit                       |
|--------------|-----------|-------|----------------------------|
| Electricity  | Base      | 20.4  | kWh/ft <sup>2</sup> /year  |
|              | Cooling   | 0.8   | kWh/ft <sup>2</sup> /year  |
|              | Heating   | 0.4   | kWh/ft <sup>2</sup> /year  |
|              | Total     | 21.5  | kWh/ft <sup>2</sup> /year  |
| Gas          | Base      | 2.0   | ekWh/ft <sup>2</sup> /year |
|              | Heating   | 8.7   | ekWh/ft <sup>2</sup> /year |
|              | Total     | 10.6  | ekWh/ft <sup>2</sup> /year |
| Total energy | Total     | 32.2  | ekWh/ft <sup>2</sup> /year |

Table 128: Top Quartile Targets

The data set for target-setting is made up of 37 indoor sports arenas with complete and reliable data, 25 of which are City of Toronto buildings and 12 are from other municipalities. Before calculation of potential savings for each building, the energy use component targets were adjusted for site specific factors including electric heat (% building served and % for Domestic Hot Water (DHW)), % of the area



which is air conditioned, % of the area served by food services, area of the ice surface and months of ice-in. The specific target adjustments are found in Appendix A.

### 1.3 Savings Potential

The difference between the actual 2012 energy use and the adjusted target represents the potential annual savings for each energy component in each indoor sports arena. The total savings potential for each indoor sports arena is then determined as the sum of the components. Some buildings have very high percentage and dollar potential while other more efficient buildings have little or no potential. The 27 indoor sports arenas are categorized as high potential (annual savings of over \$100,000), medium (mid) potential (annual savings between \$5,000 and \$100,000) and low potential (annual savings of less than \$5,000). The savings potential for each individual building is summarized in Appendix B.

There are 2 indoor sports arenas with annual savings potential greater than \$100,000. 20 indoor sports arenas have annual savings potential between \$5,000 and \$100,000, and 5 indoor sports arenas have annual savings potential less than \$5,000 (see Table 3).

The total annual savings potential for the 27 buildings is \$1,210,887 (\$1,098,965 for electricity and \$111,922 for gas) with an average total energy savings of 35%.

For the 2 high-potential savings facilities, the total annual savings potential is \$326,348 (\$292,800 for electricity and \$33,547 for gas) with an average total energy savings of 56%.

For the 20 mid-potential savings facilities, the total annual savings potential is \$877,330 (\$799,904 for electricity and \$77,426 for gas) with an average total energy savings of 35%.

For the 5 low-potential savings facilities, the total annual savings potential is \$7,210 (\$6,261 for electricity and \$949 for gas) with an average total energy savings of 2%.


| Operation name                        | Electricity Savings Potential |            |            |            |                    | Gas Savings Potential |            |            |                  | Total Energy Savings Potential |                    | Incentives       |                 | Indoor Area<br>ft <sup>2</sup> | GHG Emissions<br>kg/yr |
|---------------------------------------|-------------------------------|------------|------------|------------|--------------------|-----------------------|------------|------------|------------------|--------------------------------|--------------------|------------------|-----------------|--------------------------------|------------------------|
|                                       | Average %                     |            |            |            | \$/yr              | Average %             |            |            | \$/yr            | Avg %                          | \$/yr              | Electricity      | Gas             |                                |                        |
|                                       | Base-load                     | Cooling    | Heating    | Total      |                    | Base-load             | Heating    | Total      |                  |                                |                    |                  |                 |                                |                        |
| <b>TOTAL: 27 facilities</b>           | <b>31%</b>                    | <b>00%</b> | <b>16%</b> | <b>39%</b> | <b>\$1,098,965</b> | <b>65%</b>            | <b>20%</b> | <b>29%</b> | <b>\$111,922</b> | <b>35%</b>                     | <b>\$1,210,887</b> | <b>\$627,980</b> | <b>\$43,047</b> | <b>862,996</b>                 | <b>1,672,325</b>       |
| High potential savings facilities (2) | 50%                           | 00%        | 00%        | 59%        | \$ 292,800         | 81%                   | 32%        | 53%        | \$ 33,547        | 56%                            | \$ 326,348         | \$167,315        | \$12,903        | 99,814                         | 472,502                |
| Mid-potential savings facilities (20) | 31%                           | 00%        | 25%        | 41%        | \$ 799,904         | 61%                   | 20%        | 27%        | \$ 77,426        | 35%                            | \$ 877,330         | \$457,088        | \$29,779        | 606,040                        | 1,188,046              |
| Low potential savings facilities (5)  | 02%                           | 00%        | 00%        | 02%        | \$ 6,261           | 00%                   | 03%        | 02%        | \$ 949           | 02%                            | \$ 7,210           | \$ 3,578         | \$ 365          | 157,142                        | 11,777                 |

**Table 129: Savings Potential Summary**

GHG emissions reduction is based on 110g GHG/kWh of electricity and 1879g GHG/m<sup>3</sup> of natural gas. Utility company incentives are calculated based on \$0.08/kWh of electricity (a composite of \$0.05/kWh for lighting retrofits and \$0.10 for non-lighting measures) and \$0.10/m<sup>3</sup> of natural gas saved.

The savings potential for each individual energy component points to where the biggest savings are to be found and guides the priorities for implementation. Table 4 below shows the total potential savings for all 27 buildings and highlights where the greatest percentage savings are.

| Energy and Water Components   | 2012 Use    | Target      | Savings Potential % | Savings Potential \$ |
|---|-------------|-------------|---------------------|----------------------|
| Electric Baseload (kWh/ft <sup>2</sup> )  | 29.7        | 20.3        | 31%                 | \$ 1,029,692         |
| Electric Cooling (kWh/ft <sup>2</sup> )   | 0.3         | 0.0         | 100%                | \$ 1,756             |
| Electric Heating (kWh/ft <sup>2</sup> )   | 0.5         | 0.4         | 16%                 | \$ 10,675            |
| Total Electricity (kWh/ft <sup>2</sup> ) for facilities w/o component intensities | 21.9        | 16.4        | 25%                 | \$ 56,843            |
| Gas Baseload (ekWh/ft <sup>2</sup> )  | 4.2         | 1.4         | 65%                 | \$ 53,907            |
| Gas Heating (ekWh/ft <sup>2</sup> )   | 14.0        | 11.2        | 20%                 | \$ 55,037            |
| Total Gas (ekWh/ft <sup>2</sup> ) for facilities w/o component intensities        | 14.8        | 13.2        | 11%                 | \$ 2,978             |
| <b>Total Energy (ekWh/ft<sup>2</sup>)</b>   | <b>41.0</b> | <b>26.7</b> | <b>35%</b>          | <b>\$ 1,210,887</b>  |



**Table 130: Savings Potential Based on Energy Use Component for 27 Indoor Sports Arenas**

Savings potential is considered high if it is 30% and above, moderate if between 10 and 29% and low if less than 10%.

Components with the highest percentage savings potential (i.e. Electric Cooling and Gas Baseload) will be given higher priority in terms of recommended measures for implementation. In many cases, Electric Baseload measures can provide a significant portion of dollar savings. However, they generally require significant capital investment and will therefore be implemented in later years.

## 2 Conservation Measures and Budget

### 2.1 Previous Energy Efficiency Initiatives

In 2004, the City of Toronto undertook a study to identify building improvement measures that would improve energy and water efficiency and reduce the operating cost and environmental impact of arenas located throughout the City of Toronto.

Table 131 below summarizes the estimated overall project costs, savings and estimated energy reduction for 89 arenas as a result of the 2004 project.

| Project Name & Year | Num. of Bldgs | Total Floor Area (m2) | Project Cost & Annual Savings (estimated) |                 |                    |                            |         | Estimated Energy Reduction |                        |                        |                  |
|---------------------|---------------|-----------------------|---|-----------------|--------------------|----------------------------|---------|----------------------------|------------------------|------------------------|------------------|
|                     |               |                       | Retrofit Cost                             | Total \$Savings | Total ekWh Savings | Total CO2 Savings (tonnes) | Payback | Electricity Savings kWh    | Electricity Savings kW | Natural Gas Savings m3 | Water Savings m3 |
| Arena 2004          | 89            | 206,485               | \$9,932,267                               | \$1,217,181     | 19,815,506         | 4,298                      | 8.2     | 9,051,822                  | 3,649                  | 1,040,804              | 1,469            |

**Table 131: 2004 Arenas Project Estimated Project Costs and Savings**

The design and construction of the measures took place from January 2005 to June 2007. Various Energy Conservation Measures (ECMs) were installed in 89 ice arenas, outdoor rinks and community centres. The majority of the indoor arenas in this ECDM Plan were part of this 2004 project. These measures included design and retrofit of energy efficient lighting, lighting controls, improved temperature controls, ventilation controls, insulation, building envelope and refrigeration controls. Training and energy awareness was also provided as part of this project.

### 2.2 Proposed Energy Efficiency Measures

Table 123 below shows the full range of possible energy efficiency measures for the entire portfolio of indoor sports arenas. The measures are grouped based on the component of energy use they relate to and have been sorted based on chronology of implementation.

The measures are categorized by system type - lighting (L), mechanical (M), electrical (EL), envelope (EN), process (P) (i.e. domestic hot water) and behavioural (B) measures. The profiles of energy use and conservation potential for the 27 facilities indicate that the largest percentage will come from measures associated with electric cooling and gas baseload, the majority of which are low/no cost measures.

The measures have been prioritized in order to help make an informed decision on which to implement first. Priorities are set using the criteria of 'Energy Savings Potential' and 'Ease of Implementation'. Each measure was assigned a score from 1 to 4 for both energy savings potential and ease of implementation.

For Energy Savings Potential, a score of 4 was assigned to measures with the greatest percentage energy savings potential and a score of 1 was assigned to measures with the smallest percentage energy savings potential. For Ease of Implementation, a score of 4 was assigned to measures that are the easiest to implement and a score of 1 to measures that are the most difficult to implement.

The Energy Savings Potential scoring was determined using the following criteria:

4 – Savings potential is greater than 40%

3 – Savings potential is 30-40%

2 – Savings potential is 20-30%

1 – Savings potential is less than 20%

The Ease of Implementation scoring was determined using the following criteria:

4 – Measure can be done immediately by building occupants or service contractors (little/no cost)

3 – Measure involves testing, tuning, measuring (low cost)

2 – Measure involves significant investigation/optimization (more significant costs)

1 – Measure involves replacement/installation involving capital costs

The measures with the highest combined Energy Savings Potential and Ease of Implementation scores (out of 8) are deemed the highest priority.

Accordingly the Overall score associated to the proposed measures can be summarized as follows:

1 - Least energy savings potential; Most difficult to implement



8 - Greatest energy savings potential; Easiest to implement

### **Timelines**

Measures recommended to be implemented in Year 1 (the year of the initial assessment) are behavioural measures that can be done immediately without capital budgets. Measures recommended for Year 2 will generally result in high percentage savings, are mainly operational and do not require significant capital costs. Year 3 measures will provide high percentage savings (i.e. measures related to electric cooling and gas baseload) but have associated capital costs (i.e. installation and replacement measures). Measures to be implemented in Year 4 and Year 5 are those that have significant associated capital costs and may result in high dollar savings but less significant percentage energy savings (i.e. measures related to all other energy components).