



NOTES:

1. ANY JUNCTION MADE IN SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP TO BE MADE WITH APPROVED COUPLINGS.
2. ALL WATER SERVICES TO BE INSTALLED AT RIGHT ANGLES TO THE WATERMAIN UNLESS APPROVED OTHERWISE.
3. DRY TAPPING IS PROHIBITED.
4. PARK SERVICES AND OTHER SEASONAL SERVICES MUST HAVE SELF DRAINING CURB STOPS. THE BACKFILL AROUND THE SELF DRAINING CURB STOP MUST BE 25 mm CLEAR STONE.
5. TRACER WIRES ARE REQUIRED ON ALL NON-METALLIC SERVICE CONNECTIONS AND PRIVATE WATER SERVICE PIPES.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING AND CONSTRUCTION SERVICES STANDARD DRAWING

REV 1

APR 2013

STANDARD WATER SERVICE CONNECTION DETAILS
32 mm, 38 mm AND 50 mm DIAMETER SIZES

T-1104.02-1

NTS

SHEET 1