



OVERHEAD SUPPLY INSTALLATION ON A DIRECT BURIED POLE

OVERHEAD SUPPLY INSTALLATION ON A STEEL POLE

NOTES

- 1 Number of ground plates or rods, and the size of ground wire, shall be as indicated elsewhere in the contract. See TTD 806.010
- 2 Modify size of conduits according to layout drawings.
- 3 For power supply disconnect, schematic wiring diagram, See TTD 806.005
- 4 Maximum distance from Disconnect pole to Hydro supply point is 7.0m.
- 5 All dimensions are in millimetres unless otherwise shown.



**POWER SUPPLY DISCONNECT INSTALLATION
 DETAILS FOR OVERHEAD POWER FEED
 (TCD OVERHEAD CABLE)**

SCALE
 NOT TO SCALE

REVISION DATE
 JANUARY, 2018

Traffic Plant Installation and Maintenance

APPROVED BY:
 J. R. C.

DRAWN BY:
 O. G.

PLAN No.
806.001