


NOTES:

1. ANY WATER SERVICE EXCEEDING 20 METRES IN LENGTH WITHIN THE CUL-DE-SAC WILL HAVE A MINIMUM DIAMETER OF 25 mm.
2. FOR OFFSET OF WATERMAIN FROM STREETLINE, REFER TO TYPICAL STANDARD ROAD CROSS - SECTION.

All dimensions are in millimetres unless otherwise shown.

	ENGINEERING AND CONSTRUCTION SERVICES STANDARD DRAWING	REV 1	APR 2013
	TYPICAL 150 mm WATERMAIN ON CUL-DE-SAC		T-1107.05
		NTS	SHEET 1