



NOTES:

1. USE 50mm GATE VALVE AND PLUG FOR TESTING WHERE REQUIRED.
2. CONCRETE TO BE 20MPa COMPRESSIVE STRENGTH.
3. FLANGED FITTINGS ARE REQUIRED FOR ALL COMPOUND METERS.
4. BY-PASS LINE TO BE THE SAME AS METER LINE.
5. WORKING SPACE IN FRONT OF METER MUST HAVE 2m HEAD CLEARANCE.
6. ALL CHECK VALVES, BACK FLOW PREVENTERS, AND PRESSURE REDUCING VALVES MUST BE LOCATED BEYOND THE BY-PASS.
7. BY-PASS VALVE TO BE CLOSED & SEALED BY THE CITY.
8. THE METER INSTALLATION SHALL CONFORM TO THE MANUFACTURER'S REQUIREMENTS.

 METRIC
ALL DIMENSIONS SHOWN HERE ARE IN MILLIMETRES UNLESS OTHERWISE NOTED

APPROVED BY

 TOM DENES, P. ENG.
 EXECUTIVE DIRECTOR TECHNICAL SERVICES

SCALE
 N.T.S.

DATE: JUNE, 2001

REVISED:

STANDARD No.

T-1107.03-1



INSTALLATION DETAILS FOR
 A COMPOUND WATER METER