



NOTES:

1. t = THICKNESS OF SIDEWALK.
2. SIDEWALK THICKNESS 150 mm EXCEPT ACROSS COMMERCIAL, INDUSTRIAL AND HIGH DENSITY RESIDENTIAL DRIVEWAY WHERE IT SHALL BE 180 mm.
3. JOINTS SHALL BE ACCORDING TO T-310.010-1.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

REV 2

NOV 2014

**COMBINED CONCRETE CURB
AND SIDEWALK**

T-310.010-4

NTS

SHEET 1