

REVISION INFORMATION SHEET

CONSTRUCTION STANDARDS FOR SEWERS AND WATERMAINS

REVISION NO. 4 – NOVEMBER 2007

Subject: Standard Specifications and Drawings

| Superseded / Cancelled (Remove) | Revised / New (Insert) | Description | Remarks |
|---|--|--|---|
| T-1105.02-1 Jan 2004 | T-1105.02-1 Aug 2007 | “STANDARD SERVICE CONNECTION – 1” | Revised Title Block , & removed reference to former “ Works & Emergency Services ”. |
| T-1105.02-2 Jan 2004 | T-1105.02-2 Aug 2007 | “STANDARD SERVICE CONNECTION – 2” | Revised Title block & removed reference to former “ Works & Emergency Services ” |
| T-1107.03-1 Feb 2006 (Sheet 1 of 3) | T-1107.03-1 Aug 2007 (Sheet 1 of 3) | “INSTALLATION DETAILS FOR COMPOUND, TURBINE OR ELECTROMAGNETIC TYPE WATER METER IN BUILDINGS” | Revised the size of the “ Floor Drain to Sanitary Sewer ” from “150mm Dia. Min.” to “ 100mm dia. Min. ” |
| T-1107.04-1 Feb 2006 (Sheet 1 of 3) | T-1107.04-1 Aug 2007 (Sheet 1 of 3) | “INSTALLATION DETAILS FOR 37mm AND 50mm POSITIVE DISPLACEMENT WATER METER IN ALL BUILDINGS” | Revised the size of the “ Floor Drain to Sanitary Sewer ” (from “150mm Dia. Min.” to) “ 100mm dia. Min. ” |
| T-1107.04-3 Jun 2001 | T-1107.04-3 Aug 2007 | “ DETAIL OF CONNECTIONS WITH CROSS OR TEE FOR WATERMAINS ” | Revised Title Block and title Description |
| T-1107.04-6 Feb 2006 (Sheet 1 of 3) | T-1107.04-6 Aug 2007 (Sheet 1 of 3) | “INSTALLATION DETAILS FOR 16mm AND 25mm POSITIVE DISPLACEMENT WATER METER IN ALL BUILDINGS OTHER THAN SINGLE FAMILY RESIDENTIAL BUILDINGS” | Revised the size of the “ Floor Drain to Sanitary Sewer ” (from “150mm Dia. Min.” to) “ 100mm dia. Min. ” |