



## UNRESTRAINED - LOW RISK

### NOTES:

1. SUPPLY AND INSTALL COUPLING (EXPOSING COATED SLEEVE) WITH GASKETS, TO SUIT O.D. OF CAST IRON PIPE.
2. FIELD VERIFY O.D. OF CAST IRON PIPE PRIOR TO ORDERING CONNECTION COUPLING.
3. PATCH LINING OF CAST IRON PIPE AT POINT OF CONNECTION.
4. WRAP PIPE AND COUPLING WITH DENSO PASTE AND TAPE.
5. THIS DRAWING IS APPLICABLE TO LARGE DIAMETER WATERMAINS SIZES 750 TO 2300 mm DIA.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

REV 0

SEP 2017

### PROPOSED STAINLESS STEEL PIPE CONNECTION TO EXISTING CAST IRON PIPE

T-1110.03-18

NTS

SHEET 1