

## REVISION INFORMATION SHEET

### CONSTRUCTION STANDARDS FOR SEWERS AND WATERMANS

**REVISION NO. 5 – APRIL 2008**

**Subject: Standard Specifications and Drawings**

Superseded / Cancelled (Remove)	Revised / New (Insert)	Description	Remarks
T-701.010 Apr 2007	<b>T-701.010</b> Mar 2008	“Precast Maintenance Hole 1200mm Diameter”	Revisions to Note 3.
T-701.011 Jun 2001	<b>T-701.011</b> Mar 2008	“Precast Maintenance Hole 1500mm Diameter”	Revisions to Note 3.
T-701.012-1 Jun 2001	<b>T-701.012-1</b> Mar 2008	“Precast Maintenance Hole 1800mm Diameter”	Revisions to Note 3.
T-701.013 Jun 2001	<b>T-701.013</b> Mar 2008	“Precast Maintenance Hole 2400mm Diameter”	Revisions to Note 3.
T-1104.02-1 Jun 2001	<b>T-1104.02-1</b> Mar 2008	“Standard Water Service Connection Details – 32mm, 38mm and 50mm Diameter Sizes”	Revised drawing title.
T-1104.02-2 Jan 2004	<b>T-1104.02-2</b> Mar 2008	“Tapping Sleeve and Valve Connection Details”	Correction to title of drawing.
T-1106.02 June 2001	<b>T-1106.02</b> May 2006	“Thermite Welding of Metallic Water Mains”	Revised title block.
T-1106.03 Jun 2001	<b>T-1106.03-1</b> Jan 2008 (1 of 2)	“Electrical Bonding of Iron Water Mains”	Revised title block.
N/A	<b>T-1106.03-2</b> Jan 2008 (2 of 2)	“Electrical Bonding of Iron Water Mains”	New drawing.
T-1106.04 Jun 2001	<b>T-1106.04</b> Jan 2008	“Cathodic Protection for Valves Not in Chamber - Iron Fittings, Hydrants & Service Connection on Non-Metallic Mains”	Revised title block and magnesium anode changed to zinc anode.
T-1106.05 Jun 2001	<b>T-1106.05</b> May 2006	“Cathodic Protection for New Ductile Iron Water Main Construction”	Revised title block.
T-1106.06 Jun 2001	<b>T-1106.06</b> Jan 2004	“Cathodic Protection On Short Sections of Ductile Iron Water Mains”	Revised title block.
T-1106.07 Jan 2004	<b>T-1106.07</b> May 2006	“Test Station for Cathodic Protection of Ductile Iron Water Mains”	Revised title block.
N/A	<b>T-1106.08</b> May 2006	“Test Station with Cathodic Protection Monitoring Probe for New or Existing Iron Water Mains”	New drawing.

TS 7.30 Jun 2007	<b>TS 7.30</b> Apr 2008	“Procedure for Disinfecting Water Mains”	Wording in section TS 7.30.09.02 reworded to make instructions clearer.
TS 701 Jun 2001	<b>TS 701</b> Mar 2008	“Amendments to OPSS 701 (Nov 06) – Construction Specification for Watermain Installation in Open Cut”	Wording added about direction to open valves based on where district watermain is located.
Mtl./Manufacturer Specifications for Watermains Jun 2007	<b>Mtl./Manufacturer Specifications for Watermains</b> Apr 2008	“Material / Manufacturer Specifications for Distribution Watermains and Appurtenances”	Revisions to section T.S. 2.2 - page 1, T.S. 7.1 - page 4, T.S. 12 - page 6, T.S. 13 - page 7