

TS No.	Superseded (Remove)	Revised/New (Insert)	Remarks
TS 7.30	Apr 2013	Jan 2015	<p>Procedure for Disinfecting Watermains</p> <ul style="list-style-type: none"> • Subsection 7.30.05.01 Disinfectants; revised. • Clause 7.30.07.02.01 Submission of Disinfection Proposal Plan; heading revised. • Clause 7.30.07.02.02 Supervision, Testing and Records; second paragraph revised, last sentence revised. • Clause 7.30.07.02.03 Valve Operation; paragraph revised. • Subsection 7.30.08.03 Flushing after Disinfection; 1.5 mg/L changed to 2.0 mg/L. • Subsection 7.30.09.02 Water Sampling and Analytical Tests; 1.5 mg/L changed to 2.0 mg/L, second sentence in second paragraph rewritten. • Subsection 7.30.09.05 Water Quality Guidelines for Disinfection Approval; first sentence rewritten. • Existing subsection 7.30.09.07 Final Flushing; heading revised to Connecting to Existing System, first paragraph rewritten. • Table 2; Value for total chlorine residual changed to 2.0 mg/L.

TS No.	Superseded (Remove)	Revised/New (Insert)	Remarks
TS 7.60	Apr 2013	Jan 2015	<p>Specification for the Cured-In-Place Lining of Watermains</p> <ul style="list-style-type: none"> • Section 7.60.01 Scope; revised first paragraph. • Section 7.60.02 Information to be Submitted with Bid; revised list number 5, new list number 6, renumbered list number 7 and 8. • Section 7.60.05 Temporary Watermain Bypass Lines; heading revised. • Section 7.60.05 Temporary Water Services; heading revised. • Section 7.60.18 CCTV Equipment, Inspections and Reports; heading revised. Entire section written. • Section 7.60.19 Preliminary CCTV Inspection – V1; existing paragraphs deleted and rewritten. • Section 7.60.21 Cleaning and Preparation of Watermain; first paragraph revised. • Section 7.60.22 Measuring Inside Diameter of Watermain; new section. • Section 7.60.24 Post Cleaning and Preparation CCTV Inspection – V2; existing paragraphs deleted and rewritten. • Section 7.70.25 Materials; revised cross reference from TS 7.60.26 to TS 7.60.28 • Section 7.60.26 Tight Fit of Liner to Watermains; new section. • Section 7.60.27 Diametric Sizing; first paragraph revised, new 3rd paragraph added, 4th paragraph revised, revised cross reference from TS 7.60.27 to TS 7.60.29. • Section 7.60.28 Design Requirements; new sub section Liner Thickness and Stretching Out for Tight Fit. • Section 7.60.29 Liner Fit, Finish and Properties; heading revised, entire section rewritten. • Section 7.60.30 Installation; sub section Wet –out and Curing Requirements rewritten. • Section 7.60.32 Field Lining Samples and Testing; heading revised, entire section rewritten.
TS 7.70	Apr 2013	Jan 2015	<p>Watermain Replacement and Connection Procedure</p> <ul style="list-style-type: none"> • Throughout specification Technical Services renamed to Engineering and Construction Services. • Section 7.70.03 Connecting to Branch Connections; revised process – all steps. • Figure 1; revised. • Section 7.70.04 Connecting to Source Feeder Watermain; revised process – all steps. • Figure 2; revised.
TS 7.80	- - - -	Jan 2015	<p>Material Specification for Large Diameter Watermains</p> <ul style="list-style-type: none"> • New specification.