

TS No.	Superseded (Remove)	Revised/New (Insert)	Remarks
TS 7.30	Nov 2016	Apr 2017	<p>Procedure for Disinfecting Watermains</p> <ul style="list-style-type: none"> • Section 7.30.03 Definitions; wet taps definition added. • Clause 7.30.07.03.01 Tapping; entire clause rewritten, certified operator only allowed to perform wet taps. • Subsection 7.30.09.04 Sampling for Short Filler Pieces and Appurtenances; change to one sample from two samples; revised. • Section 7.30.10 Disinfection of Watermains in Emergency Situations; revised paragraph. • Subsection 7.30.10.02 Category 2; paragraph revised. • Subsection 7.30.10.03 Sewage or Chemical Contamination; new subsection.
TS 7.70	Nov 2016	Apr 2017	<p>Watermain Replacement and Connection Procedure</p> <ul style="list-style-type: none"> • Clause 7.70.07.01 New Watermain System; Step 7 revised to say one bacteriological sample, was two before. Step 9 revised to say a minimum of two branch connections. • Clause 7.70.07.02 Connecting to Branch Connections; Step 4 revised. Step 9 and 10 changed to Toronto Water. Step 12 revised to say one bacteriological sample, was two before. • Clause 7.70.07.03 Connecting to Source Feeder Watermain with Backflow Protected Bypass; revised heading title. First paragraph revised. Step 12 revised to say one bacteriological sample, was two before. Step 14 revised to say a minimum of two branch connections. • Note 1; revised.