



DIAMETER (mm)	T (mm)
750-1500	150
1550-1900	200
>1900	300

NOTES:

1. THIS DRAWING IS APPLICABLE TO LARGE DIAMETER WATERMAINS SIZES 750 TO 2300 mm DIA.
2. DESIGNER/ENGINEER TO SPECIFY SURFACE RESTORATION AS REQUIRED.
3. CONCRETE REINFORCEMENT GREATER THAN 5 m OR TO SUIT STEEP SLOPES AND TRANSITION TO 5 m DEPTH.
4. PRIOR TO REMOVAL OF SUPPORT SYSTEM ANY VOIDS TO BE FILLED WITH APPROVED BACKFILL.

All dimensions are in millimetres unless otherwise shown.

	ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING	REV 0	APR 2017
	TRENCH DETAIL HIGH RISK CONCRETE ENCASED WELDED STEEL PIPE		T-1110.01-10
		NTS	SHEET 1