



NOTES:

1. ANY JUNCTION MADE IN SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP TO BE MADE WITH APPROVED COUPLINGS.
2. ALL WATER SERVICES TO BE INSTALLED AT RIGHT ANGLES TO THE WATERMAIN UNLESS APPROVED OTHERWISE.
3. DRY TAPPING IS PROHIBITED.
4. ALL 20mm AND 25mm SERVICES TAPPED INTO A PVC WATERMAIN MUST BE TAPPED THROUGH A PVC SADDLE.
5. FOR ANY JUNCTION MADE IN THE SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP, COUPLINGS WILL NOT BE PERMITTED UNLESS THE SERVICE LENGTH EXCEEDS 20m.
6. ALL WATER SERVICES TO BE INSTALLED 90° TO THE LONGITUDINAL AXIS OF THE WATERMAIN.

METRIC
ALL DIMENSIONS SHOWN HERE ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



WORKS & EMERGENCY SERVICES

TECHNICAL SERVICES DIVISION
Engineering Services - Works Facilities & Structures

| | | | |
|-----------|---------------|---|------------------|
| SCALE: | N.T.S. | STANDARD WATER SERVICE CONNECTION DETAILS 20mm AND 25mm DIAMETER SIZES | DRAWING NUMBER: |
| DATE: | JANUARY, 2004 | | T-1104.01 |
| DRAFTING: | V. DIDIANO | | SHEET: 1 |