



NOTES:

1. ANY JUNCTION MADE IN SERVICE PIPE BETWEEN MAIN STOP AND CURB STOP TO BE MADE WITH APPROVED COUPLINGS.
2. ALL WATER SERVICES TO BE INSTALLED AT RIGHT ANGLES TO THE WATERMAIN UNLESS APPROVED OTHERWISE.
3. DRY TAPPING IS PROHIBITED.
4. PARK SERVICES AND OTHER SEASONAL SERVICES MUST HAVE SELF DRAINING CURB STOPS. THE BACKFILL AROUND THE SELF DRAINING CURB STOP MUST BE 25mm CLEAR STONE.

METRIC
ALL DIMENSIONS SHOWN HERE ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TECHNICAL SERVICES
Engineering Services - Works Facilities & Structures

SCALE:	N.T.S.	STANDARD WATER SERVICE CONNECTION DETAILS 32mm, 38mm AND 50mm DIAMETER SIZES	DRAWING NUMBER:
DATE:	MARCH 2008		T-1104.02-1
DRAFTING:	V. DIDIANO		SHEET: 1