


NOTES:

1. NOT ALL TEST STATIONS INCLUDE BOTH ANODE AND CATHODIC PROTECTION MONITORING PROBE LEAD WIRES.
2. ALL EXPOSED THERMITE WELDS MUST BE PROTECTED WITH A THICK COAT OF MASTIC.

All dimensions are in millimetres unless otherwise shown.

	ENGINEERING AND CONSTRUCTION SERVICES STANDARD DRAWING	REV 1	APR 2013
	TEST STATION WITH CATHODIC PROTECTION MONITORING PROBE FOR NEW OR EXISTING IRON WATER MAINS	T-1106.08	
		NTS	SHEET 1