



NOTES

1. Clearances to underground utilities and other guy anchors as shown on `Normal guying requirements' apply to `Sidewalk Strut' details.

GUY ATTACHMENT

- 2. Where it is impractical to install power driven anchors, 250 mm dia. expandable type anchors shall be installed and native backfill shall be compacted.
- 3. Pole attachment height to be set using applicable drawings TTD 804.025, 804.030 and 804.035.
- 4. Guy steel strand shall be to CSA Standard G12-1971 and shall be 8 mm dia. Grade 180.
- 5. For pole setting depth, see TTD 805.005.
- 6. This drawing applies to low voltage and traffic signal installations only.
- 7. Dimensions are in millimetres or metres, unless otherwise shown.

