

- 1. For base mounting details, anchor assembly, template details and cabinet orientation see standard TTD 807.020. For duct orientation and size refer to layout drawing.
- 2. Top of footing to be installed at 50mm above finished grade.
- 3. For more than 2 ducts, provide wire mesh 6mm dia., 100 x 100mm, 150mm from top of controller footing.
- 4. Concrete base shall be level.
- 5. Solvent weld caps (scepter or equal) of the proper size shall be placed on ends of all unused rigid PVC conduit.
- 6. Anchor bolts installed in locations according to cabinet manufacturer's layout drawing.

Dimensions are in millimetres or metres, unless otherwise shown.

