



NOTES:

1. FOR SERVICE CONNECTIONS 100 mm DIA OR LARGER, THE SERVICE LINE VALVE MAY BE LOCATED AT THE WATERMAIN LOCATION ON THE STREET IF THE LENGTH OF THE SERVICE CONNECTION IS LESS THAN 3.5 m.
2. ALL SERVICE LINE VALVES 100 mm AND LARGER WILL BE INSTALLED IN VALVE BOXES.
3. WATER METER SETBACK FROM PROPERTY LINE 30 m OR GREATER AS MEASURED ALONG THE ALIGNMENT OF THE WATER SERVICE PIPE WILL REQUIRE A METER CHAMBER.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING AND CONSTRUCTION SERVICES STANDARD DRAWING

REV 3

APR 2013

STANDARD SERVICE CONNECTION - 2

T-1105.02-2

NTS

SHEET 1