



NOTES

1. For duct entry details see standard TTD 802.025.
2. Unshrinkable fill to be placed as backfill in excavated area around handwell.
3. Ground rod can be used in place of ground plate.
4. For handwells with metal covers and non-metallic frames, the ground wire shall be attached to the handwell cover using a ground lug suitable for #6 AWG copper wire.
5. For specific handwell details see standards TTD 802.001, TTD 802.005, TTD 802.006

Dimensions are in millimetres or metres, unless otherwise shown.