



NOTES:

1. ALL EXCAVATIONS FOR TOE WALLS TO BE BACKFILLED WITH GRANULAR 'A' MATERIAL.
2. WEEP HOLES SHALL BE PLACED SO THAT THE TOP OF THE WEEPER ON THE INSIDE AND THE BOTTOM OF THE WEEPER ON THE OUTSIDE ARE LEVEL.
3. SIDEWALK AND EXPANSION JOINT AS T-310.010-1.
4. MAXIMUM LENGTH OF TOE WALL SECTIONS TO BE 6.0m ,13mm FLEXCELL (OR EQUIVALENT) EXPANSION JOINT MATERIAL TO BE PLACED BETWEEN ADJACENT SECTIONS.
5. CLASS OF CONCRETE 32 MP<sub>a</sub>, CLASS 2 EXPOSURE.
6. PERFORATED PIPE SUB-DRAIN 150mm DIA. WITH PERFORATIONS DOWN TO BE USED ONLY AS SHOWN ON PLANS OR AS SPECIFIED.

METRIC  
ALL DIMENSIONS SHOWN HERE ARE IN MILLIMETRES UNLESS OTHERWISE NOTED

APPROVED BY TOM DENES, P. ENG.  
EXECUTIVE DIRECTOR TECHNICAL SERVICES

SCALE N.T.S.



CONCRETE TOE WALLS

DATE: JUNE, 2001

REVISED:

STANDARD No.  
T-601.01-2