



NOTES:

1. USE BIBBY STE-CROIX PART No. S-69080 OR APPROVED EQUAL.
2. THE SAMPLING ACCESS POINT SHALL BE LOCATED OUTSIDE OF THE BUILDING ON PRIVATE PROPERTY CLOSE TO THE PROPERTY LINE AND UPSTREAM OF THE CONTROL MAINTENANCE ACCESS HOLE.
3. A SEPARATE SERVICE CONNECTION FOR GROUNDWATER IS NOT PERMITTED. THE CONNECTION OF THE GROUNDWATER DISCHARGE LINE SHALL BE MADE UPSTREAM OF THE STORM OR SANITARY CONTROL MAINTENANCE ACCESS HOLE BASED ON THE GROUNDWATER QUALITY AND SUBJECT TO APPROVAL.
4. THE GROUNDWATER SAMPLING ACCESS POINT SHALL BE INSTALLED DIRECTLY UPSTREAM OF THE STORM OR SANITARY CONTROL MAINTENANCE ACCESS HOLE BASED ON THE GROUNDWATER QUALITY AND SUBJECT TO APPROVAL.
5. A 1200 mm BUFFER CLEARANCE IS REQUIRED FROM THE EDGE OF THE MAINTENANCE ACCESS HOLE COVER.
6. THE OVERHEAD CLEARANCE REQUIRED FOR THE SAMPLING ACCESS POINT IS THE DEPTH OF THE SAMPLING ACCESS POINT, FROM GRADE TO THE BOTTOM OF THE GROUNDWATER LINE PLUS 2000 mm.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

**GROUNDWATER SAMPLING ACCESS POINT
WITH MAINTENANCE ACCESS HOLE
FRAME AND COVER**

REV 0

APR 2018

T-709.020

NTS

SHEET 1