



NOTES:

1. BACKWATER VALVE (HUB 7 SPIGOT) TO BE SPECIFIED ONLY IF CONNECTING TO SANITARY.
2. USE BIBBY STE-CROIX PART No. S-69080 OR APPROVED EQUAL.
3. USE IPEX PVC CLEANOUT WITH PLUG NO. 026301 OR APPROVED EQUIVALENT.
4. INSTALL 200 mm CLEANOUT, COVER PLATE MARKED SEWER CLEAN-OUT BOLTED, SIGMA PART No. VB-SC08L OR APPROVED EQUIVALENT.
5. THE SAMPLING PORT SHALL BE LOCATED OUTSIDE OF THE BUILDING ON PRIVATE PROPERTY CLOSE TO THE PROPERTY LINE AND UPSTREAM OF THE CONTROL MAINTENANCE ACCESS HOLE.
6. NO SEPARATE SERVICE CONNECTION FOR GROUNDWATER. CONNECTION SHALL BE UPSTREAM OF THE STORM OR SANITARY CONTROL MAINTENANCE ACCESS HOLE BASED ON THE GROUNDWATER QUALITY AND SUBJECT TO APPROVAL.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

REV 0

NOV 2016

**GROUNDWATER SAMPLING
PORT DETAIL**

T-708.04

NTS

SHEET 1