

**General Notes Revision History**  
April 2018 version

The revisions to the general notes (April 2018) version include:

<b>Construction Notes</b>	
<b>(Delete or append construction notes as required)</b>	<p>Add: new clarification note in brackets. For this column only, user can delete any of the notes 1 to 12 or append their own notes as required. Do not rewrite any of the notes, just delete and append your own new construction notes.</p> <p>Construction notes reordered from 1 to 12.</p>
<b>Contact Information</b>	
<b>(Delete or append contact information notes as required)</b>	<p>Add: new clarification note in brackets. For this column only, user can delete any of the notes 1 to 4 or append their own notes as required. Do not rewrite any of the notes, just delete and append your own new contact information notes.</p>
<b>Watermains</b>	
<b>Note 1</b>	<p>Add: PVC pipes ranging in size from 350 mm through 600 mm in diameter, shall be pressure rating 235, DR 18 according to AWWA C905-10.</p>
<b>Sanitary and Storm Sewers</b>	
<b>Note 6</b>	<p>Remove text "Type B open (storm)" from end sentence as not required.</p>

Contact: Robert Klimas at 416-392-8388 or [Robert.Klimas@toronto.ca](mailto:Robert.Klimas@toronto.ca)

**General Notes Revision History**  
August 2017 version

The changes to the general notes (August 2017) version include:

<b>Watermains</b>	
<b>Note 1</b>	Added: molecularly oriented polyvinyl chloride (PVCO) pipes ranging in size from 100 mm to 300 mm in diameter Pressure Class 235 AWWA C909-09.
<b>Note 5</b>	Added: or Pressure Class 235 AWWA C909-09.

  

<b>Sanitary and Storm Sewers</b>	
<b>Note 3</b>	Revised Granular A to: Granular A Native or Granular A RCM
<b>Note 4</b>	Revised Granular A to: Granular A Native or Granular A RCM

Contact: Robert Klimas at 416-392-8388 or [Robert.Klimas@toronto.ca](mailto:Robert.Klimas@toronto.ca)

**General Notes Revision History**  
December 2016 version

The changes to the general notes (January 2015) version include:

<b>Construction Notes</b>	
<b>Note 10</b>	Revised wording about vertical clearances between watermains and gas mains to be in line with Appendix D – Utility Separations.

  

<b>Contact Information</b>	
<b>Note 3</b>	TTC contact information updated.

  

<b>Sanitary and Storm Sewers</b>	
<b>Note 6</b>	Change from Type B (open) to Type A (closed) for storm sewer maintenance hole cover

Contact: Robert Klimas at 416-392-8388 or [Robert.Klimas@toronto.ca](mailto:Robert.Klimas@toronto.ca)