



TYPICAL ZONES WITHIN SIDEWALK

MINIMUM PEDESTRIAN CLEARWAY WIDTHS AND SIDEWALK PLACEMENT

ROADWAY CLASSIFICATION	SIDEWALK ON ONE OR BOTH SIDES	MINIMUM PEDESTRIAN CLEARWAY WIDTH *
MAJOR ARTERIAL	BOTH SIDES	2.1 m
MINOR ARTERIAL	BOTH SIDES	2.1 m
COLLECTOR	BOTH SIDES	2.1 m
LOCAL	AT LEAST ONE SIDE	2.1 m BUT CAN BE REDUCED TO 1.8 m ON ROADS WITH LOW PEDESTRIAN VOLUMES AND LOW VEHICLE SPEEDS AND VOLUMES

* IN AREAS WHERE HIGHER PEDESTRIAN VOLUMES DEMAND, AN INCREASE IN PEDESTRIAN CLEARWAY WIDTHS WILL BE REQUIRED. CONSULT WITH CITY STAFF TO REVIEW GUIDELINES AND STANDARDS TO ADDRESS CONTEXT-SPECIFIC CONDITIONS.

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

PEDESTRIAN CLEARWAY WIDTHS ON SIDEWALKS

REV 1

SEP 2018

T-310.010-10

NTS

SHEET 1