



**Notes:**

1. The top 0.5 m shall consist of hard cap and granular fill to a minimum depth of 0.5 m. Final pavement structure will dictate depth.
2. Below the 0.5 m of hard cap and granular fill is an additional 1.5 m of unimpacted fill.
3. Where there are utility pipes that are deeper than 1.5 m from the ground surface, there shall be unimpacted fill to the top of the utility pipe.
4. Below the base of each new utility pipe to a minimum depth of 0.5 m below the utility pipe there must be unimpacted fill.
5. For any utility pipe that has a diameter of 0.9 m or less, there must be a minimum of 0.6 m of unimpacted fill on either side of the utility pipe.
6. For any utility pipe that has a diameter greater than 0.9 m, there must be a minimum of 1.3 m of unimpacted fill on either side of the utility pipe.

All dimensions are in millimetres unless otherwise shown.

	ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING	REV 0	SEP 2019
	<b>CLEAN FILL REQUIREMENTS FOR CONTAMINATED LANDS</b>	<b>T-985.100</b>	
	<b>TYPICAL STREET</b>	NTS	SHEET 1