

Superseded/Cancelled (Remove)		Revised/New (Insert)		Drawings for Sewers and Watermains
T No.	Revision	T No.	Revision	Remarks
All T-drawings				Revision numbers: <ul style="list-style-type: none"> Revision No. 0 means original release. Revision No. 1 means first revision. Revision No. 2 means second revision Revision No. 3 means third revision and so on.
T-701.010 Apr 2014	3	T-701.010 Sep 2020	4	Precast Maintenance Hole 1200 mm Diameter <ul style="list-style-type: none"> Note 4; Revise depth from 5.0 to 4.5 m to align with Occupation Health and Safety Act (O. Reg. 213/91 section 286 (1)).
T-701.011 Apr 2014	3	T-701.011 Sep 2020	4	Precast Maintenance Hole 1500 mm Diameter <ul style="list-style-type: none"> Note 4; Revise depth from 5.0 to 4.5 m to align with Occupation Health and Safety Act (O. Reg. 213/91 section 286 (1)).
T-701.013 Apr 2014	3	T-701.013 Sep 2020	4	Precast Maintenance Hole 2400 mm Diameter <ul style="list-style-type: none"> Note 4; Revise depth from 5.0 to 4.5 m to align with Occupation Health and Safety Act (O. Reg. 213/91 section 286 (1)).
T-705.010 Apr 2013	1	T-705.010 Sep 2020	2	Precast Catch Basin With Sump <ul style="list-style-type: none"> New Note 7. Goss trap now mandatory. The "if specified" note removed.
T-705.010-2 Apr 2013	1	T-705.010-2 Sep 2020	2	Cast in Place Catch Basin With Sump <ul style="list-style-type: none"> New Note 7. Goss trap now mandatory. The "if specified" note removed.
T-705.010-4 Apr 2013	1	T-705.010-4 Sep 2020	2	Cast In Place Catch Basin With Sump – Double Top <ul style="list-style-type: none"> New Note 7. Goss trap now mandatory. The "if specified" note removed.
T-705.020 Apr 2013	1	T-705.020 Sep 2020	2	Precast Double Catch Basin With Sump <ul style="list-style-type: none"> New Note 7. Goss trap now mandatory. The "if specified" note removed.
T-708.01 Apr 2013	1	T-708.01 Sep 2020	2	Drain and Sewer Connections for Concrete Pipe for Sewers 600mm Diameter or Smaller <ul style="list-style-type: none"> Title of drawing revised to: Rigid Sewer Service Connections / Catchbasin Leads Connected to Rigid Sewer Main Pipes

Superseded/Cancelled (Remove)		Revised/New (Insert)		Drawings for Sewers and Watermains
T-708.03 Apr 2013	1	----	----	Catchbasin Connection – Flexible Pipe Sewer • Drawing Cancelled.
----	----	T-1006.010 Sep 2020	0	Flexible Sewer Service Connections / Catchbasin Leads Connected to Flexible/Rigid Sewer Main Pipes • New drawing. Taken from OPSD 1006.010.
T-1006.01-1 Sep 2017	2	T-1006.01-1 Sep 2020	3	Typical Connection to City Trunk Sewer 675mm I.D. or Larger from Concrete to Concrete • Note 1; revised. • Note 3: deleted. • Note on drawing revised.
T-1101.010 Apr 2014	2	T-1101.010 Sep 2020	3	Circular Precast Gate Valve Chamber 400 mm Diameter Watermains and Smaller • Title Revised; add word 'gate' to title of drawing. • Show 'F' dimension on Wall Opening Detail. • New Note 11.
T-1101.030-1 Apr 2014	2	T-1101.030-1 Sep 2020	3	Circular Precast Butterfly Valve Chamber 400 mm Diameter Watermains and Smaller • Title Revised; add word 'circular' to title of drawing.