

## **Wet and Dry Tapping – WM214SS**

---

Supplementary Specification

February 28, 2022

---

### **Amendment to TS 7.30, September 2020**

#### **TS 7.30.07 CONSTRUCTION**

##### **TS 7.30.07.03.01 Tapping**

Clause 7.30.07.03.01 of TS 7.30 is amended by the addition of the following paragraph:

The Contractor shall perform Wet Taps using their own licensed staff. Contractor may hire a licenced sub-contractor to witness Wet Taps. A person with a P.Eng. only is not acceptable as a qualified person.

Contractor shall supply certificate number of qualified person according to [www.OWWCO.ca](http://www.OWWCO.ca) . Contractor shall enter the information and complete the Wet Tap Witness Form and provide a copy to the Contract Administrator by end of the Working Day.

Contract Administrator shall verify if person is a qualified person according to [www.OWWCO.ca](http://www.OWWCO.ca). After receiving the Wet Tap Witness Form from the Contractor and confirmation with the site inspector, the Contractor Administrator shall enter the information into the Wet Tap App within 24 hours.

### **Amendment to WM203SP, September 2018**

#### **Small Diameter Water Service Installation – WM203SP**

##### **Installation of Small Diameter Water Services**

Section Installation of Small Diameter Water Services is amended by the deletion of the third sentence and replacing with the following:

Water service connections, 50 mm and smaller shall be connected to the new watermain under pressure, that is to say wet tapping.

Contractor may "dry tap" water services negating the use of license staff. Dry tapping shall only be performed during mainline construction only.