



Electromagnetic Locking Devices

Folder No.	

Project In	formation		
Street No.	Street Name		
Locations w	ithin building		
		Yes	No
	ling has a Fire Alarm System that complies with subsection 3.2.4 of the OBC or is acceptable to the Chief Fire Official.		
2. The devi	ce releases:		
a) immed	liately upon activation of the Fire Alarm System		
b) upon I	oss of power: (i) to the fire alarm control panel, or		
	(ii) to the EMLD and its associated auxiliary controls		
	activation of a manually operated switch controlling all locking devices in the ng and accessible only to authorized personnel		
	a fault being detected in the electrical circuit between the fire alarm control panel be controller of the EMLD		
	activation of the manual pull station that is located no more than 600mm from the frame of the door		
3. There is of the d	a manual pull station for the Fire Alarm System located on the wall within 600mm oor.		
ALARM"	a legible sign having the words "EMERGENCY EXIT UNLOCKED BY FIRE permanently mounted on the exit door and the lettering on the sign is at least ligh with a 5mm stroke.		
5. Emerger	cy lighting is provided at the door(s).		
6. Upon rele to in 2c)	ease, all EMLD's can only be reset by manual activation of the switch referred		

Continue on next page.



Electromagnetic Locking Devices

The undersigned hereby certifies that the electromagnetic locking device has been installed in a fail-safe mode at the location(s) noted above and meets all the requirements and provisions of the OBC 3.4.6.15.(4),(5),(6),(7) and 3.4.6.17.(3), Canadian Electrical Code, Part I, Section 32 and CAN/ULC-S524-M as applicable <u>and</u> the fire alarm system has been verified in accordance with CAN/ULC-S537-M, as per OBC 3.2.4.5.(2). A third party report for the verification, and for the testing of the Fire Alarm System in conformance with CAN/ULC S536, will be submitted.

Installer Information					
First Name		Last Name		Company Name	
Street No.	Street Name				Telephone No.
City/Town Provi		Province	e Postal Code		Suite/Unit No.
Signature Date (yyyy-mm-dd)				yy-mm-dd)	

The undersigned hereby certifies that the manually operated switch is accessible only to authorized personnel and the operation of these devices is part of the approved FIRE SAFETY PLAN for the building.

D: . :	O	presentativ	- I£	
RIIIIAINA	()W/nar/Re	nracantativ	a int	ormation
Dunania		DIESCHLAUV	C	OHIBLIOH

First Name		Last Name		Position	
Street No.	Street Name				Telephone No.
City/Town Province		Province		Postal Code	Suite/Unit No.
			,		
Signature				Date (y	vyyy-mm-dd)

Note

The installation will not be acceptable to Building and Fire Services unless:

- (i) the device meets all the above requirements,
- (ii) this form is completed in full and signed by the Installer and the Building Owner and
- (iii) the verification report is attached.