

Engineering & Construction Services Division Standard Specifications for Sewers and Watermains

Revision No. 21

September 2024

TS No.	Superseded (Remove)	Revised/New (Insert)	Remarks
TS 4.10	Sep 2022	Feb 2024	 Specification for the Cured-In-Place Pipe (CIPP) for the Lining of Sewers and Culvers Specification revised and rewritten by Toronto Water.
TS 7.30	Sep 2020	Sep 2024	Procedure for Disinfecting Watermains
			 WM214SS, Wet and Dry Tapping supplementary specification is cancelled and content incorporated into TS 7.30.
			 Section 7.30.02 References; Practice 8 title revised.
			 Clause 7.30.07.03.01 Tapping; added contractor can perform wet taps using their own licensed staff, supply certificate of qualified person.
			 Clause 7.30.09.04.01 Connections Greater than One Pipe Length; added province of Ontario Watermain Disinfection Procedure to first paragraph. Delete last paragraph and add criteria for procedure to follow if any exceptions.
			 Form TS 115; added signature line for certified operator on Page 4.
TS 7.60	Sep 2022	Nov 2023	Specification for the Cured-In-Place Lining of Watermains
			 Specification revised and rewritten by Toronto Water.