



NOTES

- 1 Duct entry holes shall be filled with expandable foam.
- 2 Rigid ducts terminating in maintenance holes, handholes, or other permanent openings of underground systems shall be provided with an end bell.
- 3 Concrete encasement to be used where applicable.

Dimensions are in millimetres or metres, unless otherwise shown.



ENTRY OF DIRECT BURIED AND ENCASED DUCTS INTO ELECTRICAL HANDWELL

SCALE
NOT TO SCALE

REVISION DATE
SEPTEMBER, 2024

Traffic Management Section

APPROVED BY:

--

DRAWN BY:

Y. J.

PLAN No.

802.025