



NOTES:

1. CONCRETE SHALL BE 32 MPa AT 28 DAYS.
2. PARGING MIX ON ALL BRICKWORK SHALL BE 1:3 MORTAR MIX AND APPLIED 15 mm THICK.
3. ALL JOINTS AND LIFTING HOLES SHALL BE COMPLETELY FILLED WITH A 1:3 MORTAR MIX AND POINTED BEFORE BACKFILLING.
4. BACKFILL SHALL BE UNSHRINKABLE FILL.
5. WHERE WEEPHOLES ARE USED BACKFILL WITH 50 mm CRUSHED STONE IN MIN. 300 mm WEDGE TO DEPTH OF WEEPHOLES.
6. ALTERNATE WALL THICKNESS SHALL BE 150 mm WHERE SPECIFIED.

PLAN

All dimensions are in millimetres unless otherwise shown.



ENGINEERING & CONSTRUCTION SERVICES STANDARD DRAWING

OFFSET CATCH BASIN WITH SUMP

REV 0

SEP 2025

T-705.011

NTS

SHEET 1